



# POUDRE SCHOOL DISTRICT

## SOLAR AND STORAGE FEASIBILITY STUDY

FINAL REPORT  
FORT COLLINS, CO  
JULY 2023

Together, Building a Thriving Planet

# Table of Contents

- EXECUTIVE SUMMARY .....5**
- METHODOLOGY..... 12**
  - 2.1 General Approach .....13
  - 2.2 Conceptual Design and Energy Modeling .....13
  - 2.3 Bill Savings Analysis.....13
  - 2.4 Cost Estimation ..... 14
  - 2.5 Financial Modeling ..... 14
  - 2.6 Construction Service Market Conditions.....15
  - 2.7 Inflation Reduction Act (IRA) Impacts.....16
  - 2.8 Assumptions, Inclusions, and Exclusions.....17
- PORTFOLIO DETAILS ..... 18**
  - 3.1 Portfolios.....19
  - 3.2 Financially Feasible Portfolio Details .....25
    - 3.2.1 Bamford Elementary School .....25
    - 3.2.2 Bethke Elementary School.....29
    - 3.2.3 Eyestone South Elementary School .....32
    - 3.2.4 Rice Elementary School .....35
    - 3.2.5 Timnath Middle/ High School.....38
    - 3.2.6 Wellington Middle/ High School ..... 41
  - 3.3 Financially Not Feasible Portfolio Details .....45
    - 3.3.1 Beattie Elementary .....45
    - 3.3.2 Blevins Middle School.....48
    - 3.3.3 Boltz Middle School .....51
    - 3.3.4 Cache la Poudre Middle School.....54
    - 3.3.5 Fort Collins High School .....55
    - 3.3.6 Fossil Ridge High School .....58
    - 3.3.7 Johannsen Support Services Center.....61
    - 3.3.8 Kinard Core Knowledge Middle School .....63
    - 3.3.9 Preston Middle School.....66
    - 3.3.10 Poudre High School.....69
    - 3.3.11 Rocky Mountain High School .....72
    - 3.3.12 South Bus Terminal.....75
    - 3.3.13 Traut Core Knowledge Elementary School .....78
    - 3.3.14 Warehouse 5 .....81
    - 3.3.15 Werner Elementary School.....85
- ENVIRONMENTAL, PERMITTING, ZONING AND RISK CONSIDERATIONS .....88**
  - 4.1 Environmental Considerations.....89
  - 4.2 Permitting, and Planning and Zoning.....89
  - 4.3 Other Risk Considerations .....91
- EQUIPMENT CONSIDERATIONS AND O&M .....89**

# Table of Contents

- 5.1 Equipment Considerations and Recommended Operations & Maintenance (O&M) .....90
- 5.2 Major Equipment Selection Criteria .....90
- 5.3 Recommended O&M .....91
  
- FINANCIAL FUNDING OPTIONS, AND NEXT STEPS ..... 94**
- 6.1 Funding Options.....95
- 6.2 PPA Overview.....95
- 6.3 Next Steps.....96
  
- APPENDIX A: STRUCTURAL CAPACITY ASSESSMENTS ..... 100**
  
- APPENDIX B: INTERCONNECTION ASSESSMENTS ..... 106**

# Contacts

## ***McKinstry Contacts***

**Martin Beggs**

Project Director – Renewables

720.386.4941

[martinb@mckinstry.com](mailto:martinb@mckinstry.com)

**Tim DeLeo**

Renewable Energy Engineer

508.813.9472

[timdel@mckinstry.com](mailto:timdel@mckinstry.com)

**Lauren Bridgers**

Project Director

720.583.5895

[laurenb@mckinstry.com](mailto:laurenb@mckinstry.com)

**Jordan Worthington**

Account Executive I

303.656.6152

[jordanw@mckinstry.com](mailto:jordanw@mckinstry.com)

## ***Poudre School District Contacts***

**Brett Larsen**

Director of Special Projects and Initiatives

970.490.3215

[blarsen@psdschools.org](mailto:blarsen@psdschools.org)

**Trudy Trimbath**

Energy and Sustainability Manager

970.490.3502

[ttrimbath@psdschools.org](mailto:ttrimbath@psdschools.org)



Section

1



# Executive Summary

# 1. Executive Summary

In February 2023, Poudre School District (PSD) contracted with McKinstry to perform a feasibility study for solar photovoltaic (PV) and battery energy storage systems (BESS) across 62 different sites throughout the district. The goal of the feasibility study is to investigate opportunities to deploy ground, carport canopy, and roof-mounted solar arrays and BESS to progress PSD’s renewable energy goals. McKinstry’s feasibility assessment incorporates technical, financial, sustainability, and many other considerations, as detailed in McKinstry’s High Performance Buildings Bond Planning Proposal.

As a result of the feasibility study and in consideration of all PSD’s priorities, McKinstry has engineered a series of PV arrays and BESS which were designed to meet the goals above and assembled these into two portfolios (Financially Feasible and Technically Feasible, but Not Financially Feasible), along with four BESS sites. In general, the solar PV sites which are supplied electrical service by City of Fort Collins Utilities (FCU), as well as all BESS sites were found to have challenging financial outcomes.

## Solar Photovoltaic – Financially Feasible Portfolio

| Site              | PV System Type          | DC Capacity (kWDC) | Year 1 Production (kWh) | GHG Reduction (MTCO2) | Building Consumption Offset |
|-------------------|-------------------------|--------------------|-------------------------|-----------------------|-----------------------------|
| Bamford ES        | Roof                    | 202.0              | 302,000                 | 124.7                 | 73.8%                       |
| Bethke ES         | Fixed Tilt Ground Mount | 137.7              | 220,900                 | 91.3                  | 76.9%                       |
| Eyestone ES South | Fixed Tilt Ground Mount | 110.2              | 189,400                 | 78.2                  | 100.9%                      |
| Rice ES           | Fixed Tilt Ground Mount | 142.6              | 241,700                 | 99.8                  | 77.2%                       |
| Timnath MS/HS     | Roof                    | 679.3              | 1,003,200               | 414.3                 | 99.0%                       |
| Wellington MS/HS  | Roof                    | 679.3              | 1,003,200               | 414.3                 | 94.3%                       |
| <b>Totals</b>     |                         | <b>1,951.0</b>     | <b>2,960,400</b>        | <b>1,222.7</b>        | <b>90.4%</b>                |

*\*GHG Reduction based on Xcel Energy guidelines of 1kWh=0.000413MTCO2*

# 1. Executive Summary

## Solar Photovoltaic – Technically Feasible, But Not Financially Feasible Portfolio

| Site                              | PV System Type          | DC Capacity (kWDC) | Year 1 Production (kWh) | GHG Reduction* (MTCO <sub>2</sub> ) | Building Consumption Offset |
|-----------------------------------|-------------------------|--------------------|-------------------------|-------------------------------------|-----------------------------|
| Beattie ES                        | Fixed Tilt Ground Mount | 202.0              | 327,300                 | 135.2                               | 97.4%                       |
| Blevins MS                        | Carport                 | 248.4              | 363,100                 | 150.0                               | 93.1%                       |
| Boltz MS                          | Carport                 | 197.1              | 295,400                 | 122.0                               | 56.3%                       |
| Fort Collins HS                   | Carport                 | 1222.6             | 1,715,800               | 708.6                               | 91.4%                       |
| Fossil Ridge HS GM                | Fixed Tilt Ground Mount | 679.3              | 1,126,300               | 465.2                               | 55.5%                       |
| Johannsen Support Services Center | Carport                 | 151.2              | 216,800                 | 89.6                                | 90.1%                       |
| Kinard Core Knowledge MS          | Carport                 | 268.9              | 388,700                 | 160.5                               | 60.5%                       |
| Preston MS                        | Fixed Tilt Ground Mount | 388.8              | 626,800                 | 258.9                               | 75.6%                       |
| Poudre HS                         | Carport                 | 871.6              | 1,301,400               | 537.5                               | 82.1%                       |
| Rocky Mountain HS                 | Carport                 | 1164.2             | 1,761,400               | 727.5                               | 95.1%                       |
| South Bus Terminal                | Flush Mount             | 101.0              | 136,800                 | 56.5                                | 79.3%                       |
| Traut Core Knowledge ES           | Carport                 | 156.6              | 234,400                 | 96.8                                | 87.5%                       |
| Warehouse 5                       | Roof                    | 110.2              | 151,800                 | 62.7                                | 29.2%                       |
| Werner ES                         | Fixed Tilt Ground Mount | 128.5              | 213,800                 | 88.3                                | 96.9%                       |
| <b>Totals</b>                     |                         | <b>5,789.4</b>     | <b>8,723,000</b>        | <b>3,602.6</b>                      | <b>77.1%</b>                |

\*GHG Reduction based on Xcel Energy guidelines of 1kWh=0.000413MTCO<sub>2</sub>

# 1. Executive Summary

The Financially Feasible portfolio includes sites where Xcel Energy, Poudre Valley REA (PVREA), and The City of Loveland Water and Power supply electricity to the facilities. These sites were found to have a value of solar energy (VOSE) that leads to financially feasible projects.

**Financial Summary – Direct Ownership, Financially Feasible**

| Site              | PV System Type          | Estimated System Cost* | Estimated System Cost with 30% IRA Contribution* | Year 1 Utility Savings | Estimated Simple Payback with 30% IRA and Applicable Incentives** |
|-------------------|-------------------------|------------------------|--|------------------------|---|
| Bamford ES        | Roof                    | \$750,300              | \$525,210  | \$23,300               | 22.5  |
| Bethke ES         | Fixed Tilt Ground Mount | \$579,800              | \$405,860  | \$22,400               | 18.0  |
| Eyestone ES South | Fixed Tilt Ground Mount | \$497,600              | \$348,320  | \$19,800               | 17.6  |
| Rice ES           | Fixed Tilt Ground Mount | \$592,500              | \$414,750  | \$33,300               | 12.5  |
| Timnath MS/HS     | Roof                    | \$1,992,200            | \$1,394,540                                      | \$98,300               | 14.2  |
| Wellington MS/HS  | Roof                    | \$2,001,900            | \$1,478,500                                      | \$69,800               | 20.00   |
| <b>Totals</b>     |                         | <b>\$6,414,300</b>     | <b>\$4,567,180</b>                               | <b>\$266,900</b>       | <b>16.8</b>   |

\*Costs and savings are estimated to be +/- 20% and reflect conditions at Q2, 2023. Savings include utility bill savings and incentives. Financial summary above assumes projects are contracted as a portfolio.

\*\*Simple payback does not include O&M, decommissioning, inverter replacement, and utility rate escalation.

McKinstry has determined a very low VOSE for the sites within the FCU service area. These low VOSE sites lead to many system paybacks longer than the expected life of the PV systems. Because of these long paybacks, we have estimated pricing based on a per-project basis and would look to PSD for guidance on which sites to move forward to an implementation phase.

# 1. Executive Summary

## Financial Summary – Direct Ownership Technically Feasible, but Not Financially Feasible

| Site                              | PV System Type          | Estimated System Cost* | Estimated System Cost with 30% IRA Contribution* | Year 1 Utility Savings | Estimated Simple Payback with 30% IRA and Applicable Incentives** |
|-----------------------------------|-------------------------|------------------------|--|------------------------|---|
| Beattie ES                        | Fixed Tilt Ground Mount | \$816,500              | \$571,500  | \$17,250               | 30.2  |
| Blevins MS                        | Carport                 | \$1,348,100            | \$943,700  | \$20,500               | 43.4  |
| Boltz MS                          | Carport                 | \$1,111,300            | \$778,900  | \$17,200               | 42.4  |
| Fort Collins HS                   | Carport                 | \$5,140,500            | \$3,598,400                                      | \$95,800               | 37.0  |
| Fossil Ridge HS GM                | Fixed Tilt Ground Mount | \$2,174,200            | \$1,521,900                                      | \$63,300               | 23.2  |
| Johannsen Support Services Center | Carport                 | \$895,300              | \$626,700  | \$12,800               | 45.1  |
| Kinard Core Knowledge MS          | Carport                 | \$1,443,100            | \$1,010,200                                      | \$19,700               | 48.7  |
| Preston MS                        | Fixed Tilt Ground Mount | \$1,381,100            | \$966,800  | \$34,900               | 26.3  |
| Poudre HS                         | Carport                 | \$3,858,500            | \$2,700,900                                      | \$72,800               | 36.4  |
| Rocky Mountain HS                 | Carport                 | \$4,930,000            | \$3,451,000                                      | \$97,400               | 34.9  |
| South Bus Terminal                | Flush Mount             | \$403,500              | \$282,500  | \$10,700               | 21.8  |
| Traut Core Knowledge ES           | Carport                 | \$925,700              | \$648,000  | \$13,200               | 45.2  |
| Warehouse 5                       | Roof                    | \$404,900              | \$283,400  | \$9,300                | 25.2  |
| Werner ES                         | Fixed Tilt Ground Mount | \$599,800              | \$419,900  | \$11,700               | 31.70   |
| <b>Totals</b>                     |                         | <b>\$25,432,500</b>    | <b>\$17,803,800</b>                              | <b>\$496,550</b>       | <b>34.3</b>   |

\*Costs and savings are estimated to be +/- 20% and reflect conditions at Q2, 2023. Savings include utility bill savings and incentives. Financial summary above assumes projects are contracted as a portfolio.

\*\*Simple payback does not include O&M, decommissioning, inverter replacement, and utility rate escalation.



# 1. Executive Summary

## *BESS Portfolio - (Battery Energy Storage System)*

The BESS sites were chosen with guidance from PSD and the analysis focused on determining the potential demand saving values and resiliency functionality. These systems were integrated with the solar PV where applicable, but cost/savings analyses are separate from the PV systems. As the table below shows, the demand management system paybacks far exceed the expected 10-year lifespan of the BESS. While the economics are poor, additional value can be derived from resiliency functionality at Cache la Poudre and the Warehouse 5. BESS details can be found in Section 3 for the following sites:

- Bamford Elementary School
- Cache la Poudre Middle School
- Warehouse 5
- Wellington Middle / High School

**BESS – Portfolio Details**

| Site               | Use Case                                 | BESS Size    | Total Project Cost* | Total Project Cost with 30% IRA Contribution* | Simple Payback (years)** |
|--------------------|--|--------------|---------------------|---|--------------------------|
| Bamford ES         | Utility Bill Optimization                | 125kW/250kWh | \$516,200           | \$361,300                                     | 42.6                     |
| Cache la Poudre MS | Backup Power                             | 125kW/250kWh | \$529,400           | N/A   | N/A                      |
| Warehouse 5        | Utility Bill Optimization & Backup Power | 125kW/250kWh | \$529,400           | \$370,600                                     | 57.8                     |
| Wellington MS/HS   | Utility Bill Optimization                | 250kW/500kWh | \$753,600           | \$527,500                                     | 20.6                     |

*\*The financial results above are in addition to PV systems, where applicable, and are priced on an individual project basis.*

*\*\*Simple payback does not include O&M, decommissioning, inverter replacement, and utility rate escalation.*

# 1. Executive Summary

---

## *Funding Opportunities*

Several funding options have been identified to support project implementation. To get the Financially Not Feasible Solar PV Portfolio payback below 20 years, PSD would need to make a capital contribution through allocated stimulus funding or bundle additional measures with a payback shorter than the overall recommended portfolio through an Energy Savings Performance Contract. The following are opportunities for PSD to consider for funding the Financially Feasible solar PV project portfolio option above and are further described in Section 6:

- **Energy Savings Performance Contracting (ESPC)**
- **Tax Exempt Lease Purchase (TELP)**
- **Certificates of Participation (COP)**
- **Bonds**
- **Debt-free Mill Levy**
- **Power Purchase Agreement (PPA)**
- **Grant funding**
- **Xcel Renewable Energy Credits (RECs) and SPVTOU rate**
- **Combination of above funding options**

Section

2



Methodology

## 2. Analysis Methodology

---

### 2.1 General Approach

The portfolio described in this section is the result of our data collection, analysis, and costing activities, as well as ongoing discussions with PSD personnel. The evaluation utilized the approach outlined in McKinstry's RFP response and included the following key steps.

1. **Learn.** Data collection, documentation review, and identification of and initial engagement with key PSD staff.
2. **Audit.** Assess data, verify site conditions, review utility usage by site.
3. **Analyze.** Analyze data, produce conceptual designs, solicit PSD feedback, model system outputs, estimate bill savings, and create the preliminary cost estimate.
4. **Finalize Analysis and Cost Estimates.** Finalize designs, savings analyses, cost estimates, portfolio composition and financial assessments.
5. **Report.**

Our approach sought to maximize capacity and offset at each site to realize best installed costs and bill savings. Constraints included physical space available, roof ages, excessive shading, and constructability issues. Each subsection in Section 3 below describes each site in detail.

### 2.2 Conceptual Design and Energy Modeling

Array layouts at each site were designed using Helioscope, an industry-standard design and energy modeling software package with 3-dimensional modeling capabilities incorporating site-specific characteristics of buildings, ground areas, parking lots, shade producing obstructions, as well as other array locations and their impacts upon system layout and production. McKinstry further applies our knowledge of Codes and regulations, industry best practices, and professional judgment to ensure that designs are Code-compliant, and strike a balance across customer preferences, production, constructability, and installed-cost concerns.

Helioscope also provides robust PV system output modeling capabilities, which we utilize in conjunction with Typical Meteorological Year (TMY) weather datasets, real-world equipment specifications, dust and snow soiling coverage models developed by independent engineers, and professional judgment for critical assumptions and modeling setup.

### 2.3 Bill Savings Analysis

Our bill savings analyses are based upon output from Energy Toolbase, an industry-standard modeling software package. Energy Toolbase estimates bill savings based upon each site's load characteristics, PV system production (imported from Helioscope or other sources), applicable utility tariffs, and net metering policies. With respect to tariff selection, we evaluate savings under various eligible tariff options to find the best possible savings.

## 2. Analysis Methodology

### 2.4 Cost Estimation

Cost estimates for each portfolio are produced using a comprehensive cost model that incorporates estimates for all costs required to bring each portfolio through final development, design, and construction. Detailed costs estimates are developed for cost categories summarized in the following table.

| Project Phase | Cost Category                         | Cost Details  |
|---------------|---------------------------------------|---|
| Development   | Development Personnel                 | Development Engineering and Analysis<br>Program Management  |
|               | Engineering and Professional Services | Electrical Engineering<br>Civil and Geotechnical Engineering<br>Structural Engineering<br>Surveying<br>Utility Fees |
| Construction  | Capital Equipment                     | Modules<br>Inverters<br>Mounting Systems<br>Data Acquisition Systems<br>Shipping Costs                              |
|               | Subcontractors (Labor & Materials)    | Electrical Subcontractors<br>Mounting System Subcontractors<br>Civil Subcontractors                                 |
|               | Project Management                    | Construction Management<br>Project Engineering<br>Site Supervision<br>Travel  |
|               | Other Construction Costs              | General Conditions<br>Permits and Inspections<br>Bonds  |
| All Phases    | Administrative                        | Contingency<br>Overhead<br>Profit   |

Cost estimates are informed by a mix of high-level project-specific quotes for equipment and subcontracting, quotes from recent similar projects, and McKinstry internal estimates and experience. Cost assumptions at this stage of analysis are estimated to be +/-20% for each overall portfolio. Total portfolio costs assume that all sites/systems in each portfolio are implemented. Costs may change slightly and would not simply sum should individual projects be removed from each portfolio, as certain fixed costs are redistributed, and scale-driven cost factors will change.

### 2.5 Financial Modeling

Finally, lifecycle system value is modeled using a 25-year pro forma cash flow. In addition to installed cost and annual bill savings, lifecycle values are impacted by several key assumptions including annual PV system performance degradation, annual utility rate escalation, utility incentives, annual O&M costs, annual cost



## 2. Analysis Methodology

escalation, and assumed inverter replacement costs and timing. Details of the financial modeling are included in Section 6.


System decommissioning estimates are included as separate costs in Section 3 and were based off input from subcontractors.

Note that all financial results reflect the outcome of a 25-year cash flow analysis that also incorporates the assumptions outlined in Section 6. The 25-year Lifetime Savings are undiscounted, so do not include a discount rate on future cash flows.

### 2.6 Construction Service Market Conditions

#### CONSTRUCTION PRICING TRENDS

Overall construction pricing has risen sharply over the last few years due to supply chain complications caused by the COVID-19 pandemic, but we are seeing increases tapering off. The Producer Price Index (PPI) for nonresidential construction shown in the chart below represents the average change over time in selling prices received by domestic producers of construction services.



Starting in 2020, the PPI has significantly jumped year to year, well above pre-COVID-19 year-on-year increases. We further anecdotally note similar increases in our observed contractor pricing over the past years on active construction projects we have put out to competitive bid. While the 2022-2023 increase has fallen more in line with pre-COVID-19 increases, it is difficult to predict future cost increases.

#### IMPACTS TO PORTFOLIO ESTIMATES

We recognize PSD is seeking to install PV and storage systems beginning in 2025. Given the volatility and general construction market price inflation we have observed recently, we emphasize that the pricing provided is indicative of market conditions at the time of this report. Further, we present estimated portfolio price sensitivities to module and contractor construction costs to help gauge their relative potential impact given the high degree of recent volatility.

## 2. Analysis Methodology

---

### 2.7 Inflation Reduction Act (IRA) Impacts

With the passing of the IRA in 2022, development and deployment of clean energy projects in the public sector can be incentivized through an Investment Tax Credit (ITC). The base credit is 30% of cost, with additional adders for:

- Domestic Content – 10% adder
  - All steel and 40% of manufactured products must originate from the US.
  - The cost of US manufactured equipment is significantly higher than that out of country manufactured equipment. We expect these increases to be well over the value of the additional incentive and have not included this adder in our cost and financial models.
- Energy Communities (one or more of the following) – 10% adder
  - Brownfield Category
    - Defined as the real property, the expansion, redevelopment, or reuse of which may be complicated by the presence or potential presence of a hazardous substance, pollutant, or contaminant.
    - We have not identified any of the buildings as Brownfield sites.
  - Statistical Area Category
    - Includes a metropolitan statistical area (MSA) or non-metropolitan statistical area (“non-MSA”) that (i) has 0.17% or greater direct employment (the “Fossil Fuel Employment Requirement”) or 25% or greater local tax revenues related to the extraction, processing, transport or storage of coal, oil or natural gas (the “Fossil Fuel Tax Revenue Requirement”), and (ii) has an unemployment rate at or above the national average unemployment rate for the previous year (the “Unemployment Rate Requirement”). Treasury and the IRS intend to issue, annually each May, listings that identify the MSAs and non-MSAs that qualify in the Statistical Area Category based on the Unemployment Rate Requirement.
    - We did not find that any of these sites would qualify for this adder.
  - Additional Resources Relevant to Identifying Energy Communities
    - The IRS released appendices identifying counties that constitute an MSA or non-MSA, (ii) identifying MSAs and non-MSAs that meet the Fossil Fuel Employment Requirement, and (iii) identifying census tracts and directly adjoining tracts that have ever had a Closed Coal Mine or a Retired Coal-Fired Electric Generating Unit.
    - We did not find that any of these sites would qualify for this adder.
- Low Income or Tribal– 10% adder
  - Poverty rate must be 20% or greater, or site located in/ owned by a Tribe.
    - We did not find that any sites qualify for this adder.

## 2. Analysis Methodology

---

### 2.8 Pricing Assumptions, Inclusions, and Exclusions

All cost and savings were based off the following:

- Codes and Utility Standards:
  - NEC 2020
  - IBC 2021
  - IFC 2021
- City of Fort Collins Light & Power Interconnection Standards for Distributed Energy Resources
- Tax-exempt
- 10% mechanical attachment count for the rooftop
- No structural upgrades required of the roofs
- Sites where the remaining roof life is not compatible with the PV system lifespan have been dropped from the study (see “Physically Not Feasible Portfolio” in section 3.1)
- Scope from AC combiner to interconnection is included in the electrical scope and pricing
- Pricing assumes a portfolio approach
- Pricing includes payment & performance bond
- Terms & Conditions listed in the City of Fort Collins Light & Power Interconnection Agreement and REC Contract
- Current labor rates
- Modeling:
  - TMY, GREELEY/WELD (AWOS), NSRDB (tmy3, II) weather data file
  - 1.5% production gain for ground mounts with bifacial modules
  - Soiling data from DNV Solar Resource Compass
- Design Loads
  - Category III: 1.15 importance factor
  - Ground snow load: 35 psf
  - Wind speed: 114 mph
- No interconnection upgrade costs
- Project payback is, in part, contingent on renewable energy credits (RECs), incentives from Xcel Energy. McKinstry would make best efforts to capture solar incentives from the utility on the PSD’s behalf. In the event the incentives are not available the payback is subject to increase for the applicable sites.
- No grounding transformers
- Major equipment warranties:
  - Modules – 12 years
  - Inverters – 10 years
  - DAS – 5 years
  - AC Combiners – 5 years
  - LEDs (carport canopies only) – 5 years
- No extended warranties
- No ongoing DAS Costs
- Any ongoing fees beyond year 5 are excluded (both Cell Service and Data Subscription Monitoring fees).
- No reroofing or roofing repairs
- No backup generation
- 4’ perimeter setback for rooftops
- Favorable soil conditions. No hard drilling or special footers/foundations required.
- No hazardous soils or materials (asbestos, PFAS, etc.). Should monitoring, mitigation, abatement, and/or disposal be required, Louisville would be responsible for this additional scope.
- City of Fort Collins Utility Solar REC Incentives:
  - Onetime payment of \$0.50/ watt of generating capacity up to \$50,000
  - Maximum of 2 PV projects can be incentivized per calendar year

Section

3



## Portfolio Details

# 3. Portfolio Details

---

## 3.1 Portfolios

This section provides consolidated portfolio-level performance and financial results, as well as detailed descriptions of each site within the portfolios, including site and system descriptions, modeled system outputs, site usage offsets, costs/ savings, and financial performance. Also included are a breakdown of sites that are technically, but not economically feasible, and a breakdown of sites that are not feasible with associated reasoning.

### FINANCIALLY FEASIBLE PV PORTFOLIO

The Financially Feasible Portfolio consists of 6 sites. The portfolio is a combined 1.95 MWdc and will reduce consumption across the sites by 90.4%. System details and direct ownership models are provided below.

### FINANCIALLY NOT FEASIBLE PV PORTFOLIO

This portfolio includes the 14 sites which are provided electricity by Fort Collins Utility, and where paybacks were found to be greater than the expected life of the PV systems. System details, direct ownership models, and additional funding figures to make these projects economically feasible are provided below.

### PV SYSTEM TYPE DETERMINATION

The table below shows all the sites in the scope of the study with reasoning for the proposed PV system type, or lack thereof.

McKinstry, along with PSD’s guidance, reviewed all the available land area for PV ground mount systems. Sites where there was not enough land for an economically feasible system were dropped from the study.

Carport feasibility was based off available double-row parking, and a total system capacity of 200kWdc. Single-row parking and systems smaller than 200kWdc would not be economically feasible.

Roof ages along with feasible PV system layouts were the determining factors for going forward with roof-based systems. All sites below would need a roof replacement within the lifespan of the PV system, the cost of a deinstall-reinstall of the system would not lead to an economically feasible project. On a positive note, there are several roofs where PV system layouts would be technically feasible. When these roofs are replaced, they would be great candidates for rooftop PV systems.

For the roof systems where roof life aligns with PV system life, structural capacity assessments were performed to ensure feasibility. It was found that the North Transportation Center lacks sufficient structural capacity to support the added weight of a PV system.

On sites where multiple PV system types were technically feasible, system economics determined the recommended modality for the site. Roof top systems are typically the most economical, therefore roof mount systems were the first choice, followed by ground mount, and finally carports, which are typically the most expensive to implement.



# 3. Portfolio Details

## Site Feasibility Breakdown

\*Rooftop PV array too small, heavily shaded, roof layout not feasible

\*\*F = Feasible; NF = Not Feasible, TFNFF = Technically Feasible Not Financially Feasible

| Site                                 | Ground Mount PV Not Feasible | Carport PV Not Feasible | Roof PV Not Feasible - Roof Age Not In Alignment With PV System Life | Roof PV Not Feasible - PV System Layout Is Not Economically Feasible* | Roof PV Not Feasible - Structural Capacity of Roof Does Not Support PV | PV Feasibility** | System Selection Narrative  |
|--------------------------------------|------------------------------|-------------------------|--|---|--|------------------|---|
| Assessment & Research Offices BLDG C | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and would not be conducive to an economic project.   |
| Bacon ES                             | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Bamford ES                           | x                            | x                       |  |   |  | F                | With guidance from PSD, a roof top PV system was proposed for this site due to its new roof.  |
| Bauder ES                            | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Beattie ES                           |                              | x                       | x  |   |  | TFNFF            | With the remaining roof life just outside of the PV system life and a small carport area, a ground mount option was selected along with PSD input.                          |
| Bennett ES                           | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Bethke ES                            |                              | x                       | x  |   |  | F                | While the roof age is out of alignment with a rooftop PV system, a ground mount system is appropriate for this site. The array location was decided on with input from PSD. |
| Blevins MS                           | x                            |                         | x  |   |  | TFNFF            | Since there the roof is too old, and there not land available for a ground mount, a carport PV system has been proposed at this site.                                       |
| Boltz MS                             | x                            |                         | x  |   |  | TFNFF            | Since there the roof is too old, and there not land available for a ground mount, a carport PV system has been proposed at this site.                                       |
| Cache La Poudre ES                   | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Centennial HS                        | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and would not be conducive to an economic project.   |
| Customer Support Center - OPS        | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and would not be conducive to an economic project.   |
| Dunn ES                              | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study.  |

### 3. Portfolio Details

| Site                              | Ground Mount PV Not Feasible | Carport PV Not Feasible | Roof PV Not Feasible - Roof Age Not In Alignment With PV System Life | Roof PV Not Feasible - PV System Layout Is Not Economically Feasible* | Roof PV Not Feasible - Structural Capacity of Roof Does Not Support PV | PV Feasibility** | System Selection Narrative  |
|-----------------------------------|------------------------------|-------------------------|--|---|--|------------------|---|
|                                   |                              |                         |  |   |  |                  | When the roof is replaced, this site should be considered for rooftop PV.   |
| Eyestone ES North                 | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Eyestone ES South                 |                              | x                       | x  |   |  | F                | With no roof replacement planned, a ground mount system is the best option at this time. if the roof were to be replaced, it is likely that a rooftop system would be more economical than the proposed ground mount system.        |
| Fort Collins HS                   | x                            |                         | x  |   |  | TFNFF            | Since there the roof is too old, and there is not land available for a ground mount, a carport PV system has been proposed at this site.  |
| Fossil Ridge HS                   |                              |                         | x  |   |  | TFNFF            | Since there the roof is too old, and there is available land area, a ground mount PV system has been proposed at this site. The array location was decided on with input from PSD.  |
| Fullana Learning Center-Headstart | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Grounds Office BLDG I             | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Harris Bilingual ES               | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and heavily shaded, which would not be conducive to an economic project.                                     |
| Irish ES                          | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| ITC                               | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Johannsen Support Services Center | x                            |                         | x  | x   |  | TFNFF            | With the roof being so small, and no available land area, a carport PV system was proposed for this site.   |
| Johnson ES                        | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |
| Kinard Core Knowledge MS          | x                            |                         | x  |   |  | TFNFF            | With the roof being too old, and no available land area, a carport PV system was proposed for this site.  |

### 3. Portfolio Details

| Site   | Ground Mount PV Not Feasible | Carport PV Not Feasible | Roof PV Not Feasible - Roof Age Not In Alignment With PV System Life | Roof PV Not Feasible - PV System Layout Is Not Economically Feasible* | Roof PV Not Feasible - Structural Capacity of Roof Does Not Support PV | PV Feasibility** | System Selection Narrative  |
|--|------------------------------|-------------------------|--|---|--|------------------|---|
| Kruse ES                                     | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |
| Laurel School of Arts & Tech ES              | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |
| Leshner, IB World School                     | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Lincoln, IB World School                     | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Linton ES                                    | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |
| Livermore ES                                 | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Lopez ES                                     | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| McGraw, IB World School ES                   | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |
| North Transportation Center                  | x                            | x                       |  |   | x  | NF               | The roof capacity assessment shows that there is not enough structural loading capacity to support the additional weight of a PV system.  |
| O'Dea Core Knowledge ES                      | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.  |
| Olander School for Project Based Learning ES | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area heavily shaded by dormers, severely hampering PV system capacity which would not be conducive to an economic project. |

### 3. Portfolio Details

| Site                                | Ground Mount PV Not Feasible | Carport PV Not Feasible | Roof PV Not Feasible - Roof Age Not In Alignment With PV System Life | Roof PV Not Feasible - PV System Layout Is Not Economically Feasible* | Roof PV Not Feasible - Structural Capacity of Roof Does Not Support PV | PV Feasibility** | System Selection Narrative  |
|-------------------------------------|------------------------------|-------------------------|--|---|--|------------------|---|
| Old warehouse BLDG E                | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Partnership & Volunteer Center      | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and heavily shaded, which would not be conducive to an economic project. |
| Polaris Expeditionary Learning K-12 | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Preston MS                          |                              | x                       | x  | x   |  | TFNFF            | Due to an old, complicated roof layout, and a small parking area, a ground mount system was proposed for this site.   |
| Poudre Community Academy            | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and heavily shaded, which would not be conducive to an economic project. |
| Poudre HS                           | x                            |                         | x  |   |  | TFNFF            | With an old roof and no ground mount area, a carport PV system was proposed at this site.   |
| Poudre High School Laundry Building | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small which would not be conducive to an economic project.                     |
| PSD Global Academy Charter School   | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Putnam ES                           | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Records Warehouse BLDG G            | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Red Feather ES                      | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small and heavily shaded, which would not be conducive to an economic project. |
| Rice ES                             |                              | x                       | x  |   |  | F                | With the remaining roof life just outside of the PV system life, a ground mount option was selected along with PSD input.   |
| Riffenburgh, IB World School ES     | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.                          |
| Rocky Mountain HS                   | x                            |                         | x  |   |  | TFNFF            | With an old roof and no ground mount area, a carport PV system was proposed at this site.   |

### 3. Portfolio Details

| Site               | Ground Mount PV Not Feasible | Carport PV Not Feasible | Roof PV Not Feasible - Roof Age Not In Alignment With PV System Life | Roof PV Not Feasible - PV System Layout Is Not Economically Feasible* | Roof PV Not Feasible - Structural Capacity of Roof Does Not Support PV | PV Feasibility** | System Selection Narrative  |
|--------------------|------------------------------|-------------------------|--|---|--|------------------|---|
| Shepardson STEM ES | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| South Bus Terminal | x                            | x                       |  |   |  | TFNFF            | With no ground mount area, and a small parking area, the bus parking structure would provide a flush mount PV system.   |
| Stove Prairie ES   | x                            | x                       | x  | x   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. The rooftop area is small which would not be conducive to an economic project. |
| Tavelli ES         | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Tinmath ES         | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Tinmath MS/HS      |                              |                         |  |   |  | F                | Since this is a new building and roof, a rooftop system was proposed in lieu of a ground mount or carport system.   |
| Traut              | x                            |                         | x  |   |  | TFNFF            | Since there the roof is too old, and there is not land available for a ground mount, a carport PV system has been proposed at this site.                                    |
| Warehouse 5        | x                            | x                       |  |   |  | TFNFF            | With no available land, and small parking areas, a flush mount roof system has been proposed at this site.  |
| Webber MS          | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |
| Wellington MS/HS   |                              |                         |  |   |  | F                | Since this is a new building and roof, a rooftop system was proposed in lieu of a ground mount or carport system.   |
| Werner ES          |                              | x                       | x  | x   |  | TFNFF            | Since the roof is old and heavily shaded, and carport areas are small, a ground mount system has been proposed for this site.   |
| Zach ES            | x                            | x                       | x  |   |  | NF               | Since there is no current opportunity for a PV system, this site was dropped from the study. When the roof is replaced, this site should be considered for rooftop PV.      |



# 3. Portfolio Details

## 3.2 Financially Feasible Portfolio Details

The sections below give details for the Financially Feasible PV Portfolio along with any BESS systems, which are priced out separately from the PV systems. The direct ownership models included in this section assume the following:


- 25-year cashflow model
- 3% utility escalator
- Inverter replacement at year 15
- 0.6% annual module degradation
- 3% inflation rate
- 30% IRA contribution

### 3.2.1 Bamford Elementary School

#### SITE DESCRIPTION

This ballasted flat roof system was designed as an array on multiple sections of the roof where an economic system layout and azimuth were taken into consideration.

**Bamford Elementary School**



### 3. Portfolio Details

#### PV SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Bamford Elementary              | Roof System                  |
|---------------------------------|------------------------------|
| Utility and Current Rate        | Loveland Water and Power; LG |
| Annual Usage                    | 408,960                      |
| System Size (kWDC/kWAC)         | 202.0/ 172.0                 |
| Production, Year 1 (kWh-AC)     | 302,000                      |
| Solar Offset, Year 1            | 73.8%                        |
| GHG Reduction, Year 1 (MT CO2e) | 124.8                        |

#### PV FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA/ Funding details.

| Bamford Elementary – PV Direct Ownership     |           |
|--|-----------|
| Total Project Cost*                          | \$670,000 |
| Total Project Cost with 30% IRA Contribution | \$469,000 |
| Bill Savings, Year 1                         | \$23,300  |
| REC/ Incentive, Year 1                       | N/A       |
| Payback (years)                              | 17.6      |
| 25-year Total Lifetime Savings               | \$799,980 |
| End of Life Decommissioning Cost             | \$35,300  |

\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR PV EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY |   | Equipment Description                              |             |
|-------------------------|-----|---|--|-------------|
| PV Modules              | 374 |   | JA Solar 540-Watt Bifacial Module                  |             |
| Inverter                | 2   | 2 | CPS 50kW-AC  | CPS 36kW-AC |
| Data Acquisition System | 1   |   | AlsoEnergy Data Acquisition System                 |             |
| Module Shutdown Unit    | 216 |   | Tigo TS4-A-2F – Tigo PV Module Rapid Shutdown Unit |             |

### 3. Portfolio Details

#### BESS DETAILS

The BESS system at Bamford is intended to be implemented along with the PV system. This system would be charged from the solar PV and generate savings by lowering the building’s electrical demand.

| Bamford Elementary | BESS System       |
|--------------------|-------------------|
| BESS Use Case      | Demand Management |
| Manufacturer       | SYL/ STEM         |
| System Size (kWAC) | 125               |
| System Size (kWh)  | 250               |

#### BESS FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. This system would be a capital improvement measure as the system payback far exceeds the expected system life of 10 years.

| Bamford Elementary – BESS Direct Ownership    |           |
|---|-----------|
| Total Project Cost                            | \$516,200 |
| Total Project Cost with 30% IRA Contribution  | \$361,300 |
| Bill Savings, Year 1                          | \$8,500   |
| Payback (years)                               | 42.6      |
| 10-year Total Lifetime Savings                | \$85,000  |
| Additional Funding Needed for 10 Year Payback | \$267,600 |



# 3. Portfolio Details

## 3.2.2 Bethke Elementary School

### SITE DESCRIPTION

The recommended ground mount system at Bethke Elementary totals 137.7 kWDC.

The ground mount system is comprised of 4 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 3 small trees.

Bethke Elementary





### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Bethke Elementary               | Ground Mount System |
|---------------------------------|---------------------|
| Utility and Current Rate        | Xcel; SG            |
| Annual Usage                    | 287,200             |
| System Size (kWDC/kWAC)         | 137.7/100.0         |
| Production, Year 1 (kWh-AC)     | 220,900             |
| Solar Offset, Year 1            | 76.9%               |
| GHG Reduction, Year 1 (MT CO2e) | 91.3                |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA/ Funding details.

| Bethke Elementary                            |           |
|--|-----------|
| Total Project Cost**                         | \$568,400 |
| Total Project Cost with 30% IRA Contribution | \$397,900 |
| Bill Savings, Year 1                         | \$13,800  |
| REC/ Incentive, Year 1*                      | \$8,600   |
| Payback (years)                              | 14.0      |
| 25-year Total Lifetime Savings               | \$670,400 |
| End of Life Decommissioning Cost             | \$28,200  |

\*Xcel Energy Solar Rewards Commercial/Industrial pay credits at \$0.04/kWh of PV generation for systems smaller than 250kW, for a period of 20 years.

\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 255 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 50kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |

#### INTERCONNECTION

The SLD below illustrates the way the proposed PV system would be interconnected to the site’s electrical infrastructure. Bethke’s proposed PV system would be interconnected via a line side tap on the Main Distribution Center. See Appendix B for full SLD mark-ups.

# 3. Portfolio Details

## Bethke Elementary PV System Proposed Interconnection Method



# 3. Portfolio Details

## 3.2.3 Eystone South Elementary School

### SITE DESCRIPTION

The recommended ground mount system at Eystone South totals 110.2 kWDC.

The ground mount system is comprised of 2 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 2 trees and shrubbery on the north side of the array. The concrete circle on the south-west corner of the array has been removed.

Eystone Elementary South





### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Eyestone South                  | Ground Mount System |
|---------------------------------|---------------------|
| Utility and Current Rate        | Xcel; SG            |
| Annual Usage                    | 187,700             |
| System Size (kWDC/kWAC)         | 110.2/100.0         |
| Production, Year 1 (kWh-AC)     | 189,400             |
| Solar Offset, Year 1            | 100%                |
| GHG Reduction, Year 1 (MT CO2e) | 78.2                |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA / Funding details.

| Eyestone South – Direct Ownership            |           |
|--|-----------|
| Total Project Cost**                         | \$487,900 |
| Total Project Cost with 30% IRA Contribution | \$341,500 |
| Bill Savings, Year 1                         | \$12,400  |
| REC/ Incentive, Year 1*                      | \$7,400   |
| Payback (years)                              | 11.9      |
| 25-year Total Lifetime Savings               | \$681,700 |
| End of Life Decommissioning Cost             | \$22,600  |

\*Xcel Energy Solar Rewards Commercial/Industrial pay credits at \$0.04/kWh of PV generation for systems smaller than 250kW, for a period of 20 years.

\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 204 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 50kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |



# 3. Portfolio Details

## 3.2.4 Rice Elementary School

### SITE DESCRIPTION

The recommended ground mount system at Rice Elementary totals 142.6 kWDC.

The ground mount system is comprised of 5 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 3 trees.

Rice Elementary School



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Rice Elementary                 | Roof System |
|---------------------------------|-------------|
| Utility and Current Rate        | Xcel; SG    |
| Annual Usage                    | 313,000     |
| System Size (kWDC/kWAC)         | 142.6/120.0 |
| Production, Year 1 (kWh-AC)     | 241,700     |
| Solar Offset, Year 1            | 77.2%       |
| GHG Reduction, Year 1 (MT CO2e) | 99.8        |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA/ Funding details.

| Rice Elementary – Direct Ownership           |             |
|--|-------------|
| Total Project Cost***                        | \$580,800   |
| Total Project Cost with 30% IRA Contribution | \$406,600   |
| Bill Savings, Year 1*                        | \$23,800    |
| REC/ Incentive, Year 1**                     | \$9,500     |
| Payback (years)                              | 9.1         |
| 25-year Total Lifetime Savings               | \$1,142,400 |
| End of Life Decommissioning Cost             | \$29,200    |

\*Savings assume a rate switch to SPVTOU.

\*\*Xcel Energy Solar Rewards Commercial/Industrial pay credits at \$0.04/kWh of PV generation for systems smaller than 250kW, for a period of 20 years.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 264 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 60kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |

# 3. Portfolio Details

## INTERCONNECTION

The proposed PV system at Rice Elementary can be interconnected by a 200 amp back feed breaker in one of the spare breaker locations on the Main Distribution Center (MDC). The existing 600-amp main fuses would need to be replaced with 500-amp fuses. See appendix B for full SLD mark-ups.

### Rice ES PV System Proposed Interconnection Method





## 3. Portfolio Details


### 3.2.5 Timnath Middle / High School

#### SITE DESCRIPTION

This ballasted flat roof system was designed as an array on multiple sections of the roof where an economic system layout was taken into consideration. Since the school is so new, there is not imagery of it in Helioscope's satellite view. This design is based off Wellington Middle/ High School, a sister building to Timnath. PSD has confirmed the design differences in these buildings are negligible.

Since the school is new, we do not have a full year of representative utility data. As of now the school does not qualify for a rate switch from SG to SPVTOU due to a single month having a load factor below 20%. Based on the data that is available, we see the likelihood that this school would qualify for the rate switch. The SPVTOU rate adds a significant amount of savings and would greatly improve project economics. The financial details below illustrate the economics of both rate structures.

Timnath Middle/ High School



### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Timnath Middle / High School           | Roof System  |
|--|--------------|
| Utility and Current Rate               | Xcel; SG     |
| Annual Usage                           | 1,013,200*   |
| System Size (kWDC/kWAC)                | 679.3/ 540.0 |
| Production, Year 1 (kWh-AC)            | 1,003,200    |
| Solar Offset, Year 1                   | 99.0%        |
| <b>GHG Reduction, Year 1 (MT CO2e)</b> | <b>414.3</b> |

\*Since the school opened in August 2023, there is not a full year’s worth of representative utility data. Usage and associated savings are based on monthly bills from 5/22-5/23.

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA/ Funding details.

| Timnath Middle / High School – Direct Ownership | SG Rate     | SPVTOU Rate     |
|---|-------------|-----------------|
| Total Project Cost**                            | \$1,857,600 | Same as SG Rate |
| Total Project Cost with 30% IRA Contribution    | \$1,300,300 | Same as SG Rate |
| Bill Savings, Year 1                            | \$61,500    | \$104,260       |
| REC/ Incentive, Year 1*                         | \$36,800    | Same as SG Rate |
| Payback (years)                                 | 9.5         | 7.1             |
| 25-year Total Lifetime Savings                  | \$3,292,200 | \$4,809,100     |
| End of Life Decommissioning Cost                | \$118,900   | Same as SG Rate |

\*Xcel Energy Solar Rewards Commercial/Industrial pay credits at \$0.0375/kWh of PV generation for systems larger than 250kW, and small than 500kW, for a period of 20 years.

\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| Equipment Type          | QTY   | Equipment Description                              |
|-------------------------|-------|--|
| PV Modules              | 1,258 | JA Solar 540-Watt Bifacial Module                  |
| Inverter                | 9     | CPS 60kW-AC  |
| Data Acquisition System | 1     | AlsoEnergy Data Acquisition System                 |
| Module Shutdown Unit    | 666   | Tigo TS4-A-2F – Tigo PV Module Rapid Shutdown Unit |

# 3. Portfolio Details

## INTERCONNECTION

The proposed PV system could be interconnected by either a supply side tap or a load side breaker. An electrical field investigation would determine if there is space for a supply side tap, if not a load side breaker could be implemented if PSD were onboard with lowering the main breaker setting from 2000 amps to 1500 amps. See Appendix B for full SLD mark-ups.

**Timnath MS/HS PV System Proposed Interconnection Method**





# 3. Portfolio Details

## 3.2.6 Wellington Middle / High School

### SITE DESCRIPTION

This ballasted flat roof system was designed as an array on multiple sections of the roof where an economic system layout was taken into consideration.

Wellington Middle/ High School



### PV SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Wellington Middle / High School        | Roof System  |
|--|--------------|
| Utility and Current Rate               | PVREA; LP    |
| Annual Usage                           | 1,013,200*   |
| System Size (kWDC/kWAC)                | 679.3/ 540.0 |
| Production, Year 1 (kWh-AC)            | 1,003,200    |
| Solar Offset, Year 1                   | 94.3%        |
| <b>GHG Reduction, Year 1 (MT CO2e)</b> | <b>414.3</b> |

### 3. Portfolio Details

*\*Since the school opened in August 2023, there is not a full year’s worth of representative utility data. Usage and associated savings are based on 15-minute interval data from 5/22-5/23.*

#### PV FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. See Section 6 for PPA/ Funding details.

| Wellington Middle / High School – Direct Ownership         |             |
|--|-------------|
| Total Project Cost**                                       | \$1,867,100 |
| Total Project Cost with 30% IRA Contribution               | \$1,307,000 |
| Bill Savings, Year 1                                       | \$69,800    |
| REC/ Incentive, Onetime Payment*                           | N/A         |
| Simple Payback (years)                                     | 16.2        |
| Additional Funding Needed to Reach 20 Year Simple Payback* | \$271,100   |
| 25-year Total Lifetime Savings                             | \$2,637,800 |
| End of Life Decommissioning Cost                           | \$118,900   |

*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.*

*\*\*Financial summary above assumes projects are contracted as a portfolio.*

#### MAJOR PV EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY   | Equipment Description                              |
|-------------------------|-------|--|
| PV Modules              | 1,258 | JA Solar 540-Watt Bifacial Module                  |
| Inverter                | 9     | CPS 60kW-AC  |
| Data Acquisition System | 1     | AlsoEnergy Data Acquisition System                 |
| Module Shutdown Unit    | 666   | Tigo TS4-A-2F – Tigo PV Module Rapid Shutdown Unit |

### 3. Portfolio Details

#### BESS DETAILS

The BESS system at Bamford is intended to be implemented along with the PV system. This system would be charged from PV and generate savings by lowering the demand from the utility.

| Wellington Middle / High School | BESS System       |
|---------------------------------|-------------------|
| BESS Use Case                   | Demand Management |
| Manufacturer                    | SYL/ STEM         |
| System Size (kWAC)              | 250               |
| System Size (kWh)               | 500               |

#### BESS FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. This system would be a capital improvement measure as the system payback far exceeds the expected system life of 10 years.


| Wellington Middle / High School– BESS Direct Ownership |           |
|--|-----------|
| Total Project Cost                                     | \$753,600 |
| Total Project Cost with 30% IRA Contribution           | \$527,500 |
| Bill Savings, Year 1                                   | \$25,700  |
| Payback (years)  | 20.6      |
| 10-year Total Lifetime Savings                         | \$257,000 |
| Additional Funding Needed for 10 Year Payback          | \$270,900 |

# 3. Portfolio Details

## PV AND BESS INTERCONNECTION

An electrical field investigation would be required to ensure there is room for a supply side tap interconnection. See Appendix B for full SLD mark-ups.

### Wellington MS/HS PV System Proposed Interconnection Method



# 3. Portfolio Details

## 3.3 Financially Not Feasible Portfolio Details

The sections below give details for the Financially Not Feasible PV Portfolio along with any BESS systems, which are priced out separately from the PV system.

### 3.3.1 Beattie Elementary

#### SITE DESCRIPTION

The recommended ground mount system at Beattie Elementary totals 202.0 kWDC.

The ground mount system is comprised of 5 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 7 trees.

Beattie Elementary School





### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Beattie Elementary              | Ground Mount System        |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 336,200                    |
| System Size (kWDC/kWAC)         | 202.0/150.0                |
| Production, Year 1 (kWh-AC)     | 327,300                    |
| Solar Offset, Year 1            | 97.4%                      |
| GHG Reduction, Year 1 (MT CO2e) | 135.2                      |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Beattie Elementary – Direct Ownership                       |           |
|---|-----------|
| Total Project Cost***                                       | \$816,500 |
| Total Project Cost with 30% IRA Contribution                | \$571,500 |
| Bill Savings, Year 1  | \$17,250  |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 30.2      |
| Simple Payback without FCU Incentive (years)                | 33.1      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$226,500 |
| 25-year Total Lifetime Savings                              | \$799,980 |
| End of Life Decommissioning Cost                            | \$41,400  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


# 3. Portfolio Details

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 374 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 3   | CPS 50kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |

## INTERCONNECTION

The SLD below illustrates the way the proposed PV system would be interconnected to the site’s electrical infostructure. Ideally Beattie’s proposed PV system would be interconnected via a line side tap on the Main Distribution Board (MDB). An electrical field investigation would be required to access the available space for a line side tap. If there is not room for a line side tap, a 600-amp breaker could be placed on the utility side of the main breaker, or a 600-amp breaker could be placed on the far end of the MDB with the existing 1000 amp main fuses being replaced with 800 amp fuses. See Appendix B for full SLD mark-ups.

### Bettie Elementary PV System Proposed Interconnection Method



## 3. Portfolio Details

### 3.3.2 Blevins Middle School

#### SITE DESCRIPTION

The PV carport system at Blevins Middle totals 248.4kW-DC.

The carport system utilizes 3 standalone canopies with 5 rows of modules in portrait at a 5° tilt, utilizing parking lots for utility consumption offset while providing shaded parking.

**Blevins Middle**





### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Blevins Middle                  | Carport System             |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 389,900                    |
| System Size (kWDC/kWAC)         | 248.4/192.0                |
| Production, Year 1 (kWh-AC)     | 363,100                    |
| Solar Offset, Year 1            | 93.1%                      |
| GHG Reduction, Year 1 (MT CO2e) | 149.9                      |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Blevins Elementary – Direct Ownership                       |             |
|---|-------------|
| Total Project Cost***                                       | \$1,348,100 |
| Total Project Cost with 30% IRA Contribution                | \$943,700   |
| Bill Savings, Year 1  | \$20,500    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 43.4        |
| Simple Payback without FCU Incentive (years)                | 45.8        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$531,800   |
| 25-year Total Lifetime Savings                              | \$708,100   |
| End of Life Decommissioning Cost                            | \$64,600    |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


# 3. Portfolio Details

| Equipment Type          | QTY |   | Equipment Description              |             |
|-------------------------|-----|---|------------------------------------|-------------|
| PV Modules              | 460 |   | JA Solar 540-Watt Bifacial Module  |             |
| Inverter                | 2   | 2 | CPS 60kW-AC                        | CPS 36kW-AC |
| Data Acquisition System | 1   |   | AlsoEnergy Data Acquisition System |             |

## INTERCONNECTION

The SLD below illustrates the way the proposed PV system would be interconnected to the site’s electrical infostructure. Blevins’ proposed PV system would be interconnected via a line side tap on the Main Distribution Panel (MDP). An electrical field investigation would be needed to confirm there is adequate space in the MDP to achieve this interconnection method. See Appendix B for full SLD mark-ups.

**Blevins Middle PV System Proposed Interconnection Method**



# 3. Portfolio Details

## 3.3.3 Boltz Middle School

### SITE DESCRIPTION

The PV carport system at Boltz Middle totals 197.1kW-DC.

The carport system utilizes 1 standalone canopy with 5 rows of modules in portrait at a 5° tilt, utilizing parking lots for utility consumption offset while providing shaded parking.

**Boltz Middle**



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| <b>Boltz Middle</b>             | <b>Carport System</b>      |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 524,700                    |
| System Size (kWDC/kWAC)         | 197.1/150.0                |
| Production, Year 1 (kWh-AC)     | 295,400                    |
| Solar Offset, Year 1            | 56.3%                      |
| GHG Reduction, Year 1 (MT CO2e) | 121.9                      |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| <b>Boltz Elementary – Direct Ownership</b>                  |             |
|---|-------------|
| Total Project Cost***                                       | \$1,111,300 |
| Total Project Cost with 30% IRA Contribution                | \$778,900   |
| Bill Savings, Year 1  | \$17,200    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 42.4        |
| Simple Payback without FCU Incentive (years)                | 45.3        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$434,900   |
| 25-year Total Lifetime Savings                              | \$578,600   |
| End of Life Decommissioning Cost                            | \$51,200    |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| <b>Equipment Type</b>   | <b>QTY</b> | <b>Equipment Description</b>       |
|-------------------------|------------|------------------------------------|
| PV Modules              | 365        | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 3          | CPS 50kW-AC                        |
| Data Acquisition System | 1          | AlsoEnergy Data Acquisition System |

# 3. Portfolio Details

## INTERCONNECTION

Boltz's proposed PV system final interconnection method would need to be determined by an electrical field investigation and working with the Main Distribution Panel manufacturer to access if a 250-amp breaker could be procured and placed in one of the two spare breaker locations for a load side tap. A supply side tap could also be utilized if needed.

### Boltz Elementary PV System Proposed Interconnection Method



# 3. Portfolio Details

## 3.3.4 Cache la Poudre Middle School

### BESS AND DIRECT OWNERSHIP DETAILS


The BESS system at Cache la Poudre Middle School is intended to serve as a resiliency system. This system would be charged from the grid and provide power in an outage situation. Since this school is an emergency shelter, funding via a DOLA grant can be applied for, and would help with this capital improvement measure. The value this system offers cannot be quantified into a monetary amount on the utility bill, but rather derived by adding robustness to an emergency shelter’s electrical infrastructure.

| Cache la Poudre Middle School | BESS System  |
|-------------------------------|--------------|
| BESS Use Case                 | Backup Power |
| Manufacturer                  | SYL/ STEM    |
| System Size (kWAC)            | 250          |
| System Size (kWh)             | 500          |
| Total Project Cost            | \$529,369    |

### BESS INTERCONNECTION

To achieve interconnection, a new section of switchboard would need to be installed to house an SEL-700G electronically operated breaker. An electrical field investigation will also be needed to check for space for either a load side tap or 600-amp breaker. See appendix B for full SLD mark-ups.

Cache la Poudre MS PV System Proposed Interconnection Method





# 3. Portfolio Details

## 3.3.5 Fort Collins High School

### SITE DESCRIPTION

The recommended PV carport system at Fort Collins High School totals 1,222.6kW-DC.

The carport system utilizes 4 standalone canopies with 5 rows of modules in portrait at a 5° tilt, utilizing parking lots for utility consumption offset while providing shaded parking.

Fort Collins High School



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Fort Collins HS                 | Carport System             |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 1,876,400                  |
| System Size (kWDC/kWAC)         | 1,222.6/960.0              |
| Production, Year 1 (kWh-AC)     | 1,715,800                  |
| Solar Offset, Year 1            | 91.4%                      |
| GHG Reduction, Year 1 (MT CO2e) | 708.7                      |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Fort Collins HS – Direct Ownership                          |             |
|---|-------------|
| Total Project Cost***                                       | \$5,140,500 |
| Total Project Cost with 30% IRA Contribution                | \$3,598,400 |
| Bill Savings, Year 1  | \$95,800    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 37.0        |
| Simple Payback without FCU Incentive (years)                | 37.5        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$1,681,800 |
| 25-year Total Lifetime Savings                              | \$3,361,100 |
| End of Life Decommissioning Cost                            | \$317,900   |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY   | Equipment Description              |
|-------------------------|-------|------------------------------------|
| PV Modules              | 2,264 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 16    | CPS 60kW-AC                        |
| Data Acquisition System | 1     | AlsoEnergy Data Acquisition System |





## 3. Portfolio Details

### 3.3.6 Fossil Ridge High School

#### SITE DESCRIPTION

The recommended ground mount system at Fossil Ridge High School totals 679.3 kWDC.

The ground mount system is comprised of 10 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 9 trees.

Fossil Ridge High School



### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Fossil Ridge HS                 | Ground Mount System        |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E370 |
| Annual Usage                    | 2,029,500                  |
| System Size (kWDC/kWAC)         | 679.3/540.0                |
| Production, Year 1 (kWh-AC)     | 1,126,300                  |
| Solar Offset, Year 1            | 55.5%                      |
| GHG Reduction, Year 1 (MT CO2e) | 465.2                      |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Fossil Ridge HS – Direct Ownership                          |             |
|---|-------------|
| Total Project Cost***                                       | \$2,174,200 |
| Total Project Cost with 30% IRA Contribution                | \$1,521,900 |
| Bill Savings, Year 1  | \$63,300    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 23.2        |
| Simple Payback without FCU Incentive (years)                | 24.0        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$255,300   |
| 25-year Total Lifetime Savings                              | \$2,130,500 |
| End of Life Decommissioning Cost                            | \$139,300   |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


# 3. Portfolio Details

| Equipment Type          | QTY   | Equipment Description              |
|-------------------------|-------|------------------------------------|
| PV Modules              | 1,258 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 9     | CPS 60kW-AC                        |
| Data Acquisition System | 1     | AlsoEnergy Data Acquisition System |

## INTERCONNECTION

The SLD below illustrates the way the proposed PV system would be interconnected to the site's electrical infrastructure. Fort Collins HS' proposed PV system would be interconnected by either a load side, or supply side tap on the Main Switchboard (MSB1). The main breaker on MSB1 would need the long-time trip setting changed to 3800 amps. See Appendix B for full SLD mark-ups.

**Fossil Ridge HS PV System Proposed Interconnection Method**





# 3. Portfolio Details


## 3.3.7 Johanssen Support Services Center

### SITE DESCRIPTION

The recommended PV carport system at Johanssen Support Service Center totals 151.2kW-DC.

The carport system utilizes 1 standalone canopy with 5 rows of modules in portrait at a 5° tilt, utilizing parking lots for utility consumption offset while providing shaded parking.

Johanssen Support Services Center



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Johanssen Support Services Center | Carport System             |
|-----------------------------------|----------------------------|
| Utility and Current Rate          | City of Fort Collins; E300 |
| Annual Usage                      | 240,500                    |
| System Size (kWDC/kWAC)           | 151.2/120.0                |
| Production, Year 1 (kWh-AC)       | 216,800                    |
| Solar Offset, Year 1              | 90.1%                      |
| GHG Reduction, Year 1 (MT CO2e)   | 89.6                       |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Johannsen Support Services Center – Direct Ownership        |           |
|---|-----------|
| Total Project Cost***                                       | \$895,300 |
| Total Project Cost with 30% IRA Contribution                | \$626,700 |
| Bill Savings, Year 1  | \$12,800  |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 45.1      |
| Simple Payback without FCU Incentive (years)                | 49.0      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$370,900 |
| 25-year Total Lifetime Savings                              | \$430,300 |
| End of Life Decommissioning Cost                            | \$39,300  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 280 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 60kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |

#### INTERCONNECTION

This site appears to be difficult to interconnect any size PV system due to the age of the existing equipment, bus ratings and no available space for a new breaker/fused switch. An electrical field investigation is required to determine if a supply side tap or load side tap is possible. If the electrical field investigation determines either (2 sets) of #4/0 can terminate on the supply side or (2 sets) of #250 can terminate on the load side of the 1200A bus (right section) then the proposed (2) CPS 60kW inverters can be interconnected. The limitations of length of tap conductors for both cases must be factored in the electrical field investigation. See appendix B for full SLD mark-ups.



# 3. Portfolio Details

## 3.3.8 Kinard Core Knowledge Middle School

### SITE DESCRIPTION

The recommended PV carport system at Kinard Core Knowledge Middle School totals 268.9kW-DC.

The carport system utilizes 5 standalone canopies with 5 rows of modules in portrait at a 5° tilt, utilizing parking lots for utility consumption offset while providing shaded parking.

**Kinard Core Knowledge Middle School**



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| <b>Kinard Core Knowledge MS</b> | <b>Carport System</b>      |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 642,200                    |
| System Size (kWDC/kWAC)         | 1268.9/236.0               |
| Production, Year 1 (kWh-AC)     | 388,700                    |
| Solar Offset, Year 1            | 60.5%                      |
| GHG Reduction, Year 1 (MT CO2e) | 163.5                      |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Kinard Core Knowledge MS – Direct Ownership                 |             |
|---|-------------|
| Total Project Cost***                                       | \$1,443,100 |
| Total Project Cost with 30% IRA Contribution                | \$1,010,200 |
| Bill Savings, Year 1  | \$19,700    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 48.7        |
| Simple Payback without FCU Incentive (years)                | 51.2        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$615,500   |
| 25-year Total Lifetime Savings                              | \$663,900   |
| End of Life Decommissioning Cost                            | \$69,900    |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| Equipment Type          | QTY |   | Equipment Description              |             |
|-------------------------|-----|---|------------------------------------|-------------|
| PV Modules              | 460 |   | JA Solar 540-Watt Bifacial Module  |             |
| Inverter                | 4   | 1 | CPS 50kW-AC                        | CPS 36kW-AC |
| Data Acquisition System | 1   |   | AlsoEnergy Data Acquisition System |             |

# 3. Portfolio Details

## INTERCONNECTION

The proposed PV system would interconnect to the main distribution panel via a back feed 400-amp breaker which can be seen in below. See appendix B for full SLD mark-ups.

### Kinard Core Knowledge MS PV System Proposed Interconnection Method



## 3. Portfolio Details

### 3.3.9 Preston Middle School

#### SITE DESCRIPTION

The recommended ground mount system at Preston Middle totals 388.8 kWDC.

The ground mount system is comprised of 12 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 8 trees.

Preston MS





### 3. Portfolio Details

#### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Preston MS                      | Roof System                |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 828,900                    |
| System Size (kWDC/kWAC)         | 388.8/300.0                |
| Production, Year 1 (kWh-AC)     | 626,800                    |
| Solar Offset, Year 1            | 75.6%                      |
| GHG Reduction, Year 1 (MT CO2e) | 258.9                      |

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Preston MS – Direct Ownership                               |             |
|---|-------------|
| Total Project Cost***                                       | \$1,381,100 |
| Total Project Cost with 30% IRA Contribution                | \$966,800   |
| Bill Savings, Year 1  | \$34,900    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 26.3        |
| Simple Payback without FCU Incentive (years)                | 27.7        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$268,200   |
| 25-year Total Lifetime Savings                              | \$1,174,400 |
| End of Life Decommissioning Cost                            | \$79,700    |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


# 3. Portfolio Details

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 720 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 5   | CPS 60kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |

## INTERCONNECTION

The proposed PV system would ideally be interconnected via a 600 amp back feed breaker. In the event the breaker will not fit into the far end of the Main Distribution Switchboard (MDS), the main 2500-amp fuses could be replaced with 2000-amp fuses which would allow the 600 amp breaker to be placed in any section of the MDS. An electrical field investigation would be required to determine the breaker placement. See appendix B for full SLD mark-ups.

**Preston MS PV System Proposed Interconnection Method**





# 3. Portfolio Details

## 3.3.10 Poudre High School

### SITE DESCRIPTION

The PV carport system at Poudre High School totals 871.6kW-DC.

The carport system utilizes 6 standalone canopies, 3 canopies with rows 4 of modules, and 3 canopies with rows of 5 modules in portrait at a 5° tilt. This system utilizes parking lots for utility consumption offset while providing shaded parking.

**Poudre High School**



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| <b>Poudre High School</b>       | <b>Carport System</b>      |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 1,585,800                  |
| System Size (kWDC/kWAC)         | 871.6/726.0                |
| Production, Year 1 (kWh-AC)     | 1,301,400                  |
| Solar Offset, Year 1            | 82.1%                      |
| GHG Reduction, Year 1 (MT CO2e) | 538.0                      |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Poudre High School – Direct Ownership                       |             |
|---|-------------|
| Total Project Cost***                                       | \$3,858,500 |
| Total Project Cost with 30% IRA Contribution                | \$2,700,900 |
| Bill Savings, Year 1  | \$72,800    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 36.4        |
| Simple Payback without FCU Incentive (years)                | 37.0        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$1,244,000 |
| 25-year Total Lifetime Savings                              | \$2,450,700 |
| End of Life Decommissioning Cost                            | \$226,600   |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES


Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY   |   |   | Equipment Description              |             |             |
|-------------------------|-------|---|---|------------------------------------|-------------|-------------|
| PV Modules              | 1,614 |   |   | JA Solar 540-Watt Bifacial Module  |             |             |
| Inverter                | 6     | 3 | 6 | CPS 60kW-AC                        | CPS 50kW-AC | CPS 36kW-AC |
| Data Acquisition System | 1     |   |   | AlsoEnergy Data Acquisition System |             |             |

# 3. Portfolio Details

## INTERCONNECTION

An electrical field investigation and coordination with the Main Distribution Switchboard (MDSB) manufacturer will be needed to finalize the interconnection method. A new 1200-amp section of switchboard could be added to the existing MDSB with the PV system interconnected to a 1200 amp back feed breaker. The existing 4000-amp fuses would need to be replaced with 3500-amp fuses. See Appendix B for full SLD mark-ups.



# 3. Portfolio Details

## 3.3.11 Rocky Mountain High School

### SITE DESCRIPTION

The recommended PV carport system at Rocky Mountain High School totals 1,164.2kW-DC.

The carport system utilizes 10 standalone canopies with rows 4 of modules in portrait at a 5° tilt. This system utilizes parking lots for utility consumption offset while providing shaded parking. As can be seen in the layout below, there are 3 sections of double row parking without PV due to excessive shading from the large trees (green circles).

Rocky Mountain High School



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Rocky Mountain High School      | Carport System             |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 1,851,700                  |
| System Size (kWDC/kWAC)         | 1,164.2/960.0              |
| Production, Year 1 (kWh-AC)     | 1,761,400                  |
| Solar Offset, Year 1            | 95.1%                      |
| GHG Reduction, Year 1 (MT CO2e) | 727.5                      |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Rocky Mountain High School – Direct Ownership               |             |
|---|-------------|
| Total Project Cost***                                       | \$4,930,000 |
| Total Project Cost with 30% IRA Contribution                | \$3,451,000 |
| Bill Savings, Year 1  | \$97,400    |
| REC/ Incentive, Onetime Payment*                            | \$50,000    |
| Simple Payback with FCU Incentive (years)                   | 34.9        |
| Simple Payback without FCU Incentive (years)                | 35.4        |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$1,503,500 |
| 25-year Total Lifetime Savings                              | \$3,275,800 |
| End of Life Decommissioning Cost                            | \$302,700   |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY   | Equipment Description              |
|-------------------------|-------|------------------------------------|
| PV Modules              | 2,156 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 16    | CPS 60kW-AC                        |
| Data Acquisition System | 1     | AlsoEnergy Data Acquisition System |




# 3. Portfolio Details

## INTERCONNECTION

An electrical field investigation and utility guidance will be needed for final interconnection methodology. There are 3 potential options:

- A supply side tap could be implemented if there is enough space in the Main Distribution Switchboard (MDS).
  - It appears that the utility meter current transformers (CT's) are located in section 1 of 7. If this is correct, then the tap can only land in section 2 of 7.
  - If it is allowed by the utility, the taps could be placed in section 1 of 7.
- The third option depends on the switchboard rating in section 7 of 7. A new section with a 1600-amp fused switch could be installed. If they are properly rated and the new section added, then the existing 4000-amp main fuses can be replaced with 3200 amp rated fuses; allowing a load side interconnection. The recent peak utility load data shows the peak current of only 1487 amps. Therefore, 3200A fuses will allow additional future loads. See appendix B for full SLD mark-ups.

**Rocky Mountain HS PV System Proposed Interconnection Method**





# 3. Portfolio Details

## 3.3.12 South Bus Terminal

### SITE DESCRIPTION

The recommended flush mount PV system at the South Bus Terminal totals 101.0 kW-DC.

The roof mount system over the bus parking canopy is a great way to offset energy consumption and could be expanded in the event PSD adds electric busses and chargers. There is a slim margin for structural feasibility at this site, as the available structural capacity is nearly the same as the weight of the proposed PV system.

South Bus Terminal



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| South Bus Terminal              | Flush Mount System         |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E254 |
| Annual Usage                    | 172,500                    |
| System Size (kWDC/kWAC)         | 101.0/85.0                 |
| Production, Year 1 (kWh-AC)     | 136,800                    |
| Solar Offset, Year 1            | 79.3%                      |
| GHG Reduction, Year 1 (MT CO2e) | 56.5                       |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| South Bus Terminal – Direct Ownership                       |           |
|---|-----------|
| Total Project Cost***                                       | \$403,500 |
| Total Project Cost with 30% IRA Contribution                | \$282,500 |
| Bill Savings, Year 1  | \$10,700  |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 21.8      |
| Simple Payback without FCU Incentive (years)                | 26.5      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$69,200  |
| 25-year Total Lifetime Savings                              | \$358,600 |
| End of Life Decommissioning Cost                            | \$17,700  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.


| Equipment Type          | QTY |   | Equipment Description                              |             |
|-------------------------|-----|---|--|-------------|
| PV Modules              | 187 |   | JA Solar 540-Watt Bifacial Module                  |             |
| Inverter                | 1   | 1 | CPS 60kW-AC  | CPS 25kW-AC |
| Data Acquisition System | 1   |   | AlsoEnergy Data Acquisition System                 |             |
| Module Shutdown Unit    | 99  |   | Tigo TS4-A-2F – Tigo PV Module Rapid Shutdown Unit |             |

# 3. Portfolio Details

## INTERCONNECTION

An electrical field investigation would be required to identify if there are terminal ports available on the main switch to land a supply side tap. See appendix B for full SLD mark-ups.

### South Bus Terminal PV System Proposed Interconnection Method



# 3. Portfolio Details

## 3.3.13 Traut Core Knowledge Elementary School

### SITE DESCRIPTION

The recommended PV carport system at Traut totals 156.6kW-DC.

The carport system utilizes 1 standalone canopy with rows 5 of modules in portrait at a 5° tilt. This system utilizes parking lots for utility consumption offset while providing shaded parking.

**Traut Core Knowledge Elementary School**



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Traut Core Knowledge Elementary School | Carport System             |
|--|----------------------------|
| Utility and Current Rate               | City of Fort Collins; E300 |
| Annual Usage                           | 267,900                    |
| System Size (kWDC/kWAC)                | 156.6/120.0                |
| Production, Year 1 (kWh-AC)            | 234,400                    |
| Solar Offset, Year 1                   | 87.5%                      |
| GHG Reduction, Year 1 (MT CO2e)        | 96.8                       |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Traut Core Knowledge Elementary School – Direct Ownership   |           |
|---|-----------|
| Total Project Cost***                                       | \$925,700 |
| Total Project Cost with 30% IRA Contribution                | \$648,000 |
| Bill Savings, Year 1  | \$13,200  |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 45.2      |
| Simple Payback without FCU Incentive (years)                | 49.0      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$383,500 |
| 25-year Total Lifetime Savings                              | \$444,800 |
| End of Life Decommissioning Cost                            | \$40,700  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 290 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 60kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |




# 3. Portfolio Details

## INTERCONNECTION

The proposed PV system at Traut Core Knowledge Elementary School would be interconnected via a supply side tap. An electrical field investigation would be required to determine if there is enough space in the Main Distribution Board (MDB) to achieve this interconnection method.

Traut ES PV System Proposed Interconnection Method





## 3. Portfolio Details

### 3.3.14 Warehouse 5

#### SITE DESCRIPTION

This flush mount roof system layout was designed around the roof capacity assessment where PV will need to be centered over the roof joists, totaling 110.2 kWDC.

Warehouse 5



#### PV SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Warehouse 5                     | Roof System                |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 520,600                    |
| System Size (kWDC/kWAC)         | 110.2/ 100.0               |
| Production, Year 1 (kWh-AC)     | 151,800                    |
| Solar Offset, Year 1            | 29.2%                      |
| GHG Reduction, Year 1 (MT CO2e) | 62.7                       |

### 3. Portfolio Details

#### PV FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Warehouse 5 – Direct Ownership                              |           |
|---|-----------|
| Total Project Cost***                                       | \$404,900 |
| Total Project Cost with 30% IRA Contribution                | \$283,400 |
| Bill Savings, Year 1  | \$9,300   |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 25.2      |
| Simple Payback without FCU Incentive (years)                | 30.6      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$98,000  |
| 25-year Total Lifetime Savings                              | \$232,500 |
| End of Life Decommissioning Cost                            | \$40,700  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR PV EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY | Equipment Description                              |
|-------------------------|-----|--|
| PV Modules              | 204 | JA Solar 540-Watt Bifacial Module                  |
| Inverter                | 2   | CPS 50kW-AC  |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System                 |
| Module Shutdown Unit    | 108 | Tigo TS4-A-2F – Tigo PV Module Rapid Shutdown Unit |

### 3. Portfolio Details

#### BESS DETAILS

The BESS system at Warehouse 5 is intended to be implemented along with the PV system. This system would be charged from PV and generate savings by lowering the demand from the utility, while providing 50% of the system’s capacity for resiliency power.

| Warehouse 5        | BESS System                     |
|--------------------|---------------------------------|
| BESS Use Case      | Demand Management/ Backup Power |
| Manufacturer       | SYL/ STEM                       |
| System Size (kWAC) | 125                             |
| System Size (kWh)  | 250                             |

#### BESS FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below. This system would be a capital improvement measure as the system payback far exceeds the expected system life of 10 years. There is additional value in having backup power at the Warehouse by allowing the refrigeration system to remain online in the event of a blackout. Since this value is difficult to quantify, the savings figures below only include bill reduction from demand management.


| Warehouse 5 – BESS Direct Ownership           |           |
|---|-----------|
| Total Project Cost                            | \$529,400 |
| Total Project Cost with 30% IRA Contribution  | \$370,600 |
| Bill Savings, Year 1                          | \$7,800   |
| Payback (years)                               | 63.7      |
| 10-year Total Lifetime Savings                | \$78,000  |
| Additional Funding Needed for 10 Year Payback | \$370,600 |

# 3. Portfolio Details

## PV AND BESS INTERCONNECTION

An electrical field investigation will be required to determine the final interconnection method. A 400 amp back feed breaker could be used to interconnect both the BESS and PV systems. If the breaker does not fit, a supply side tap can be utilized. For both situations, the existing main fused disconnect would need to be replaced with an electronically operated SEL-700G relay with sync check, and the main breaker long trip setting would need to be set to 500 amps. See Appendix B for full SLD mark-ups.

### Warehouse 5 BESS and PV System Proposed Interconnection Method



# 3. Portfolio Details

## 3.3.15 Werner Elementary School

### SITE DESCRIPTION

The recommended ground mount system at Werner Elementary totals 128.5 kWDC.

The ground mount system is comprised of 4 rows of 2 PV modules high at a 25° tilt. The location has been designed based off input from PSD. This array would need to be fenced in and would require the removal of 4 trees, the backstop, and 2 small benches.

Werner Elementary School



### SYSTEM DETAILS

System technical and performance details are outlined in the table below.

| Werner Elementary               | Ground Mount System        |
|---------------------------------|----------------------------|
| Utility and Current Rate        | City of Fort Collins; E300 |
| Annual Usage                    | 220,500                    |
| System Size (kWDC/kWAC)         | 128.5/100.0                |
| Production, Year 1 (kWh-AC)     | 213,800                    |
| Solar Offset, Year 1            | 96.9%                      |
| GHG Reduction, Year 1 (MT CO2e) | 88.2                       |

### 3. Portfolio Details

#### FINANCIAL DIRECT OWNERSHIP DETAILS

Financial performance details are provided in the table below.

| Werner Elementary – Direct Ownership                        |           |
|---|-----------|
| Total Project Cost**  | \$599,800 |
| Total Project Cost with 30% IRA Contribution                | \$419,900 |
| Bill Savings, Year 1  | \$11,700  |
| REC/ Incentive, Onetime Payment*                            | \$50,000  |
| Simple Payback with FCU Incentive (years)                   | 31.7      |
| Simple Payback without FCU Incentive (years)                | 36.0      |
| Additional Funding Needed to Reach 20 Year Simple Payback** | \$186,800 |
| 25-year Total Lifetime Savings                              | \$392,000 |
| End of Life Decommissioning Cost                            | \$26,300  |

\*FCU offers a onetime incentive of \$0.50/ watt of installed PV, up to \$50,000, two projects can qualify per calendar year.

\*\*Amount excludes any FCU Incentive. Additional funding could be derived from additional IRA contributions, DOLA grant awards, donations, etc.

\*\*\*Financial summary above assumes projects are contracted as a portfolio.

#### MAJOR EQUIPMENT INCLUDED IN PERFORMANCE MODELING AND COST ESTIMATES

Our technical modeling and cost estimates incorporate the specifications and expected performance of the equipment outlined below. For the products listed, there are fungible alternatives with similar cost and performance characteristics available, and thus the exact specification of equipment is not expected to materially impact our estimates of capacity possible, costs, or system performance at the sites analyzed.

| Equipment Type          | QTY | Equipment Description              |
|-------------------------|-----|------------------------------------|
| PV Modules              | 238 | JA Solar 540-Watt Bifacial Module  |
| Inverter                | 2   | CPS 50kW-AC                        |
| Data Acquisition System | 1   | AlsoEnergy Data Acquisition System |




# 3. Portfolio Details

## INTERCONNECTION

The existing electrical infrastructure at Werner Elementary appears to be difficult to interconnect any PV system. An electrical field investigation would be needed to determine if there is space for a supply side tap.

### Werner ES PV System Interconnection Notes



Section

4



# Environmental, Permitting, Zoning and Risk Considerations

## 4. Environmental, Permitting, Zoning and Risk

---

This section describes environmental, permitting, zoning, and other risk items to consider in any project portfolio implementation. Generally, we believe the PSD sites would require relatively straightforward permitting pathways and are characterized by low environmental impact and other risks.

### 4.1 Environmental Considerations

#### **HAZARDOUS MATERIALS AND SOIL/GROUNDWATER CONTAMINATION**

Roof systems do not produce any environmental hazards or concerns, nor do they typically disturb existing contamination given that they are constructed on top of existing buildings and structures.

Construction of ground mounts and parking canopies require additional environmental due diligence because of the boring and trenching required to achieve interconnection. McKinstry has included costs for Phase 1 Environmental Assessments for these sites.

If present, asbestos can be a factor when installing roof anchors, or routing conduit through the building. The abatement of asbestos can lead to added project costs.

#### **GLINT AND GLARE**

Glint and glare studies are sometimes required when any type of PV system is sited at, or within the immediate vicinity of an airport or airfield. Some neighborhood districts also require glare studies. Bethke Elementary would require such analysis due to its proximity to WKR Airport.

### 4.2 Permitting, and Planning and Zoning

#### **PERMITTING**

The Colorado Department of Regulatory Agencies (DORA) is one permitting authority over public schools in Colorado and all electrical permitting will be through DORA. Building permits will be issued by the State School Construction Department of the Division of Fire Prevention and Control. Local fire authorities will also review the project drawings since they would be the first responders to the site in case of any emergency.

#### **PLANNING AND ZONING**

Most of the sites are within the City of Fort Collins and require a Planning and Zoning (P&Z) review. Below is a breakdown of the sites and which type of review is required. No P&Z requirements were found for the sites in the City of Loveland, Town of Timnath, Town of Wellington or Larimer County (Town of Laporte).

## 4. Environmental, Permitting, Zoning and Risk

| Site                              | Zoning Type                           | Basic Development Review | Type 2 (P&Z Commission) |
|-----------------------------------|---------------------------------------|--------------------------|-------------------------|
| Beattie ES                        | Low Density Residential               |                          | x                       |
| Blevins MS                        | Low Density Residential               |                          | x                       |
| Boltz MS                          | Low Density Residential               |                          | x                       |
| Fort Collins HS                   | Medium Density Mixed-Use Neighborhood |                          | x                       |
| Fossil Ridge HS GM                | Low Density Mixed-Use Neighborhood    |                          | x                       |
| Johannsen Support Services Center | Low Density Residential               |                          | x                       |
| Kinard Core Knowledge MS          | Low Density Mixed-Use Neighborhood    |                          | x                       |
| North Transportation Center       | Low Density Residential               |                          | x                       |
| Preston MS                        | Low Density Residential               |                          | x                       |
| Poudre HS                         | Low Density Residential               |                          | x                       |
| Rocky Mountain HS                 | Low Density Residential               |                          | x                       |
| South Bus Terminal                | Employment District                   | x                        |                         |
| Traut Core Knowledge ES           | Low Density Residential               |                          | x                       |
| Warehouse 5                       | Employment District                   | x                        |                         |
| Werner ES                         | Low Density Residential               |                          | x                       |

## 4. Environmental, Permitting, Zoning and Risk

---

### 4.3 Other Risk Considerations

#### ROOF SYSTEMS

- 1) Since all the roofs are off limits to the public, there is no concern for unauthorized personnel accessing, tampering with, or vandalizing these systems. However, if students or other members of the public are known to access a given roof without permission, a plan should be made to mitigate this circumstance.
- 2) To avoid the risk of roof leaks and maintain roof warranties, McKinstry's standard process is to engage the roofing manufacturer to perform a pre-installation and post-installation inspection, as well as ensuring that the mechanical attachments are installed by a roofer certified in the specific roof system.

#### CANOPIES

- 1) All solar carport canopies in this study have been designed to have a minimum clearance of 10'-6", which will allow a typical box truck to pass underneath.
- 2) Since canopies are accessible to the public, the inverters and electrical wiring are typically mounted at a height on the canopy structural columns or installed in such a way that would put them out of reach of the public.
- 3) It is not anticipated that any parking spaces would be eliminated or significantly impeded by the installation of the canopy structures.
- 4) Safety and maintenance of canopies related to snow and ice can be cause for concern. Based on current single tilt design, there is likely to be some snow sloughing and additional areas of ice build-up due to canopy shade in the wintertime. Accordingly, additional snow removal and ice melting operations may be required. Alternative designs that include dual-tilts, snowguards, decking, gutters, and downspouts will control snow and water flow from canopies. However, these additional features add significant cost.
- 5) Design features, including at least a 10'-6" minimum clear height, will make it unlikely that damage to the canopy structure will occur. To mitigate the risk of vehicle driver damage to carport canopies, McKinstry encourages PSD to expand their insurance coverage to include the carports. If accountability is possible, it is likely that the driver's insurance would cover any damage to the structure or modules.

#### GROUND MOUNT

- 1) Ground mount systems typically require an enclosed fence around the perimeter of the array to keep the public and wildlife from accidental contact with or tampering of the electrical equipment and wiring.
- 2) Access roads encompassing the arrays can be required by the Fire Department, but are not typical for smaller scale projects. McKinstry has included costs for access roads into the arrays and not around the array perimeter.

Section

5



# Equipment Considerations and O&M



# 5. Equipment Considerations and O&M

---

## 5.1 Equipment Considerations and Recommended Operations & Maintenance (O&M)

This section provides more detail on equipment selection criteria and recommended post-implementation O&M. While we have modeled the costs and performance of specific major equipment components (e.g., modules, inverters, etc.), such components are equivalent and interchangeable with alternative brands and models from a cost and performance point of view. As such, the overall performance and financial results presented in this study are not impacted by the specific equipment manufacturers and models selected for study.

The O&M discussion includes a breakdown of O&M types, typical scopes of work, and common contract structures. It is recommended that an O&M approach and plan is considered in conjunction with portfolio development and financial modeling. Our financial estimates include an assumed preventative O&M package for the duration of the system lifespans, and further assume all inverters will require replacement at system mid-life (Year 15).

## 5.2 Major Equipment Selection Criteria

### EQUIPMENT SELECTION

There are several factors that are considered when selecting equipment for a solar PV project. Some items may be weighted more heavily than others, but determination must be made on a case-by-case basis. The considerations for PSD when selecting equipment include:

- **Energy Efficient Design**—In several cases, there are pieces of equipment that may work in a particular situation, but that might not be the most efficient equipment available.
- **Financial Strength**—Solar modules are designed to last 25+ years and McKinstry only sources products from suppliers with long track records and the financial strength to honor warranties should any issues arise in the future.
- **Experience with Equipment**—Since we are involved in numerous energy retrofit projects within diverse markets, our staff has experience with various manufacturers. After each project is started and operational, we do an informal “how is the equipment operating” question and answer exchange between McKinstry and the owner’s personnel, as well as between McKinstry’s commissioning and design teams. This provides firsthand feedback on the equipment that is not filtered through an equipment salesperson.
- **Physical Size of Mechanical Equipment Does Matter**—Not all equipment provided by different manufacturers are the same physical size. We do the research necessary to understand if there are physical restraints when replacing equipment.
- **Performance and Quality**—When selecting equipment, a crucial consideration is whether the equipment will perform as needed to meet the intent of the scope and achieve the designated savings. McKinstry selects equipment that is high quality, with proven reliability in similar settings. For this project, McKinstry has selected top tier manufacturers for modules and inverters. The solar photovoltaic market is dynamic with new manufacturers appearing regularly. McKinstry and its partners employ a selection process that emphasizes quality and performance. Particular attention is paid to viability of component manufacturers to ensure they will be available to support the warranty over the life of the

## 5. Equipment Considerations and O&M

---

project. This puts your maintenance staff in the best position to optimally maintain the equipment while keeping operational costs at a minimum.

- **Equipment Delivery Lead-Time**—Another key factor we consider when selecting equipment is the lead-time needed for delivery, as delays in equipment not only hurt schedules, but also can impact costs across multiple efficiency measures. As an extra level of protection for the schedule and budget, we ask for a full equipment review and approval from all team members before committing to any purchases.
- **Best Value for Money Being Spent**—Many contractors are drawn to the lowest first-cost when selecting equipment. This may not be the best long-term value for the owner. Taking the time to evaluate what is being provided for the cost quoted can reveal that the lowest first-cost equipment may require additional options, which cost more than the equipment where first cost was a little higher. The lower cost equipment may require a higher level of maintenance, may not have as long of a useful life, or may not be as energy efficient as a slightly more expensive piece of equipment. Best value, not just first-cost, is our goal when pricing equipment.

### 5.3 Recommended O&M

Post-installation O&M is recommended for any portfolio to ensure reliable long-term operation. Several different types of O&M are typically available in the marketplace, and it is helpful to understand the typical terminology employed to distinguish between the various types of O&M available.

#### DEFINITIONS

**Preventative Maintenance (PM)** – Ongoing performance and alarm monitoring, and scheduled inspection(s) and servicing of equipment to prevent breakdowns and unnecessary production losses. These take place annually according to a specific maintenance plan and schedule dependent on the equipment installed onsite. Annual reports will summarize actual performance vs. expected and will typically list items recommended for correction if not addressable during the annual PM inspection. PM is typically contracted on an annual fixed cost basis, with multi-year plans also commonly available.

**Corrective Maintenance (CM)** – Actions and/or techniques taken to correct equipment faults, failures or damage detected during routine operations and maintenance inspections. Corrective maintenance actions are those that include the material and labor to restore a PV system to its expected performance if any equipment is damaged or deemed defective. CM is typically contracted on a time and materials basis – when corrective actions are minor, these are sometimes covered during annual Preventative Maintenance activities. Examples of CM: ground faults, inverter outage issues, blown fuses and vandalism.

**Extraordinary Maintenance (EM)** – Any activity(s) or action(s) required in the case of major unpredictable events, such as Force Majeure or serial defects, which are considered outside the normal course of business. These events are typically covered by a customer’s insurance policy for their PV system. EM is typically contracted on a time and materials basis.

**Warranty Management** – The activity that manages all equipment under warranty at the time of service with the objective of reducing costs, coordinating repairs, and facilitating any required paperwork such as Return Merchandise Authorization (RMA) receipts. Installation contractors may provide warranty management for a specified term following completion of installation – for example, McKinstry typically includes one year of warranty management for any system McKinstry installs.

# 5. Equipment Considerations and O&M

## TYPICAL PREVENTATIVE MAINTENANCE SCOPE OF WORK

Below is a table summarizing a typical PM services and frequency, followed by a detailed scope of work that McKinstry typically recommends for PM.

| Strategy     | Service  | Frequency  | Deliverable   |
|--------------|--|------------|---|
| Preventative | Ongoing Performance & Alarm Monitoring; integration of dashboard | Continuous | Communications/corrections coordinated with owner as appropriate. |
| Preventative | Preventative Maintenance Inspection                              | Annual     | Preventative Maintenance (PM) Report                              |
| Corrective   | Minor Corrective Maintenance                                     | Annual     | Summary of actions taken included in the above PM Report.         |

### Typical Preventive O&M Scope of Work

#### 1. Operations

##### a) Performance Reporting

- i) Annual Reporting: A report will be provided on an annual basis outlining the solar installation’s performance over the course of the previous year. This report will include the following measurements and additional information on non-routine procedures that resulted in system downtime.
- ii) Monthly Performance Assessment: Monthly Performance Assessment of solar asset by reviewing the Performance Ratio of the given reporting period.

$$(a) \text{ Performance Ratio } (\%) = \frac{\text{Actual Production (kWh)}}{\text{Expected Production (kWh)}}$$

##### b) Alarm Monitoring

- i) 24/7 automatic alarms will be set during the Commissioning phase to alert any system underperformance, equipment, or communication failures.
- ii) Remote supervision of the solar asset's Data Acquisition System (DAS) to ensure there are no active alarms that require immediate attention (i.e., inverter failure).
- iii) If an alarm requires immediate attention the customer will be notified within 1 business day.

#### 2. Preventative Maintenance

a) Inspection will be performed once per year.

b) Inspection will document the condition of all major system components to ensure there are no serious issues beyond expected wear and tear per the equipment operations manual. Major system components include:

- i) Grounds, Roof & Security
- ii) Inverters
- iii) AC System
- iv) DC System

## 5. Equipment Considerations and O&M

---

- v) Modules
  - vi) Racking
  - vii) Data Acquisition System, including the weather station, revenue grade meter and other applicable sensors.
- c) A Preventative Maintenance Report will be provided documenting issues found onsite, photographs taken, and a description and estimate for Corrective Maintenance needs uncovered while onsite.
3. Minor Corrective Maintenance: Minor Corrective Maintenance issues will be completed during the Preventative Maintenance inspections. Should the Minor Corrective Maintenance issued require more time, the Owner will approve additional hours of work required at Time and Materials rates.
4. Deliverables
- a) Monthly
    - i) Performance Assessment
  - b) Annually
    - i) Preventative Maintenance Report
    - ii) Annual Performance Report
    - iii) Site-Specific or Equipment-Specific Service Reports (if applicable)
  - c) As Needed
    - i) Alarm Communication to Owner
    - ii) Corrective Maintenance Service Order

For corrective maintenance issues that cannot be addressed during the annual inspection, typically a comprehensive report to the Owner detailing the required actions and a quote for the corrective maintenance needs are provided. This maintenance will only be performed once the Owner has approved the quote and authorizes the work to proceed.

Section

6



# Financial Funding Options, and Next Steps

# 6. Financial Funding Options

---

This section presents several funding options & considerations that are available to PSD for implementing a portfolio of solar and/or storage projects.

## 6.1 Funding Options & Considerations

Several funding options have been identified to support project implementation for an owner-direct or third-party owned (PPA), behind-the-meter project portfolio.

- **Energy Savings Performance Contracting (ESPC)** - Colorado legislation supports maximum 25-year term and savings would fully fund the project over the life of the term. Savings are guaranteed to PSD to ensure system performance and production for a minimum of 3 years post-construction.
- **Tax Exempt Lease Purchase (TELP)** – Lease model that allows for financing through a series of annual appropriations in a lease-to-own model. Installed equipment would be used as collateral.
- **Certificates of Participation (COP)** – Issuance of new or existing COPs could be leveraged using existing buildings as collateral (instead of installed equipment).
- **Bonds** – Issuance of new or existing bonds; this method typically has a requirement of voter approval per TABOR legislation.
- **Debt-free Mill Levy** – Funding mechanism derived from a tax applied to assessed property value. Also needs to be voter approved.
- **Power Purchase Agreement (PPA)** – Third-party ownership model, whereby PSD would pay for energy produced by projects that are sited on PSD facilities.
- **Grant funding** – the Colorado Department of Local Affairs (DOLA) has funding for renewable energy projects throughout the State. Three cycles per year currently exist, with deadlines of March 1, September 1, and December 1. Other grants could be applicable pending project implementation timeline through State or Federal government programs.
- **Xcel Renewable Energy Credits (RECs) and SPVTOU rate** – It is recommended that PSD leverage Xcel’s renewable energy credits (RECs) and switch the recommended facilities to the Xcel SPV-Time-of-use (SPVTOU) rate (where applicable) to improve the portfolio value and increase annual system savings.
- **IRA Contribution** – All sites will qualify for 30% IRA contribution. See Section 2.7 for IRA information.
- **Combination of funding strategies listed above** – PSD could consider bundling several of the suggested funding strategies above.

## 6.2 PPA Overview

The goal of PPA providers is to provide customers with a \$/kWh rate that is below or close to what is currently being paid. McKinstry worked with a PPA provider local to Fort Collins to evaluate the six sites within the technically and financially feasible portfolio for a PPA approach. We also evaluated a subset of that portfolio, specifically the two large rooftop projects at Timnath and Wellington.

Advantages of a PPA approach are that a third-party owns the system, so O&M, inverter replacement, decommissioning are not the responsibility of the site host / energy off-taker. Dependent on availability of funding, there is a potential timeline advantage for a PPA approach, whereby PSD could implement projects sooner compared to a direct ownership approach.



## 6. Financial Funding Options

---

A significant disadvantage is that the long-term economic value to the customer of a PPA is lower than for customer-owned projects. The PPA provider takes on the ownership risk and responsibility, so will reap the bulk of the financial rewards.

The PPA rate range that resulted from our analysis was \$0.09 – \$0.12/kWh, dependent on where the final EPC pricing comes in. Buydown funds can drive down these rates, so are a key factor to consider. In the case of the high end of ~\$0.12/kWh, for example, a buydown amount of ~13% of the total project price; (~\$880k) would result in a ~\$0.09/kWh rate. Further analysis would be incorporated into the development of a project portfolio towards final pricing. Utility rates, project pricing and other factors change over time, so what may not work today, might pencil a year or two later.

A major factor of PPA pricing is the up-front cost the PPA provider will pay for the Engineering, Procurement and Construction (EPC) of the projects. Given that the EPC pricing range we have provided is +/-20%, there may be a path to an attractive PPA rate for the technically and financially feasible portfolio. A component of reaching an attractive PPA rate is to run a competitive RFP, particularly for the installation scope of work.

### 6.3 Next Steps

Should PSD decide to move forward with further development of a project portfolio, it is important for efficiency and cost effectiveness to decide on which sites to prioritize first. Once favored sites are chosen, next steps include completing the remaining due diligence items, such as electrical interconnection field investigations, roof-top drone surveys, geotechnical assessments, and topographic surveys. Structural racking and electrical bid set drawings packages should also be assembled to best inform a competitive installation RFP that would yield final pricing. During development, utility interconnection applications should be considered, as hosting capacity limits are always changing, as is the availability of utility incentives.

Based on a comprehensive, big picture view of PSD facilities and goals, McKinstry proposes the further development of the a project portfolio under an IGA (investment grade audit) format, such that the renewable energy scopes of work would be bundled with other PSD facility improvements.

Section

A




# Appendix A: Structural Capacity Assessments

# Appendix: Structural Capacity Assessments

McKinstry contracted JVA Inc. to complete the rooftop structural capacity assessments provided in this appendix. Roof capacity assessments were performed on all technically and financially feasible roofs. The minimum capacity needed for rooftop PV on a flat roof is typically 4 psf, while a flush mount roof system needs a minimum of 3 psf. As seen below, all the roofs in this study have enough available capacity for the recommended solar systems.


## BAMFORD ELEMENTARY SCHOOL





# Appendix: Structural Capacity Assessments

## TIMNATH AND WELLINGTON MIDDLE/ HIGH SCHOOL



# Appendix: Structural Capacity Assessments

## SOUTH BUS TERMINAL




# Appendix: Structural Capacity Assessments

## WAREHOUSE 5

### JVA Notes:

*“We ran the calculations on the roof structure for Warehouse 5 and came up with really no available capacity for PV—by analysis, the existing structure is right at capacity with the existing loads. We can use the IEBC provision allowing additional load on the roof if it doesn’t increase the forces to any member by more than 5%—if we do that we can add up to 3 psf of PV in 15’ wide strips centered on the existing building frames (see image below).”*





Section

B




# Appendix B: Interconnection Assessments



# Appendix: Interconnection Assessments

## BEATTIE ELEMENTARY SCHOOL



EXISTING MAIN SWITCHBOARD-VIEW  
N.T.S.

| SERVICE RECAP   |              |
|---|--------------|
| EXISTING HIGHEST DEMAND LAST YEAR PER FT. COOLING LIGHT AND POWER | = 100.8 KW   |
| 100.8 KW AT 90% P.F.  | = 112.0 KVA  |
| 112.0 KVA + 25% PER NEC   | = 140.0 KVA  |
| 140.0 KVA / (208 V X 1.73)  | = 386.1 AMPS |
| EXISTING SERVICE  | = 389.1 AMPS |
| ADDED TO EXISTING   | = 79.8 AMPS  |
| RTU-6   | = 32.2 AMPS  |
| MSU-1   | = 4.7 AMPS   |
| SUB-TOTAL   | = 557.9 AMPS |
| SPARE 20%   | = 101.6 AMPS |
| NEW SERVICE TOTAL   | = 659.5 AMPS |
| EXISTING SERVICE SIZE   | = 100.0 AMPS |

| FEEDER SCHEDULE |                              |
|-----------------|------------------------------|
| DESCRIPTION     |                              |
| 1               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 2               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 3               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 4               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 5               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 6               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 7               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 8               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 9               | 200V 3 PHASE 4 WIRE CU 1.50" |
| 10              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 11              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 12              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 13              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 14              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 15              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 16              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 17              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 18              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 19              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 20              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 21              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 22              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 23              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 24              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 25              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 26              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 27              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 28              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 29              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 30              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 31              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 32              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 33              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 34              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 35              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 36              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 37              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 38              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 39              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 40              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 41              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 42              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 43              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 44              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 45              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 46              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 47              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 48              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 49              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 50              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 51              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 52              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 53              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 54              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 55              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 56              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 57              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 58              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 59              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 60              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 61              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 62              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 63              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 64              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 65              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 66              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 67              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 68              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 69              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 70              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 71              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 72              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 73              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 74              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 75              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 76              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 77              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 78              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 79              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 80              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 81              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 82              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 83              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 84              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 85              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 86              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 87              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 88              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 89              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 90              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 91              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 92              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 93              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 94              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 95              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 96              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 97              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 98              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 99              | 200V 3 PHASE 4 WIRE CU 1.50" |
| 100             | 200V 3 PHASE 4 WIRE CU 1.50" |

- FIELD NOTES - THIS SHEET ONLY**
- REMOVE NEW MAIN BUS FUSES INSTALLED IN EXISTING SPACE. PROVIDE COMPLETE WITH ALL REQUIRED MOUNTING HARDWARE AND PARTS.
  - INTERCEPT EXISTING FEEDER AND RECONNECT TO NEW 100% FUSE SWITCH.
  - REMOVE FUSES AND REPLACE WITH NEW 250A FUSES. DISCONNECT EM PANEL FEEDER AND CONNECT NEW PANEL L7.
  - ELECTRICAL CONTRACTOR SHALL PROVIDE A MINIMUM SIZE 1' COMBINATION STARTER/DISCONNECT. REAR BE DISCONNECT. SEE VOLT. AND AIR CONTRACTOR AS REQUIRED BY I.E.C. COMBINATION STARTER/DISCONNECT SHALL BE 3/4" CLASS SIZE DESIGN BY DESIGNER.
  - USE SPARE SWITCH NEW FUSES. CONNECT TO NEW MAIN UNIT.



**Owner**  
Poudre School District  
2001 Street Street  
Fort Collins, Colorado 80521  
Phone: 970.226.9610

**Architect**  
Sargent & Lundy Group, LLC  
400 West Mulberry Street, Suite 207  
Fort Collins, CO 80521  
Phone: 970.227.0073

**Electrical**  
Poudre Electric  
Fort Collins, CO 80526  
Phone: 970.226.8883

**Mechanical/Plumbing**  
AE Associates  
2001 Street Street  
Fort Collins, CO 80521  
Phone: 970.226.9610  
Fax: 970.226.3040

**Electrical**  
EJ MARR  
800 West 20th Street Unit #112  
Fort Collins, CO 80526  
Phone: 970.226.3286




**BEATTIE ELEMENTARY SCHOOL**

3000 MEADOWLARK AVE.  
FT COLLINS CO 80526

Rev: \_\_\_\_\_ Date: \_\_\_\_\_  
 BY: \_\_\_\_\_ DATE: 11/14/14  
 APPROVED: \_\_\_\_\_ DATE: \_\_\_\_\_

Project Number: 10-007  
 Drawn By: CAD  
 Checked By: RB  
 Approved By: RB

**E5.0**  
ELECTRICAL



EXISTING ELECTRICAL ONE LINE DIAGRAM  
N.T.S.

**Note:** A field investigation for supply side tap shall be performed by the contractor in order to determine if there is enough space for the proposed tap conductors. The preliminary design assumes cable ladders will either fit inside the existing switchboard or in a junction box adjacent to the switchboard.


**Other Options:**

- If there is an option to install a 600A/3-pole breaker on the utility side of the 1000A fused main breaker then cable ladders and the 7' conductor length limitation are not required.
- Finally, if a 600A breaker can fit in the furthest section from the main fused switch, then the existing 1000A main buses can be replaced with 800A rated buses. The recent peak utility load data shows the peak current of only 625A. Therefore, 800A buses will allow some additional future loads.



# Appendix: Interconnection Assessments

## BLEVINS MIDDLE SCHOOL








# Appendix: Interconnection Assessments

## CACHE LA POUVRE MIDDLE SCHOOL - BESS



Note: A field investigation for tap shall be performed by the contractor in order to determine if there is enough space for the proposed tap conductors. However, the best option will be to use a 600A frame breaker instead of the tap, if there is enough space to install a new 600A breaker frame.

| ABBREVIATIONS |                    |
|---------------|--------------------|
| 1. 120V       | 120V CONTROL PANEL |
| 2. 120V       | 120V CONTROL PANEL |
| 3. 120V       | 120V CONTROL PANEL |
| 4. 120V       | 120V CONTROL PANEL |
| 5. 120V       | 120V CONTROL PANEL |
| 6. 120V       | 120V CONTROL PANEL |
| 7. 120V       | 120V CONTROL PANEL |
| 8. 120V       | 120V CONTROL PANEL |
| 9. 120V       | 120V CONTROL PANEL |
| 10. 120V      | 120V CONTROL PANEL |
| 11. 120V      | 120V CONTROL PANEL |
| 12. 120V      | 120V CONTROL PANEL |
| 13. 120V      | 120V CONTROL PANEL |
| 14. 120V      | 120V CONTROL PANEL |
| 15. 120V      | 120V CONTROL PANEL |
| 16. 120V      | 120V CONTROL PANEL |
| 17. 120V      | 120V CONTROL PANEL |
| 18. 120V      | 120V CONTROL PANEL |
| 19. 120V      | 120V CONTROL PANEL |
| 20. 120V      | 120V CONTROL PANEL |
| 21. 120V      | 120V CONTROL PANEL |
| 22. 120V      | 120V CONTROL PANEL |
| 23. 120V      | 120V CONTROL PANEL |
| 24. 120V      | 120V CONTROL PANEL |
| 25. 120V      | 120V CONTROL PANEL |
| 26. 120V      | 120V CONTROL PANEL |
| 27. 120V      | 120V CONTROL PANEL |
| 28. 120V      | 120V CONTROL PANEL |
| 29. 120V      | 120V CONTROL PANEL |
| 30. 120V      | 120V CONTROL PANEL |
| 31. 120V      | 120V CONTROL PANEL |
| 32. 120V      | 120V CONTROL PANEL |
| 33. 120V      | 120V CONTROL PANEL |
| 34. 120V      | 120V CONTROL PANEL |
| 35. 120V      | 120V CONTROL PANEL |
| 36. 120V      | 120V CONTROL PANEL |
| 37. 120V      | 120V CONTROL PANEL |
| 38. 120V      | 120V CONTROL PANEL |
| 39. 120V      | 120V CONTROL PANEL |
| 40. 120V      | 120V CONTROL PANEL |
| 41. 120V      | 120V CONTROL PANEL |
| 42. 120V      | 120V CONTROL PANEL |
| 43. 120V      | 120V CONTROL PANEL |
| 44. 120V      | 120V CONTROL PANEL |
| 45. 120V      | 120V CONTROL PANEL |
| 46. 120V      | 120V CONTROL PANEL |
| 47. 120V      | 120V CONTROL PANEL |
| 48. 120V      | 120V CONTROL PANEL |
| 49. 120V      | 120V CONTROL PANEL |
| 50. 120V      | 120V CONTROL PANEL |
| 51. 120V      | 120V CONTROL PANEL |
| 52. 120V      | 120V CONTROL PANEL |
| 53. 120V      | 120V CONTROL PANEL |
| 54. 120V      | 120V CONTROL PANEL |
| 55. 120V      | 120V CONTROL PANEL |
| 56. 120V      | 120V CONTROL PANEL |
| 57. 120V      | 120V CONTROL PANEL |
| 58. 120V      | 120V CONTROL PANEL |
| 59. 120V      | 120V CONTROL PANEL |
| 60. 120V      | 120V CONTROL PANEL |
| 61. 120V      | 120V CONTROL PANEL |
| 62. 120V      | 120V CONTROL PANEL |
| 63. 120V      | 120V CONTROL PANEL |
| 64. 120V      | 120V CONTROL PANEL |
| 65. 120V      | 120V CONTROL PANEL |
| 66. 120V      | 120V CONTROL PANEL |
| 67. 120V      | 120V CONTROL PANEL |
| 68. 120V      | 120V CONTROL PANEL |
| 69. 120V      | 120V CONTROL PANEL |
| 70. 120V      | 120V CONTROL PANEL |
| 71. 120V      | 120V CONTROL PANEL |
| 72. 120V      | 120V CONTROL PANEL |
| 73. 120V      | 120V CONTROL PANEL |
| 74. 120V      | 120V CONTROL PANEL |
| 75. 120V      | 120V CONTROL PANEL |
| 76. 120V      | 120V CONTROL PANEL |
| 77. 120V      | 120V CONTROL PANEL |
| 78. 120V      | 120V CONTROL PANEL |
| 79. 120V      | 120V CONTROL PANEL |
| 80. 120V      | 120V CONTROL PANEL |
| 81. 120V      | 120V CONTROL PANEL |
| 82. 120V      | 120V CONTROL PANEL |
| 83. 120V      | 120V CONTROL PANEL |
| 84. 120V      | 120V CONTROL PANEL |
| 85. 120V      | 120V CONTROL PANEL |
| 86. 120V      | 120V CONTROL PANEL |
| 87. 120V      | 120V CONTROL PANEL |
| 88. 120V      | 120V CONTROL PANEL |
| 89. 120V      | 120V CONTROL PANEL |
| 90. 120V      | 120V CONTROL PANEL |
| 91. 120V      | 120V CONTROL PANEL |
| 92. 120V      | 120V CONTROL PANEL |
| 93. 120V      | 120V CONTROL PANEL |
| 94. 120V      | 120V CONTROL PANEL |
| 95. 120V      | 120V CONTROL PANEL |
| 96. 120V      | 120V CONTROL PANEL |
| 97. 120V      | 120V CONTROL PANEL |
| 98. 120V      | 120V CONTROL PANEL |
| 99. 120V      | 120V CONTROL PANEL |
| 100. 120V     | 120V CONTROL PANEL |

CONNECTION POINT REFERS TO THE LOCATION OF THE EQUIPMENT TO BE CONNECTED TO THE MAIN BUSBAR. THE LOCATION OF THE EQUIPMENT TO BE CONNECTED TO THE MAIN BUSBAR IS INDICATED BY THE CONNECTION POINT REFERENCE.

NOTE: 1. COORDINATE LOCATION OF DISCONNECTING HEADS WITH EQUIPMENT TO BE CONNECTED. PROVIDE DISCONNECTING HEADS. 2. DISCONNECTING HEADS AND LOW VOLTAGE CONTROLLER SHALL BE PROVIDED BY THE CONTRACTOR. PROVIDE DISCONNECTING HEADS. 3. DISCONNECTING HEADS AND LOW VOLTAGE CONTROLLER SHALL BE PROVIDED BY THE CONTRACTOR. PROVIDE DISCONNECTING HEADS.

**DETAIL - EQUIPMENT CONNECTION**  
SCALE: NONE

**OWNER**  
Poudre School District  
2445 Cottonwood  
1171 Cottonwood, Steamboat  
Phone: 970.482.2610

**ARCHITECT**  
Hessman Group LLC  
433 West Main Street, Suite 207  
Fort Collins, CO 80501  
Phone: 970.487.0270

**DESIGNER**  
CSC  
1715 Broadway  
Fort Collins, CO 80501  
Phone: 970.222.2222

**MECHANICAL, PLUMBING**  
AS Associates  
500 West 19th Street  
Fort Collins, CO 80501  
Phone: 970.222.2222

**ELECTRICAL**  
AS Associates  
500 West 19th Street  
Fort Collins, CO 80501  
Phone: 970.222.2222

**FOUDRE SCHOOL DISTRICT**  
CLP MIDDLE SCHOOL  
37 Paulsen Blvd  
Fort Collins, CO 80501

DATE: 10/20/2023  
DRAWN BY: JRM  
CHECKED BY: JRM  
APPROVED BY: JRM


**E0.02**

# Appendix: Interconnection Assessments

## EYESTONE SOUTH ELEMENTARY SCHOOL

| SERVICE RECAP  |                |
|--|----------------|
| EXISTING HIGHEST DEMAND OVER LAST YEAR FOR POWER COMPANY | = 380.00 KW    |
| 380.00 KW DIVIDED BY 80% POWER FACTOR                    | = 475.00 KW    |
| 380.00 KW PLUS 20%                                       | = 570.00 KW    |
| 570.00 KW DIVIDED BY (208V X 1.73)                       | = 1520.00 AMPS |
| EXISTING SERVICE   | = 648.44 AMPS  |
| NEW PANEL/PCA  | = 252.26 AMPS  |
| NEW PANEL/TE   | = 78.55 AMPS   |
| SUB TOTAL  | = 879.25 AMPS  |
| SPARE 20%  | = 175.85 AMPS  |
| NEW SERVICE TOTAL  | = 1055.10 AMPS |
| EXISTING SERVICE IS                                      | 2500 AMPS      |

| FEEDER SCHEDULE |  |
|-----------------|--|
| KEY             | DESCRIPTION  |
| 1               | 6 RUNS [4 #500 KCMIL HHW-2 CU GRD 3 1/2" C] AND (1) SPARE 3 1/2" C |
| 2               | #8 CU GRD 1/2" C   |
| 3               | #1/0 CU GRD 3/4" C   |
| 4               | #2 THIN CU & #6 GRD 1 1/2" C                                       |
| 5               | #4 THIN CU & #6 GRD 1 1/2" C                                       |
| 6               | #2 THIN CU & #6 GRD 1 1/2" C                                       |
| 7               | #4 THIN CU & #6 GRD 2" C   |
| 8               | #2 THIN CU & #6 GRD 2" C   |
| 9               | #4 THIN CU & #6 GRD 2" C   |
| 10              | #2 THIN CU & #6 GRD 2" C   |
| 11              | #4 THIN CU & #6 GRD 2" C   |
| 12              | #2 THIN CU & #6 GRD 2" C   |
| 13              | #4 THIN CU & #6 GRD 2" C   |
| 14              | #2 THIN CU & #6 GRD 2" C   |
| 15              | #4 THIN CU & #6 GRD 2" C   |
| 16              | #2 THIN CU & #6 GRD 2" C   |
| 17              | #4 THIN CU & #6 GRD 2" C   |
| 18              | #2 THIN CU & #6 GRD 2" C   |
| 19              | #4 THIN CU & #6 GRD 2" C   |
| 20              | #2 THIN CU & #6 GRD 2" C   |
| 21              | #4 THIN CU & #6 GRD 2" C   |
| 22              | #2 THIN CU & #6 GRD 2" C   |
| 23              | #4 THIN CU & #6 GRD 2" C   |
| 24              | #2 THIN CU & #6 GRD 2" C   |
| 25              | #4 THIN CU & #6 GRD 2" C   |
| 26              | #2 THIN CU & #6 GRD 2" C   |
| 27              | #4 THIN CU & #6 GRD 2" C   |
| 28              | #2 THIN CU & #6 GRD 2" C   |
| 29              | #4 THIN CU & #6 GRD 2" C   |
| 30              | #2 THIN CU & #6 GRD 2" C   |
| 31              | #4 THIN CU & #6 GRD 2" C   |
| 32              | #2 THIN CU & #6 GRD 2" C   |
| 33              | #4 THIN CU & #6 GRD 2" C   |
| 34              | #2 THIN CU & #6 GRD 2" C   |
| 35              | #4 THIN CU & #6 GRD 2" C   |
| 36              | #2 THIN CU & #6 GRD 2" C   |
| 37              | #4 THIN CU & #6 GRD 2" C   |
| 38              | #2 THIN CU & #6 GRD 2" C   |
| 39              | #4 THIN CU & #6 GRD 2" C   |
| 40              | #2 THIN CU & #6 GRD 2" C   |
| 41              | #4 THIN CU & #6 GRD 2" C   |
| 42              | #2 THIN CU & #6 GRD 2" C   |
| 43              | #4 THIN CU & #6 GRD 2" C   |
| 44              | #2 THIN CU & #6 GRD 2" C   |
| 45              | #4 THIN CU & #6 GRD 2" C   |
| 46              | #2 THIN CU & #6 GRD 2" C   |
| 47              | #4 THIN CU & #6 GRD 2" C   |
| 48              | #2 THIN CU & #6 GRD 2" C   |
| 49              | #4 THIN CU & #6 GRD 2" C   |
| 50              | #2 THIN CU & #6 GRD 2" C   |
| 51              | #4 THIN CU & #6 GRD 2" C   |
| 52              | #2 THIN CU & #6 GRD 2" C   |
| 53              | #4 THIN CU & #6 GRD 2" C   |
| 54              | #2 THIN CU & #6 GRD 2" C   |
| 55              | #4 THIN CU & #6 GRD 2" C   |
| 56              | #2 THIN CU & #6 GRD 2" C   |
| 57              | #4 THIN CU & #6 GRD 2" C   |
| 58              | #2 THIN CU & #6 GRD 2" C   |
| 59              | #4 THIN CU & #6 GRD 2" C   |
| 60              | #2 THIN CU & #6 GRD 2" C   |
| 61              | #4 THIN CU & #6 GRD 2" C   |
| 62              | #2 THIN CU & #6 GRD 2" C   |
| 63              | #4 THIN CU & #6 GRD 2" C   |
| 64              | #2 THIN CU & #6 GRD 2" C   |
| 65              | #4 THIN CU & #6 GRD 2" C   |
| 66              | #2 THIN CU & #6 GRD 2" C   |
| 67              | #4 THIN CU & #6 GRD 2" C   |
| 68              | #2 THIN CU & #6 GRD 2" C   |
| 69              | #4 THIN CU & #6 GRD 2" C   |
| 70              | #2 THIN CU & #6 GRD 2" C   |
| 71              | #4 THIN CU & #6 GRD 2" C   |
| 72              | #2 THIN CU & #6 GRD 2" C   |
| 73              | #4 THIN CU & #6 GRD 2" C   |
| 74              | #2 THIN CU & #6 GRD 2" C   |
| 75              | #4 THIN CU & #6 GRD 2" C   |
| 76              | #2 THIN CU & #6 GRD 2" C   |
| 77              | #4 THIN CU & #6 GRD 2" C   |
| 78              | #2 THIN CU & #6 GRD 2" C   |
| 79              | #4 THIN CU & #6 GRD 2" C   |
| 80              | #2 THIN CU & #6 GRD 2" C   |
| 81              | #4 THIN CU & #6 GRD 2" C   |
| 82              | #2 THIN CU & #6 GRD 2" C   |
| 83              | #4 THIN CU & #6 GRD 2" C   |
| 84              | #2 THIN CU & #6 GRD 2" C   |
| 85              | #4 THIN CU & #6 GRD 2" C   |
| 86              | #2 THIN CU & #6 GRD 2" C   |
| 87              | #4 THIN CU & #6 GRD 2" C   |
| 88              | #2 THIN CU & #6 GRD 2" C   |
| 89              | #4 THIN CU & #6 GRD 2" C   |
| 90              | #2 THIN CU & #6 GRD 2" C   |
| 91              | #4 THIN CU & #6 GRD 2" C   |
| 92              | #2 THIN CU & #6 GRD 2" C   |
| 93              | #4 THIN CU & #6 GRD 2" C   |
| 94              | #2 THIN CU & #6 GRD 2" C   |
| 95              | #4 THIN CU & #6 GRD 2" C   |
| 96              | #2 THIN CU & #6 GRD 2" C   |
| 97              | #4 THIN CU & #6 GRD 2" C   |
| 98              | #2 THIN CU & #6 GRD 2" C   |
| 99              | #4 THIN CU & #6 GRD 2" C   |
| 100             | #2 THIN CU & #6 GRD 2" C   |



**ELECTRICAL ONE-LINE**  
 120/208V 3PH, 3W, 3P, 4 WIRE  
 NTA

--- EXISTING  
 --- NEW

Note: A field investigation and working with a supplier that can provide a new or refurbished 400A PV breaker will be required in order to qualify the load side breaker on the bus because sum of the main breaker and PV breaker are less than the main bus rating. Alternatively, a busbar side tap breaker to be a workable solution as well.

THIS RECORD DRAWING HAS BEEN PREPARED, IN PART, BASED UPON INFORMATION FURNISHED BY OTHERS. WHILE THIS INFORMATION IS BELIEVED TO BE RELIABLE, THE DESIGN PROFESSIONAL CANNOT ASSURE ITS ACCURACY, AND THERE IS NOT RESPONSIBLE FOR THE ACCURACY OF THIS RECORD DRAWING OR FOR ANY ERRORS OR OMISSIONS WHICH MAY HAVE BEEN INCORPORATED INTO IT. AS A RESULT, THOSE RELYING ON THIS RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE APPLYING IT FOR ANY PURPOSE.

**Barlow Architects**  
 Group Architects LLC  
 1500 River Valley  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**POUDRE SCHOOL DISTRICT**  
 Director  
 Poudre School District  
 1500 River Valley  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**Architect**  
 Barlow Architects Group, LLC  
 1500 River Valley  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**Structural**  
 CSE Consulting  
 475 South College Avenue  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**Mechanical & Plumbing**  
 AE Associates, Inc.  
 1500 River Valley  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**Electrical**  
 AE Associates, Inc.  
 1500 River Valley  
 Fort Collins, CO 80521  
 Phone: 970.232.8005  
 Fax: 970.232.8005

**Wellington Middle School Major Renovation Package**  
 980 Miller Avenue  
 Wellington, CO 80550

Sheet No. 10-09  
 Date: 10/20/21  
 Design: 10/20/21  
 Check: 10/20/21  
 Approved: 10/20/21  
 Date: 10/20/21  
 Date: 10/20/21  
 Date: 10/20/21  
 Date: 10/20/21


**E5.0**  
 ELECTRICAL ONE-LINE





# Appendix: Interconnection Assessments

## JOHANNSEN SUPPORT SERVICES CENTER











# Appendix: Interconnection Assessments

## PRESTON MIDDLE SCHOOL



# Appendix: Interconnection Assessments

## POUDRE HIGH SCHOOL



**NOTES:**

- REFER TO REVISIONS ON SHEET E1.1 FOR CHANGES TO THIS DRAWING. THE CONTRACTOR SHALL VERIFY THE EQUIPMENT IS LOCATED AS SHOWN. THE CONTRACTOR SHALL VERIFY THE EQUIPMENT IS LOCATED AS SHOWN. THE CONTRACTOR SHALL VERIFY THE EQUIPMENT IS LOCATED AS SHOWN.
- THIS DRAWING IS NOT INTENDED TO BE USED AS A BASIS FOR CONSTRUCTION. THE CONTRACTOR SHALL VERIFY THE EQUIPMENT IS LOCATED AS SHOWN. THE CONTRACTOR SHALL VERIFY THE EQUIPMENT IS LOCATED AS SHOWN.
- VERIFY ALL SWITCHED EQUIPMENT AND PROVIDE AS INDICATED. VERIFY ALL SWITCHED EQUIPMENT AND PROVIDE AS INDICATED.

**FLAG NOTES:**

- INDICATES TO BE REMOVED AND NOT REPLACED. ALL COMPONENTS TO BE REMOVED SHALL BE RELOCATED TO SOURCE AS INDICATED BY REVISIONS.
- INDICATES TO BE REMOVED AND NOT REPLACED. ALL COMPONENTS TO BE REMOVED SHALL BE RELOCATED TO SOURCE AS INDICATED BY REVISIONS.
- INDICATES TO BE REMOVED AND NOT REPLACED. ALL COMPONENTS TO BE REMOVED SHALL BE RELOCATED TO SOURCE AS INDICATED BY REVISIONS.
- INDICATES TO BE REMOVED AND NOT REPLACED. ALL COMPONENTS TO BE REMOVED SHALL BE RELOCATED TO SOURCE AS INDICATED BY REVISIONS.

**ARCHITECTURE PLUS**  
 1000 14th Street, Suite 100, Fort Collins, CO 80521  
 970.226.1111  
 www.architectureplus.com


**SHEET CONTENTS**  
 ELECTRICAL DEMOLITION  
 Poudre High School Renovations  
 Fort Collins, CO 80521

**BALDWIN CONSULTING**  
 1000 14th Street, Suite 100, Fort Collins, CO 80521  
 970.226.1111  
 www.baldwinconsulting.com

**ISSUE FOR BIDDING**  
 DATE: 10/20/2023  
 DRAWING NO: ED5.1

# Appendix: Interconnection Assessments

## RICE ELEMENTARY SCHOOL



THIRD CONSTRUCTION OF PHOTOVOLTAIC ELEMENTARY SCHOOL  
**2007 ELEMENTARY SCHOOL**  
 WELLSINGTON, COLORADO

**RBB**

REG. NO. 00000000  
 LICENSED PROFESSIONAL ENGINEER  
 ELECTRICAL  
 STATE OF COLORADO

DESIGNED BY: RBB  
 CHECKED BY: RBB  
 ISSUE DATE: APRIL 2008  
 REVISIONS:

**SHEET NUMBER: E2.4**

# Appendix: Interconnection Assessments

## ROCKY MOUNTAIN HIGH SCHOOL

### SHORT CIRCUIT CALCULATIONS

$$X1 = \frac{139 \times 400^2 \times 0.0002}{6 \times 36700 \times 400} = 0.04$$


$$X2 = \frac{139 \times 400^2 \times 0.0002}{2 \times 3920 \times 400} = 2.244$$

$$X3 = \frac{139 \times 75^2 \times 0.0002}{1400 \times 400} = 0.01$$

$$X4 = \frac{1280 \times 138 \times 2 \times 400}{100000 \times 75} = 2.126$$

$$X5 = \frac{139 \times 400^2 \times 0.0002}{3920 \times 200} = 0.245$$

NOTE: A field investigation for energy with the tap shall be performed by the contractor in order to determine if there is enough space for the proposed tap connection. It appears that the utility meter CT is located in section 7 of 7. This is correct. From the tap can only feed to either section 2 of 7, it might be good to ask the utility if the tap could land in section 1 of 7. The CT location is also shown that this could be an alternative to section 2 of 7. There is also a third option depending on the neighborhood layout in section 7 of 7 and a new section with a 1500A busbar can be installed. If they are primarily meter feed for the system based from the existing 2000A main busbar can be replaced with 3000A meter busbar allowing a load shift PDU. The main peak utility load data shows the peak current is only 1487A. Therefore, 2000A busbar will allow additional future loads.




### EXISTING FEEDER SCHEDULE

- 1 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 2 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 3 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 4 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 5 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 6 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 7 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 8 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 9 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 10 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 11 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 12 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 13 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 14 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 15 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 16 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 17 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 18 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 19 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 20 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 21 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 22 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 23 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 24 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 25 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 26 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 27 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 28 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 29 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 30 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 31 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 32 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 33 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 34 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 35 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 36 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 37 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 38 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 39 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 40 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 41 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 42 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 43 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 44 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 45 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 46 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 47 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 48 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 49 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 50 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 51 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 52 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 53 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 54 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 55 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 56 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 57 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 58 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 59 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 60 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 61 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 62 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 63 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 64 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 65 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 66 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 67 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 68 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 69 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 70 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 71 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 72 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 73 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 74 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 75 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 76 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 77 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 78 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 79 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 80 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 81 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 82 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 83 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 84 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 85 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 86 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 87 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 88 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 89 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 90 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 91 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 92 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 93 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 94 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 95 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 96 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 97 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 98 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 99 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)
- 100 8 BARE (4000 HCH TRN) GL 2 1/2" (300 AMP)

### APPENDIX K CLARIFICATION

1. REVISED FEEDER SCHEDULE FOR PANEL 1000 SE TO BE USED FOR THE NEW 1500 KVA TRANSFORMER.



ELECTRICAL ONE-LINE DIAGRAM - EXISTING

NOTE: ONE-LINE DIAGRAM REQUIRED FOR ALL NEW WORK INDICATED WITHIN CIRCLED AREA.



**CONSULTANTS**  
**PROJECT ENGINEER**  
 Daniel J. Melik, P.E.  
 1300 West Swallow  
 Ft. Collins, CO 80522  
 970.226.4884  
 Contact: Dan.Melik@melik.com

**MECHANICAL ENGINEER**  
 Daniel J. Melik, P.E.  
 1300 West Swallow  
 Ft. Collins, CO 80522  
 970.226.4884  
 Contact: Dan.Melik@melik.com


**PROJECT TITLE**  
 Gymnasium Addition to  
 Rocky Mountain  
 High School  
 1300 West Swallow  
 Ft. Collins, Colorado  
 80522  
 Poudre School District

| REVISION | DATE       | BY | DESCRIPTION       |
|----------|------------|----|-------------------|
| 1        | 05/17/2024 | DM | ISSUED FOR PERMIT |
| 2        | 05/17/2024 | DM | 95% CDS           |
| 3        | 05/17/2024 | DM | 100% CDS          |
| 4        | 05/17/2024 | DM | AS-BUILT          |
| 5        | 05/17/2024 | DM | AS-BUILT          |


**TITLE**  
 ONE-LINE  
 DIAGRAM  
**E-6**  
 SHEET OF 55

# Appendix: Interconnection Assessments

## SOUTH BUS TERMINAL




Note: A field investigation for supply side tap shall be completed by the contractor in order to confirm there is an available terminal post on the line side of the main switch. Cable trays are not to be expanded if the new PV disconnect can be installed to the left of the existing utility meter and the tap conductors by 18.0' or more.



The existing main switch is a Square D 8000/700 and has (5) terminal posts per phase as shown. Therefore there should be an available post because the service is 300' with according to the Feeder Schedule on this sheet, and there are (2) conductors entering the bottom of the main switch.




**SQUARED**

CATALOG NO. \_\_\_\_\_  
 NO. DE CATALOGUE \_\_\_\_\_  
 AMPS / AMPERES \_\_\_\_\_  
 VOLTS / VOLTIOS \_\_\_\_\_  
 ENCLOSURE TYPE \_\_\_\_\_  
 TYPE D' ARMATURE \_\_\_\_\_  
 SERIES / SERIE E4



DESIGN-IN-PROGRESS

ID-15-02



**RBB**

SOUTH SIDE SERVICE CENTER  
 SATELLITE BUS  
 MAINTENANCE FACILITY  
 Poudre School District

Job Number: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Drawn: \_\_\_\_\_  
 Checked: \_\_\_\_\_  
 Issue: \_\_\_\_\_  
 Revisions: \_\_\_\_\_

SHEET NAME: POWER PLAN  
 SHEET NUMBER: \_\_\_\_\_


16.3





# Appendix: Interconnection Assessments

## TRAUT CORE KNOWLEDGE ELEMENTARY SCHOOL




**1999 ELEMENTARY SCHOOL**  
**POUDRE SCHOOL DISTRICT R-1**  
**FORT COLLINS, COLORADO**

JOB NO. 9703  
 DRAWN BY: KALBE/JJA  
 CHECKED BY: RBC/CP  
 REVISION  
 DATE: 9-30-01  
 ONE-LINE POWER PLAN  
**E4.1**  
 62 of 67



# Appendix: Interconnection Assessments

## WELLINGTON MS/HS -PV AND BESS



**RBB ARCHITECTS**  
 1000 14th Street, Suite 1000  
 Boulder, CO 80502  
 Phone: 303.440.1234  
 Fax: 303.440.1235  
 www.rbbarchitects.com

**MKK**  
 DESIGN & BUILD, INC.  
 1000 14th Street, Suite 1000  
 Boulder, CO 80502  
 Phone: 303.440.1234  
 Fax: 303.440.1235  
 www.mkkdesign.com

**CONSTRUCTION DOCUMENTS**

**PSD PROTOTYPE MS/HS #1**  
 Poudre School District  
 8549 North County Road 9  
 Wellington, Colorado 80549

**PROJECT INFORMATION**

**PROJECT #** 1873  
**ISSUE DATE** 12/20/23

**REVISIONS:**


| NO. | DATE     | DESCRIPTION      |
|-----|----------|------------------|
| 1   | 12/20/23 | ISSUE FOR PERMIT |
| 2   | 12/20/23 | ISSUE FOR PERMIT |
| 3   | 12/20/23 | ISSUE FOR PERMIT |
| 4   | 12/20/23 | ISSUE FOR PERMIT |
| 5   | 12/20/23 | ISSUE FOR PERMIT |
| 6   | 12/20/23 | ISSUE FOR PERMIT |
| 7   | 12/20/23 | ISSUE FOR PERMIT |
| 8   | 12/20/23 | ISSUE FOR PERMIT |
| 9   | 12/20/23 | ISSUE FOR PERMIT |
| 10  | 12/20/23 | ISSUE FOR PERMIT |
| 11  | 12/20/23 | ISSUE FOR PERMIT |
| 12  | 12/20/23 | ISSUE FOR PERMIT |
| 13  | 12/20/23 | ISSUE FOR PERMIT |
| 14  | 12/20/23 | ISSUE FOR PERMIT |
| 15  | 12/20/23 | ISSUE FOR PERMIT |
| 16  | 12/20/23 | ISSUE FOR PERMIT |
| 17  | 12/20/23 | ISSUE FOR PERMIT |
| 18  | 12/20/23 | ISSUE FOR PERMIT |
| 19  | 12/20/23 | ISSUE FOR PERMIT |
| 20  | 12/20/23 | ISSUE FOR PERMIT |

**ELECTRICAL ONE-LINE DIAGRAM, 1PHASE AND 480V**

**E200**

# Appendix: Interconnection Assessments

## WERNER ELEMENTARY SCHOOL



**RBB**  
Architects, Inc.  
215 East Riverside Ave.  
Fort Collins, CO 80521-2912  
719.226.8811  
www.rbbarchitects.com

**MKK**  
ENGINEERING CONSULTANTS, INC.  
3070 East Mountain View  
Fort Collins, CO 80521  
719.226.8811

**CONSTRUCTION DOCUMENTS**

**WERNER ELEMENTARY  
RENOVATION PROJECT**  
POUDRE SCHOOL DISTRICT  
3400 MAIL CREEK LANE  
FORT COLLINS, COLORADO 80525-3886

**PROJECT #:** 2011.01.0143  
**DRAWN BY:** CW  
**CHECKED BY:** ETH  
**ISSUE DATE:** 4-25-22  
**REVISIONS**

| No. | Description       | Date       |
|-----|-------------------|------------|
| 1   | ISSUED FOR PERMIT | 11/11/2021 |

**ELECTRICAL ONE-LINE DIAGRAM & PANEL SCHEDULES**  
**E301**