

Questions & Answers - 1

Solicitation 19-345-001 - Fossil Ridge High School Synthetic Turf and Installation
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Brock Shock Pad Alternate Approval Brock USA is seeking to have Brock Shock Pad/Series 14 (SP14) added as an alternate for this RFP. Is it allowed?</p> <p>Answer: The Brock Shock Pad/SERIES 14 (SP14) has been accepted as an approved alternate for the Fossil Ridge High School Synthetic Turf and Installation project - RFP 19-345-001.</p>	04/16/2019
Q2	<p>Question: Alternative Turf system bid (48 ounce) Can we get approved to bid our 48 ounce Blend turf system? We would like to bid our 48 ounce fiber system.</p> <p>Thanks,</p> <p>Answer: Per section 3.8.11.A.1(g & h), Poudre School District established minimums of 52-ounce face weight and 80-ounce total weight. A 48-ounce fiber system does not meet the minimum and, therefore, is not acceptable.</p>	04/17/2019