

Questions & Answers - 2

Project 20-220-001 - Boltz Middle School Tubular Daylight Device Installation
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q6	<p>Question: General Questions</p> <ol style="list-style-type: none">1. Please confirm day lighting devices to be 14" and not 22" per specs provided.2. Please confirm no structural reinforcement required at roof penetrations.3. Please confirm no room darkening daylight controllers or commercial energy kits required.4. Is a permit required for this project? <p>Answer: *Questions that are not entered one at a time in the future, will not be answered per directions in IFB and BidNet portal*</p> <ol style="list-style-type: none">1. Yes, 14in per IFB.2. No structural reinforcement required.3. No controls required.4. Yes, owner provided.	02/18/2020
Q7	<p>Question: Roofing Contractors</p> <p>Are these the only approved roofing contractors we can use? Can you provide better information for United Roofing? Have been unable to find them.</p> <p>Answer: A Johns Manville Certified Installer must be used to maintain the warranty. No further information on United Roofing is available at this time.</p>	02/19/2020
Q8	<p>Question: Roof Access</p> <p>Is it possible to get access to the roof to view again?</p> <p>Answer: We will not be having an additional site visit for this project.</p>	02/24/2020
Q9	<p>Question: Solutube Size</p> <p>Are we bidding 14" as per the walk through or 22" as per the specs.</p> <p>Answer: 14 inch as per the IFB Section 5.1</p>	02/24/2020