

Questions & Answers - 2

Project 20-230-001 - Cache La Poudre Middle School South Five Classroom Mechanical Cooling Project
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Curbs for Condensing Units Is it necessary to provide concrete curbs at the deck? Can we just use plastic condensing curbs on the existing roof material to avoid a lot of roofing costs and concrete costs?</p> <p>Answer: The engineer has stated that the units are too heavy for such an application. The drawings must be followed. The curb will go down to the roof deck and structural reinforcements to the roof trusses will need to be made.</p>	02/06/2020
Q2	<p>Question: Room Numbers Can the drawings be updated with the correct room numbers?</p> <p>Answer: This was answered in Addendum 1 and a new drawing has been posted.</p>	02/06/2020