

Questions & Answers - 2

Solicitation 20-345-001 - Fossil Ridge High School Boiler Replacements
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q5	<p>Question: Gas Piping</p> <p>We noticed at the job walk gas pressure regulators at each boiler. The new boiler gas piping detail does not show gas regulators. Is this correct?</p> <p>Answer: Individual gas regulators must be ordered with each boiler.</p>	03/18/2020