

Questions & Answers - 1

Project 20-350-002 - PHS - Stain and Polish Concrete Corridor Floors
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Terrazzo Replacement Would Cement Based Terrazzo Be Acceptable. With Cement Based Terrazzo, there are many options available, to meet the look your after.</p> <p>Answer: The old terrazzo would need to be removed and replaced with concrete to match the other areas Per the IFB.</p>	03/27/2020
Q2	<p>Question: Concrete under VCT Do you have any idea of the condition of the concrete under the VCT?</p> <p>Answer: We have no idea of the condition of concrete under the VCT. Some of the slab was poured during the 1996 remodel some of the slab is original to the building. We know that there will be imperfections in the slab.</p>	03/27/2020
Q3	<p>Question: Aggregate exposure What level of aggregate exposure are you looking for?</p> <p>Answer: We are not looking for any specific level of exposed aggregate. We want the concrete to be ground flat and polished. We are okay if there are areas of more or less exposed aggregate.</p>	03/27/2020
Q4	<p>Question: Propane equipment Can propane equipment be used?</p> <p>Answer: Yes, propane equipment is acceptable as long as it is running efficiently.</p>	03/27/2020
Q5	<p>Question: Verify available power Can you verify that there will be acces to power at the time work takes place?</p> <p>Answer: If 3 phase power is needed PSD electricians will work with the contractor to get a pig tail wired into a breaker box. We will need to know the electrical need prior to the start of the project.</p>	03/27/2020