

Questions & Answers - 1

Solicitation 20-505-001 - Polaris Expeditionary Learning School Media Center Recording Studio
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Wall scope the new wall at Studio says it is just a sound wall C3-S, in site visit we were told it goes to deck?</p> <p>Answer: Both the plans and the site visit call for full height walls, to roof deck.</p>	03/18/2020
Q2	<p>Question: Scope question Drw A4.1, is there any scope in Library, #101?</p> <p>Answer: There is no scope of work in room #101 proper, just the walls constructed around the sound booth to create room #110.</p>	03/18/2020
Q3	<p>Question: Scope question Dra A4.1, what is the C3 that is in a box mean? in 101, studio area and 102.</p> <p>Answer: The Project Manager is not certain and no timely response from the Architect. Please bid from the existing keynote text and the Project Manager will clarify after award.</p>	03/18/2020
Q4	<p>Question: Scope Question A4.1 E10 states new announcement speaker. Is this by GC and what are the specs for it.</p> <p>Answer: Owner provided; coordinate with the Project Manager before installation.</p>	03/18/2020