

Questions & Answers - 1

Solicitation 20-600-002 - Johannsen Support Services Center West Wing Carpet, Windows and Lighting
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Low Voltage Please confirm what scope, if any, is required of Low Voltage contractors.</p> <p>Answer: Prior to cubicle / workspace removal, low voltage contractor shall (but is not limited to): Label all wiring in each work area, Remove wiring, Protect wiring for re-install, Re-install wiring, Test, Terminate.</p>	03/19/2020
Q2	<p>Question: Window Coverings Key Note 4 states remove and recycle all existing mini blinds and other window coverings. Does this include locations where existing windows are not being replaced?</p> <p>Answer: Only remove and recycle mini blinds / window coverings from windows that are being replaced.</p>	03/19/2020
Q3	<p>Question: Light Disposal Is contractor responsible for disposal of light fixtures, including separation of lights and ballasts?</p> <p>Answer: Yes, contractor is responsible for disposal of light fixtures, including separation of lights and ballasts.</p>	03/19/2020
Q4	<p>Question: Windows Abatement Please confirm that no abatement is required at any window locations.</p> <p>Answer: No abatement is required at any window location.</p>	03/19/2020