

Questions & Answers - 3

Project 20-700-006 - Commissioning Services for the Three New Schools
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q16	<p>Question: Building Envelope / Building Leak Testing</p> <p>The City of Fort Collins typically requires verification of building leakage by way of blower door testing and that the leakage rate falls at or below a specified threshold. While it is our understanding that the District is technically required to comply only with the State of Colorado requirement, which does not require any sort of objective building envelope testing, is it the intent of the district to comply with the Ft. Collins requirement and if so, should we provide a line item in our proposal to conduct Bldg. Envelope Cx and/or blower door testing?</p> <p>Answer: This will not be a requirement for this RFQu.</p>	12/18/2019
Q17	<p>Question: Systems to be commissioned</p> <p>Please confirm if systems on page 10, 1.3 Systems To Be Commissioned numbers 3. Fire Protection System, 9. Public Address System, and 10. Irrigation Systems are part of the commissioning scope.</p> <p>Answer: This is correct, Item 3, 9, 10 will not be required for this RFQu.</p>	12/18/2019