



POUDRE SCHOOL DISTRICT R-1

IFB #20-700-010

Roof Recoating Projects

Addendum 4.0

ADDENDUM POSTING DATE: April 2, 2020
NEW SITE VISIT: April 6, 2020 @ 9:00 a.m. MST
QUESTIONS DUE: April 7, 2020 @ 2:00 p.m. MST
IFB CLOSING DATE: April 10, 2020 @ 2:00 p.m. MST

The attached product substitution request was submitted and approved. Please see the Architect's notes on the approval below.

"The substitution request you forwarded was for a spray foam and urethane coating (from a different manufacturer) which appear to meet the requirements of the specs other than they do not include information on any granule coats. The specifications note that a substitution like this must be approved through an addendum, so all bidders are aware and have equal opportunity, before the project bids.

Amtech suggests allowing the substitution request in an addendum and also stating for bidders to please refer to specification section 07-5700 for additional manufacturer approved application of Granule Coat which will be still required in addition to the alternative manufacturer substitution request. "

The question and answer period has been extended until April 7, 2020 @ 2:00 p.m. MST for any questions related to this project or any of the addenda.