

Questions & Answers - 1

Project 20-700-010 - Roof Recoating Projects
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Roof Inspection/Field Verification Is it possible to walk this roof to inspect and field verify conditions and measurements prior to the bid being due?</p> <p>Answer: Please see the addendum posted 3/31/2020 for site visit information.</p>	03/25/2020
Q2	<p>Question: Existing Roof Coating? Can you confirm the existing roof is granulated silicone or granulated urethane? Seeing conflicting statements in the bid documents.</p> <p>Answer: Understood to be granulated urethane.</p>	03/25/2020
Q3	<p>Question: Product Type The bids are calling for granulated coating which is typically use just for walkways. There is not a product that comes in granulated. Can we please get some clarification on the coating product?</p> <p>Answer: The basis for design is for a fluid-applied roof coating with a granule coat over.</p>	03/26/2020
Q4	<p>Question: Coating Adhesion Will an adhesion test be required?</p> <p>Answer: An adhesion test is not required for the basis of design material. Please note if another material or manufacturer product is approved by PSD, then a pull test is recommended.</p>	03/27/2020
Q5	<p>Question: Adhesion Results Will alternative coating materials be accepted? (i.e. Acrylic, Silicone)</p> <p>Answer: Alternative coating materials not recommended by Amtech.</p>	03/27/2020