

Questions & Answers - 1

Solicitation 20-715-004 - Flooring Abatement Services for Bauder Elementary and Lincoln Middle
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Question on IFB Can the IFB closing date be extended to 2/25/2020?</p> <p>Answer: No. The due date/time identified in the original IFB document will stand.</p>	02/11/2020
Q2	<p>Question: Lincoln Middle School Is there a survey report available specifying the trace amounts of mercury on the tartar flooring?</p> <p>Answer: The results for both Lincoln Middle Aux. Gym and Bauder Elementary are provided as Exhibits B and C to Addendum 1.</p>	02/13/2020
Q3	<p>Question: Bauder Elementary scope can we get an updated diagram for the changes in scope at Bauder Elementy School?</p> <p>Answer: Yes. An updated diagram has been provided as Exhibit A to Addendum 1.</p>	02/14/2020
Q4	<p>Question: Insurance requirements is the district willing to waive the insurance minimum limits to a lower amount and if so what would they be?</p> <p>Answer: The insurance limits identified in the original IFB document will stand.</p>	02/14/2020
Q6	<p>Question: Tartan Flooring are there any specification for the Tartan flooring removal? (I.E. work practices and air clearances)</p> <p>Answer: Work practices should be similar to Regulation 8 floor tile removal practices including negative air, criticals, etc. No air clearances are required.</p>	02/14/2020