

## Questions & Answers - 2

**Project** 21-103-002 - Bauder Elementary Asbestos Abatement Project  
**Buying Organization** Poudre School District

No	Question/Answer	Question Date
Q3	<p><b>Question: Revised Diagram</b></p> <p>During the site visit, it was discovered that an area listed near the corner of room 400 had already been completed and that a closet near room 13 had been missed. Will an updated diagram be posted?</p> <p><b>Answer:</b> Please find a revised Exhibit A.</p>	04/05/2021
Q5	<p><b>Question: Base Trim Mastic</b></p> <p>During the site visit, the mastic for the base trim was said to have a trace designation. What action should be taken when removing the base trim?</p> <p><b>Answer:</b> A mastic scrape shall be performed after removing base on all areas except for those cleared by the District Project Manager.</p>	04/05/2021