

Questions & Answers - 3

Project 21-210-001 - HVAC Replacement Project Professional Design Services Blevins MS
Buying Organization Poudre School District

| No | Question/Answer | Question Date |
|-----|---|---------------|
| Q24 | <p>Question: hydronic coils</p> <p>No existing hydronic system such as Boilers, pumps, distribution piping, and appurtenances are not a part of this scope. The hydronic HVAC piping modifications scope will be narrowed down to the re-connecting new hydronic coils to the existing hydronic coils, correct?</p> <p>Answer: The installation of new hydronic coils will be required.</p> | 10/13/2020 |