



## **POUDRE SCHOOL DISTRICT R-1**

**IFB #21-700-001**

### **FIRE ALARM REPLACEMENT PROJECTS**

#### **Addendum 3.0**

**ADDENDUM POSTING DATE:** Friday, November 13, 2020

**IFB CLOSING DATE:** Tuesday, November 17, 2020, 2:00 p.m. MST

---

**The following additions, deletions, clarifications and/or changes are hereby made to the above referenced IFB:**

#### **Fire Alarm Plans:**

1. Add clarification to section 3 of the scope of work, “Updated graphic map shall match field signage.”
2. Add clarification to section 6 of the scope of work, “Updated record drawings shall match field signage.”
3. Add to section 4 of the alternates:

##### Carbon monoxide locations:

- CLPM (4): Facilities Plumbing (next to Kitchen 122A), Kitchen 122A, Athletics Gym, 154 West Locker Room, below Theatre Stage 137, Modular Building Furnace Closets (2)
- FCHS (2): Room B06, Kitchen A28
- LMS (2): Facilities Mechanical 111, Kitchen 102
- PHS (2): Facilities Plumbing (lower level), Kitchen, Modular Building Furnace Closets (6)
- RMHS (3): Facilities Plumbing 117, Facilities Mechanical 419A, Kitchen 122A
- TES (3): Facilities Boiler 601, Kitchen 416, Room 405

- WMS (2): Facilities Plumbing E14A, Kitchen E12A, Modular Building Furnace Closets (1)

**Bosch Clarification:**

1. Telephone line from the Bosch communicator to the FACP shall be installed in conduit. Installation manual guidelines attached.

**Attachments:**

1. 2020.11.11-PSD7Schools\_FireAlarmReplacement\_Add3\_Plans (1 page)
2. B465\_IOG\_Contractor Installation\_Manual (1 page)
3. Existing carbon monoxide location maps (8 pages)