

Questions & Answers - 1

Solicitation 21-700-004 - Early Childhood Restroom Projects
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Putnam Bathroom What is the wall that we are to demo - cmu? Steel Studs?</p> <p>Answer: The wall in question is a partition wall built to the ceiling grid. Not CMU.</p>	04/21/2021
Q2	<p>Question: All Classrooms Is fire alarm included in the contractors bid?</p> <p>Answer: The fire alarm notification device is not in the contractor scope, only the provided J-box and conduit. The fire sprinkler head relocation will be in the scope of the contractor-where applicable.</p>	04/21/2021
Q3	<p>Question: All Classrooms Locking wall cabinet - is their a spec or detail as to what you want?</p> <p>Answer: Wooden construction with clear finish and rounded edges/corners for safety. Two (2) lockable doors with 1-2 shelves. Size: 3' W X 2' H X 12" D</p>	04/21/2021
Q4	<p>Question: Loral Bathroom Is the alternate 4x12 ceramic tile?</p> <p>Answer: Ceramic tile is the alternate to the base bid</p>	04/21/2021
Q5	<p>Question: General Terms 2.16 subcontractor info due at time of bid?</p> <p>Answer: Please indicate any use of subcontractors and the type of work to be performed with the bid. It will be sufficient for the awarded Supplier to provide the subcontractor's name, address, phone number and three (3) client references before work begins.</p>	04/21/2021
Q6	<p>Question: Harris Bathroom does it get a new frame door + hardware?</p> <p>Answer: Yes, a complete new door with hardware to match</p>	04/21/2021
Q7	<p>Question: Demo Plans The demo plans for Putnam, Bennett and Kruse do not have a scale for the amount of saw cutting required for the waste line. Please provide a drawings with a scale to determine the correct amount of saw cutting for underground plumbing.</p> <p>Answer: (This question was retracted.)</p>	04/21/2021
Q8	<p>Question: Changing Table Please provide cut sheets for Proteam Model 4075 Changing Table.</p> <p>Answer: Cut sheets for this changing table can be found online.</p>	04/21/2021

No	Question/Answer	Question Date
Q9	<p>Question: Fire Sprinkler Please confirm which schools are sprinkled in the work area.</p> <p>Answer: Laurel, Kruse, and Harris are sprinklered buildings. Bennett and Putnam are not sprinklered buildings.</p>	04/21/2021
Q10	<p>Question: Locking Cabinet Please provide specification such as dimensions, number of shelves required, etc. on required locking cabinet above changing table.</p> <p>Answer: Please see the response to Q3.</p>	04/21/2021