- 1. Tandus only
 - A. Provide a certification of compliance with the Carpet and Rug Institute's Green Label Plus Indoor Air Quality program for carpets, cushions, and adhesives
- 2. Poudre School District approved colors only (HOPSCOTCH 17201)
- 3. INSTALLER Certified by Tandus and have a minimum of five years experience on installations of similar size and complexity for all projects. Currently Approved Contractors:

Accessories:

- A. Sub-Floor Filler: 40 pounds Fix-a-Crete plus 5 gallons WFT606 latex and white silica sand, "Webcrete", "LevelCure", or Approved Equal. Use correct product for specific application thickness (to 1/8 inch and 1/8 inch to 1/2 inch).
- B. Direct Glue Down Adhesive: Recommended by carpet manufacturer.
- C. Adhesive for Carpet Mounted as Base: discouraged.
- D. Transition Moldings and Floor Edge Strips: Western Trade Supply (970-226-6933) Part No. CM304 HMF (2 inch width) by Futura. (No substitutions).
- E. Seam Adhesive: Recommended by carpet manufacturer.
- F. Contact Adhesive: Compatible with carpet material as recommended by carpet manufacturer releasable type.
- E. Primer:
 - 1. C-36: New Floors
 - 2. C-46: Old Concrete

BASE

- 1. FS SS-W-40 Rubber; top set coved:
 - A. R.C. Musson Rubber Company.
 - B. Roppe Rubber Corporation.
 - C. Burke Industries.
 - D. Johnsonite.
 - E. Approved Equal.
- 2. Height: 4 inch; 4.5 inch preferred. 6 inch if needed. 18 inch tile not allowed.
- 3. Thickness: 0.125 thick.
- 4. Finish: Matte.
- 5. Length: 4 foot sections.
- 6. Colors: black is preferred.
- 7. 1/8 inch thickness x 4 inches high.
- 8. 6 inch high base required in all toilets. Scribed internal corners.
- 9. Use topset cove base at all resilient flooring and carpeted locations.
- 10. Use solid rubber Roppe base. No vinyl base allowed.
- 11. All floor applications shall include a cove base monolithic with the floor, rubber preferred.
- 12. Carpet base considered at certain locations.
- 13. INSTALLATION
 - A. Fit joints tight, straight and vertical. Maintain minimum measurement of 1 foot 6 inches between joints.
 - B. Miter internal corners. External corners shall be job formed no joints within 2 feet of corner edge.
 - C. Install base on solid backing. Bond tight to wall and floor surfaces.
 - D. Scribe and fit to protruding door frames and other interruptions.

- E. Set cove in sealant to seal joint watertight at linoleum flooring in toilet rooms, and other sanitary conditions.
- F. Adhesive for base shall be a type not affected by heat.

ENTRY MATS – LOCATIONS: Vestibules, exterior entries

- 1. Tandus only
- 2. Color: HOPSCOTCH 17201
- 3. Secure with factory applied adhesive.

ACCESSORIES

- 1. Moisture Barrier: "Top Coat II, 7055" by Installers Best Adhesives, 877-784-2248.
- 2. Provide waterproof primers and adhesives as recommended by the manufacturer of the material being installed o suit material and substrate conditions. Use solvent free type.
- 3. Adhesive to be moisture resistant material suitable for installation over slab on grade.
- 4. Floor Filler: 40 pounds "Fix-a-Crete" plus 5 gallons WFT606 latex and white silica sand, "Webcrete", "Level Cure", or Approved Equal. Use correct product for specific application thickness (to 1/8 inch and 1/8 inch to 1/2 inch).
- 5. Roppe #47 square cove cap at wallcovering sisal edges.
- 6. Fillers for Coved Sheet Goods at Floor/Wall Intersection: plastic.
- 7. Sealant at Cove Base: Single component polysulfide.
- 8. Transition Edging for new tile to new carpet is required.
 - A. (970) 226-6933, Part No. CM304 HMF, 2 inch width by Futura. No Substitutions, a) No rubber or vinyl transitions, use Roppe #159 transition if needed.
- 9. Concrete Slab Primer: Non-staining type as recommended by flooring manufacturer.
- 10. Leveling Compound: Latex type which can be feather edged, as recommended by flooring manufacturer, trowelable consistency for tapering where required.
- 11. Provide sealer over Subfloors

END OF SECTION 09 60 00

Finishes 17