

Questions & Answers - 1

Solicitation

22-340-001 - Fort Collins High School Gymnasium Sound System

Buying Organization

Poudre School District

| No | Question/Answer | Question Date |
|----|---|---------------|
| Q1 | <p>Question: Blueprints Request Can you provide us with blueprints of the gymnasium for us to do a sound prediction analysis?</p> <p>Answer: Drawings provided by email.</p> | 02/28/2022 |
| Q2 | <p>Question: Wireless Microphones Are you looking to have 2 channels of hand help wireless microphone and 2 channels of lavalier with body packs?</p> <p>Answer: Yes, two channels of hand help wireless microphone and two channels of lavalier with body packs are requested.</p> | 03/02/2022 |
| Q3 | <p>Question: Fire Alarm Interrupt Is the contractor responsible to run signal cable for fire alarm interrupt?</p> <p>Answer: Yes, the contractor is responsible to run signal cable for fire alarm interrupt.</p> | 03/02/2022 |
| Q4 | <p>Question: Intercom Interrupt Is contractor responsible to run cable for intercom interrupt?</p> <p>Answer: Yes, the contractor is responsible to run cable for intercom interrupt.</p> | 03/02/2022 |
| Q5 | <p>Question: Tablet Control Is tablet/iPad control of audio system desired in addition to the requested touch screen control in rack?</p> <p>Answer: Yes, a tablet / iPad control of the audio system is requested in addition to the touch-screen control in the rack.</p> | 03/02/2022 |
| Q6 | <p>Question: Equipment Availability If equipment is not able to be delivered this summer what is the plan for installation? Can it take place during the school year or does it need to happen over a school break?</p> <p>Answer: Installation will be scheduled during a school break. The next available slots would be the week of Thanksgiving and the winter holiday break.</p> | 03/02/2022 |
| Q7 | <p>Question: Drawing Request What is the process for requesting construction drawings of the gym? Thank you.</p> <p>Answer: Drawings provided by email.</p> | 03/02/2022 |