Questions & Answers - 1

Solicitation Buying Organization		22-700-002 - Boiler System Replacement Design Services Poudre School District		
No	Question/Answer			Question Date
Q1	Question: Response Format In addition to completing the 8.0 References, 9.0 Bid Certification Form and 10.0 Bid Form listed in the IFB are any other forms, certificates or qualifications information required or desired to be submitted? If so, please outline the format and content to be submitted and the associated scoring criteria. Answer: No additional information needed.		01/12/2022	
Q2	required by the project required number of d district review/comment meeting and other re required (quantity of a construction services Answer: SD/DD, CD	actor shall also provide all necessary design and construction p t.". To facilitate bidding and understanding of project scope, pl esign submissions (i.e. SD, DD, CD, permit) and which submitt nt. Provide scope of bidding support required (i.e. attendance juired services). Also provide a summary of construction phase ite observations, frequency of OAC meeting attendance, and a s, CA - including (2) design meetings per site, pre-bid meetings and RFIs, shop drawing review, OAC meetings, (3) construction	lease provide the tals will under go at contractor pre-bid e support services any other required s, respond to	01/12/2022
Q3	-	ion Budget construction? Provide construction budget for each school. get is estimated at \$600,000.00.		01/12/2022
Q4	the bids include the c Answer: See paragra	ontractor sections in the IFB that seem to be directed towards a general ost of a general contractor or strictly consultant design? ph one on page three. "Contractor" is the term used to replac rofessionals. The party that would be contracted with. This w	e the professional	01/13/2022
Q5	applies for this IFB.	Requirement m that the Professional Liability for Sub-Consultants is the only urance requirements listed in the IFB.	y Insurance that	01/13/2022
Q6	Question: Profession Please clarify the Pro- limits listed in the IFB	essional Liability Insurance limits required to bid this project as	s there are multiple	01/13/2022

Answer: See answer to Q5.

No	Question/Answer	Question Date			
Q7	Question: Pump VFD's Addendum 1 states to replace VFD's. Only observed pump VFD's at Webber MS. Are we to add pump VFD's for the systems pumps at Bacon ES and Shepardson ES?	01/13/2022			
	Answer: Replace VFDs at Webber only.				
Q8	Question: Glycol Feeder Please clarify we are to add a glycol feeder tied to the building automation at all three schools.	01/13/2022			
	Answer: Add glycol feeders tied to building automation at all three (3) sites.				