



POUDRE SCHOOL DISTRICT

Poudre School District

**Boiler System Replacement,
Multiple Buildings, Phase 1 of 1**

Permit Set

Presented by:



March 15, 2022

**Table of Contents
Poudre School District
Boiler System Replacement
Permit Set Specifications**

IMEG Project #22000573.00

DIVISION 1 - GENERAL REQUIREMENTS

01 11 00	SUMMARY OF WORK
01 21 00	ALLOWANCES
01 23 00	ALTERNATES AND ALTERNATIVES
01 31 19	PROJECT MEETINGS
01 50 00	CONSTRUCTION FACILITIES & TEMPORARY CONTROLS
01 75 00	STARTING AND ADJUSTING
01 77 00	CONTRACT CLOSEOUT
01 78 23	OPERATION AND MAINTENANCE MANUALS

DIVISION 2 THRU 10 - NOT USED

DIVISION 22 - PLUMBING

22 05 00	- BASIC PLUMBING REQUIREMENTS
22 05 03	- THROUGH PENETRATION FIRESTOPPING
22 05 05	- PLUMBING DEMOLITION FOR REMODELING
22 05 29	- PLUMBING SUPPORTS AND ANCHORS
22 05 53	- PLUMBING IDENTIFICATION
22 10 23	- NATURAL GAS AND PROPANE PIPING

DIVISION 23 - MECHANICAL

23 05 00	- BASIC HVAC REQUIREMENTS
23 05 03	- THROUGH PENETRATION FIRESTOPPING
23 05 05	- HVAC DEMOLITION FOR REMODELING
23 05 13	- MOTORS
23 05 29	- HVAC SUPPORTS AND ANCHORS
23 05 48	- HVAC VIBRATION ISOLATION
23 05 53	- HVAC IDENTIFICATION
23 05 93	- TESTING, ADJUSTING, AND BALANCING
23 07 19	- HVAC PIPING INSULATION
23 09 00	- CONTROLS
23 09 13	- INSTRUMENTATION
23 21 00	- HYDRONIC PIPING
23 21 16	- HYDRONIC SPECIALTIES
23 21 23	- HVAC PUMPS
23 52 16	- CONDENSING BOILERS

DIVISION 26 - ELECTRICAL

26 05 00	- BASIC ELECTRICAL REQUIREMENTS
26 05 03	- THROUGH PENETRATION FIRESTOPPING
26 05 05	- ELECTRICAL DEMOLITION FOR REMODELING

26 05 13 - WIRE AND CABLE
26 05 26 - GROUNDING AND BONDING
26 05 27 - SUPPORTING DEVICES
26 05 33 - CONDUIT AND BOXES
26 05 42 - EQUIPMENT WIRING SYSTEMS
26 05 53 - ELECTRICAL IDENTIFICATION
26 22 00 - DRY TYPE TRANSFORMERS
26 24 16 - PANELBOARDS
26 27 16 - CABINETS AND ENCLOSURES
26 27 26 - WIRING DEVICES
26 28 13 - FUSES
26 28 16 - DISCONNECT SWITCHES

END TABLE OF CONTENTS

SECTION 01 11 00 - SUMMARY OF WORK

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work covers replacement of the boilers at Webber Middle School, Bacon Elementary School and the addition of a boiler at Shepardson Elementary School.

1.2 CONTRACTS

- A. Project shall be constructed under a multiple contract(s) that shall include the General, HVAC, Piping and Plumbing, and Electrical work.

1.3 WORK OF CONTRACTORS

- A. In addition to fulfilling Contract Requirements, Contractor shall fulfill the requirements of all drawings, specifications, and the requirements of the General Conditions, Supplementary Conditions, and Division 1, General Requirements, all of which are hereby made a part of each division and section of the project specifications.
- B. Contractor shall provide work and/or services as may be specified in all the respective specification sections and/or indicated on the drawings for all divisions of work. Contractor shall review specification sections and drawings for all divisions of work to determine extent of work and/or services each section requires for other divisions as well as its own division of work.

1.4 WORK BY OWNER

- A. Items not in contract: N/A
- B. Owner to remove and/or retain: N/A

1.5 OWNER SUPPLIED PRODUCTS

- A. Owner's responsibilities: N/A

1.6 CONTRACTOR'S USE OF SITE

- A. Access: Coordinate with owner for specific access at each building.
- B. Time restrictions for performing work: Coordinate with owner for specific restrictions at each building.
- C. Utility outage and shutdown: Contractor shall coordinate any and all utility outage and shutdowns with Owner.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 11 00

SECTION 01 21 00 - ALLOWANCES

PART 1 - GENERAL

1.1 DESCRIPTION OF REQUIREMENTS

A. Types of allowances scheduled herein for the work include the following:

1. Contingency Allowance in accordance with the following paragraph:

- a. Contingency allowance shall be used only as directed for Owner's purposes, and only by change orders that designate amounts to be charged to contingency allowance. Contractor's related costs are not included in the Contract Sum (other than allowance itself) for work so ordered to be charged to contingency allowance. The change orders will include costs and allowable overhead/profit margins. At time of project closeout, unused amounts remaining in contingency allowance shall be credited to Owner by change order.

PART 2 - PRODUCTS (Pre-ordered items assigned to Contractor)

PART 3 - EXECUTION

3.1 SCHEDULE OF ALLOWANCES

A. Contingency Allowances to be included in General Contractor's Base Bid:

1. The General Contractor shall include a contingency allowance in the amount of \$15,000 to cover costs of any additional work ordered for each project.

END OF SECTION 01 21 00

SECTION 01 23 00 - ALTERNATES/ALTERNATIVES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of Contract, including General and Supplementary Conditions and other Division 1 specification sections, apply to this section.

1.2 SUMMARY

- A. This section specifies administrative and procedural requirements for alternates.
- B. Definition: An alternate is an amount proposed by Bidders and stated on the Bid Form for certain construction activities defined in the Bidding Requirements that may be added to or deducted from the Base Bid amount if the Owner decides to accept a corresponding change in either the amount of construction to be completed, or in the product, material, equipment, systems, or installation methods described in the Contract Documents.
- C. Coordination: Coordinate related work and modify or adjust adjacent work as necessary to ensure that work affected by each accepted alternate is complete and fully integrated into the project.
- D. Notification: Immediately following the award of the Contract, prepare and distribute to each party involved, notification of the status of each Alternate. Indicate whether Alternates have been accepted, rejected or deferred for consideration at a later date. Include a complete description of negotiated modifications to Alternates.
- E. Schedule: A "Schedule of Alternates" is included under Part 3 of this Section. Specification sections referenced in the Schedule contain requirements for materials and methods necessary to achieve the work described under each Alternate.
 - 1. Include as part of each Alternate, miscellaneous devices, accessory objects, and similar items incidental to or required for a complete installation, whether or not mentioned as part of the alternate.

PART 2 - PRODUCTS (Note Used)

PART 3 - EXECUTION

3.1 SCHEDULE OF ALTERNATES

- A. Alternate Bid No. 1: Replacement of heating water pumps at Shepardson Elementary School.

END OF SECTION 01 23 00

SECTION 01 31 19 - PROJECT MEETINGS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and other Division 1 specification sections apply to this section.

1.2 SUMMARY

- A. This section specifies administrative and procedural requirements for project meetings including but not limited to:
 - 1. Preconstruction conference.
 - 2. Coordination meetings.
 - 3. Progress meetings.
 - 4. Construction schedule.

1.3 PRECONSTRUCTION CONFERENCE

- A. Architect will schedule a preconstruction conference and organizational meeting at the project site or other convenient location no later than 15 days after execution of the Agreement between Owner and Contractor and prior to commencement of construction activities. Architect will conduct the meeting to review responsibilities and personnel assignments.
- B. Attendees: The Owner, Engineer, Contractor and superintendent, major subcontractors, manufacturers, suppliers, and other concerned parties shall each be represented at the conference by persons familiar with and authorized to conclude matters relating to the work.
- C. Agenda: Discuss items of significance that could affect progress, including such topics as:
 - 1. Tentative construction schedule.
 - 2. Critical work sequencing.
 - 3. Designation of responsible personnel.
 - 4. Procedures for processing field decisions and Change Orders.
 - 5. Procedures for processing Applications for Payment.
 - 6. Distribution of Contract Documents.
 - 7. Submittal of shop drawings, product data, and samples.
 - 8. Preparation of record documents.
 - 9. Use of the premises.
 - 10. Office, work and storage areas.
 - 11. Equipment deliveries and priorities.
 - 12. Housekeeping.
- D. Contractor will record and issue preconstruction conference meeting minutes.

1.4 COORDINATION MEETINGS

- A. Contractor shall conduct project coordination meetings on an as-needed basis convenient for all parties involved. Project coordination meetings are in addition to specific meetings held for other purposes, such as regular progress meetings and special pre-installation meetings.
- B. Contractor shall request representation at each meeting by every party currently involved in coordination or planning for the construction activities involved.

1.5 CONSTRUCTION PROGRESS MEETINGS

- A. Contractor shall conduct construction progress meetings at the project site at intervals convenient for all parties involved. The meetings for the duration of the project will be regularly scheduled at the pre-construction conference.
- B. Attendees: In addition to representatives of the Owner and Engineer, each Subcontractor, supplier or other entity concerned with current progress or involved in planning, coordination, or performance of future activities shall be represented at these meetings by persons familiar with the project and authorized to conclude matters relating to progress.
- C. Contractor's Construction Schedule: Review progress since the last meeting. Determine where each activity is in relation to the Contractor's Construction Schedule, whether on time, ahead of, or behind schedule. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss whether schedule revisions are required to ensure that current and subsequent activities will be completed within the contract time.
- D. Review the present and future needs of each entity present, including such items as:
 - 1. Interface requirements
 - 2. Time
 - 3. Sequences
 - 4. Deliveries
 - 5. Off-site fabrication problems
 - 6. Access
 - 7. Site utilization
 - 8. Temporary facilities and services
 - 9. Hours of work
 - 10. Hazards and risks
 - 11. Housekeeping
 - 12. Quality and work standards
 - 13. Change orders
 - 14. Documentation of information for payment requests
- E. Contractor shall record and issue meeting minutes for all construction progress meetings to all attendees and parties involved.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 31 19

SECTION 01 50 00 - CONSTRUCTION FACILITIES & TEMPORARY CONTROLS

PART 1 - GENERAL

1.1 JOB CONDITIONS AND WORK SEQUENCE

- A. Contractor(s), Subcontractor(s), and Material Supplier(s) shall inform themselves as to conditions relating to the execution of work. Neglect of this requirement will not be accepted as cause for additional compensation and/or additional time for completion.
- B. Existing building will remain in operation during construction. Contractor shall schedule work in consultation with the Owner so there will be no interruption of existing building operations.

1.2 SITE EXAMINATION

- A. The Contractor shall take all measurements related to the existing building as required for the new work and to locate existing utilities. Contractor shall contact the City, Owner, and all utilities to carefully review all records of exposed, concealed, and buried points of connections, as to location, size, type, depth, operating characteristics, etc., including but not limited to, electrical service, telephone service, and water, gas, and sewer lines.

1.3 CLEANING

- A. General Cleaning: The Contractor and each Subcontractor shall remove rubbish and debris from the building site promptly as it accumulates but, in any case, not less frequently than each Friday afternoon. The Contractor shall perform an overall cleanup of the entire site including a broom cleaning of all appropriate surfaces as required but, in any case, not less frequently than each Friday afternoon.
- B. No burning of rubbish or debris will be allowed at site, nor shall rubbish at any time be thrown from structure. No debris shall be buried at the site. Do not dispose of wastes into streams or waterways.
- C. All dumpsters used on the project site shall have lids or canvas covers securely fastened to prevent debris from blowing about site.
- D. Keep streets and public roadways clean of dirt and mud tracked onto such surfaces by vehicles or equipment used or parked on construction site.

1.4 PROTECTION

- A. The Contractor shall:
 - 1. Provide, and maintain fences, planking, guard lights, barricades, warning signs, and guards as necessary for protection of material storage, curbs, sidewalks, streets, drives, and adjoining property, public, and new building. Use caution at all times to protect persons against injury resulting from job operations, movement of materials, and standing equipment.

2. Notify in writing, the Owners of corporate or private property that interferes with work and arrange with them for disposition of such property.
 3. Protect building from damage at all times from rain water, ground water, backing up of drains or sewers and other water. Provide pumps, equipment, and enclosures to provide this protection.
- B. Each Contractor and Subcontractor shall protect own materials, work, and equipment not normally covered by above protection; protect work of other trades, adjust damage when performing work; protect work outside of building lines such as trenches and excavations, as specified above; when performing work, maintain protection provided above. Contractor causing damage to any work shall repair or replace damaged work at Contractor's expense.
- C. Work outside of property line shall be repaired in accordance with requirements of authority having jurisdiction.
- D. Provide temporary dust barriers as required to protect existing areas during work of the contract.

1.5 TEMPORARY OFFICES/TRAILERS, EQUIPMENT AND SHEDS

- A. Offices/Trailers: The Contractor shall provide and maintain temporary watertight office of suitable size for use by Contractor, Subcontractors, and Architect. Contractor's space shall be as required for general use and to provide space and furnishings for project meetings. Telephone service in this office, local and long distance, shall be paid for by the Contractor. Location of office/trailer shall be approved by the Owner.
- B. Equipment: The Contractor shall provide and maintain a plain paper copier, telephone, and fax machine in the office for use by the Architect for job related business. The operating cost of all electronic equipment shall be paid for by the Contractor.
- C. Sheds: The Contractor and each Subcontractor shall provide sheds for storing tools and materials. Storage sheds shall be watertight and storm proof, and shall have floors raised above ground. The Contractor and each Subcontractor will be held responsible for water or storm damage to stored tools or materials.

1.6 FIRE PROTECTION

- A. During the construction period, the Contractor shall provide and maintain adequate fire protection per requirements of jurisdictional authorities, for the construction site, for each floor of the building, and for Contractor's temporary offices.
- B. In addition, each Subcontractor who maintains enclosed shed on premises for storage of materials or as workshop, or for convenience of workers, shall provide and maintain fire protection in each shed.

1.7 MANUFACTURER'S DIRECTIONS

- A. The Contractor shall apply, install, connect, erect, use, clean, and condition manufactured articles, materials, and equipment as directed by manufacturer unless specified to contrary.

1.8 CUTTING AND PATCHING

- A. Cutting and patching requirements specified herein, apply to all sections and divisions of the specifications, and all drawings covering demolition, remodeling, and new construction work to be performed by the Contractor and Mechanical and Electrical Subcontractors.
- B. All on site welding shall conform to the requirements and techniques of FM Global Engineering Division.
- C. Portions of the existing structure where existing work is to be demolished or removed, and where new work is to be done, connections made, materials handled, or equipment moved and relocated, shall be temporarily protected. Temporary protection shall be such that the interior of existing structure will at all times be protected from dust and weather inclemency and interior heat and/or air conditioning conserved. Temporary openings in exterior walls shall be protected by temporary weatherproof closures. Contractor will be held responsible for any damage to the existing structure or contents due to the insufficiency of such protection.
- D. Cutting and Patching Requirements:
 - 1. Where new work connects with present building and where remodeling of existing work occurs, the Contractor shall do all cutting, notching, keying, removal and trimming of existing construction required to make connections between the new and the old work and shall do all patching, repairing or refinishing of cut and immediately adjacent surfaces to provide a finish in conformance with industry standards and appropriate to finish materials intended to be used.
 - 2. Holes through existing floors, walls, and roofs for Mechanical and Electrical work shall be cut, patched, sealed, fire proofed, and flashed by the trade requiring the opening.
 - 3. Before breaking of surfaces, cut primary saw-cut 1" to 1-1/2" deep around areas where portions of work will be removed. Lines shall be straight.
 - 4. Materials and workmanship employed in patching, repairing, or refinishing existing surfaces and/or involving new construction shall conform to that of original work, unless otherwise shown or specified.
 - 5. Clean existing surfaces remaining exposed as a result of demolition work and/or new construction. Clean entire wall faces, floor surfaces, column faces, etc., using sandblasting, wire brushing, or carborundum wheel. Where dovetail or other insert slots are exposed, they shall be filled with grout.
- E. Keep property adjacent to buildings clean and free from accumulation of rubbish. Remove excess debris resulting from demolition operations, as it accumulates.
- F. Walls, floors, etc., required to carry the excess weight of stored materials and equipment during demolition, removal and remodeling work, or which will be subjected to undue pressure from waste material, shall be shored or braced to withstand these excess loads.

1.9 CODE REQUIREMENTS

- A. The Contractor shall conform to all requirements of local, state, and national codes, laws, ordinances, and utility company requirements and other regulations having jurisdiction over this installation.

- B. If there is a discrepancy between the codes and regulations having jurisdiction over this installation and these specifications, the codes and regulations shall determine the method of the Work.
- C. If the Contractor notes, at the time of bidding, any parts of the drawings and specifications that are not in accord with the applicable codes or regulations, Contractor shall inform the Architect in writing, requesting a clarification. If there is insufficient time to allow this procedure, Contractor shall submit, with proposal, a separate price required to make the system shown on the drawings comply with the codes and regulations.
- D. All changes to the system made after the letting of the contract in order to comply with the applicable codes or requirements of the Inspector, shall be made by Contractor without cost to the Owner.

1.10 PROGRESS SCHEDULE

- A. Immediately after being awarded the contract, the Contractor shall prepare an estimated Progress Schedule and submit same for the Architect's approval. It shall indicate the dates for the starting and completion of the various stages of construction.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 50 00

SECTION 01 75 00 - STARTING AND ADJUSTING

PART 1 - GENERAL

1.1 DESCRIPTION OF REQUIREMENTS

- A. **<Enter Description of Requirements>**

1.2 STARTING SYSTEMS

- A. Coordinate schedule for startup of various equipment and systems suppliers.
- B. Notify Engineer, Owner, and Equipment/Systems Representative, seven (7) days prior to startup of each item or system.
- C. Verify that each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, or for other conditions that may cause damage.
- D. Verify that tests, meter readings, and specified electrical characteristics agree with those required by the equipment or system manufacturer.
- E. Verify wiring and support components for equipment are complete and tested.
- F. Execute startup under supervision of applicable manufacturer's representative in accordance with manufacturer's instructions.
- G. When specified in Divisions 22, 23 or Division 26, require manufacturer to provide authorized representative to be present at site to inspect, check, and approve equipment or system installation prior to startup, and to supervise placing equipment or system in operation.
- H. Submit a written report that equipment or system has been properly installed and is functioning correctly.

1.3 DEMONSTRATION AND INSTRUCTIONS

- A. Demonstrate operation and maintenance of products to Owner's personnel prior to date of Substantial Completion.
- B. Contractor and System Representative to demonstrate project equipment operations and provide instructions by a qualified manufacturer's representative who is knowledgeable about the product and/or system. Instructions to be of adequate length for Owner to understand and be able to operate and maintain the product and/or systems.
- C. For equipment or systems requiring seasonal operation, perform demonstration for other season shall be given at the start of the season.
- D. Utilize operation and maintenance manuals as basis for instruction. Review contents of manual with Owner's personnel in detail to explain all aspects of operation and maintenance.

- E. Demonstrate startup, operation, control, adjustment, troubleshooting, servicing, maintenance, and shutdown of each item of equipment at agreed time with Owner.
- F. Prepare and insert additional data in operations and maintenance manuals when need for additional data becomes apparent during instruction.
- G. Specify the amount of time required for instruction on each item of equipment and system that is specified in Divisions 22, 23 and Division 26.

1.4 TESTING, ADJUSTING, AND BALANCING

- A. The Contractor will perform services specified in Divisions 21, 22, and 23 and Division 26.
- B. Reports will be submitted by the testing and balancing firm to the Engineer indicating observations and results of the tests and indicating compliance or non-compliance with the requirements of the Contract Documents. Non-compliance items will be corrected by the Contractor immediately and the testing and balancing shall be performed again to verify that the corrective action was taken.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 75 00

SECTION 01 77 00 - CONTRACT CLOSEOUT

PART 1 - GENERAL

1.1 CLOSEOUT PROCEDURES

- A. Submit written certification that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with Contract Documents and ready for Architect's review, normally referred to as "final punch list."
- B. Provide submittals to Architect that are called for in other specification sections.
- C. Submit final Application for Payment identifying total adjusted Contract Sum, previous payments, and remaining sum due.

1.2 FINAL CLEANING

- A. The Contractor and each Subcontractor shall perform thorough cleaning, sweeping, washing, and polishing of the entire new structure and site. The Contractor and each Subcontractor shall remove from work and equipment, provided under their respective divisions of work, all foreign matter, spots, and soil so as to put all such work and equipment, including finishes, in a complete and finished condition to the satisfaction of the Architect.
 - 1. Cleaning shall include removal of foreign matter from all drains, exterior and interior.
 - 2. Clean debris from roofs, gutters, downspouts, and drainage systems.
 - 3. Clean and sweep all paved areas; rake clean all landscaped areas.
- B. Initial protection of aluminum will be provided by Subcontractor providing work. Maintenance and any additional protection and repair work required shall be the responsibility of Contractor who shall have damaged work refinished where possible or replaced where required.
- C. Immediately prior to the occupancy of this project or parts thereof, the Contractor shall have all glass cleaned by a professional window washing contractor. Work shall include the removal of labels, paint spattering, excess glazing sealant, etc. Surfaces shall include mirrors, both sides of all glass in windows, borrowed lights, partitions, and doors.
- D. Upon completion of the work, the Contractor and each Subcontractor shall remove and dispose of all equipment, unused materials, waste, and construction facilities provided for the Contractor's work.
- E. After all outside cleanup work has been completed, interior cleanup shall be completed as follows:
 - 1. Subcontractor for plumbing work shall wash and leave free of stains and dust, all fixtures, and all piping, etc. This Contractor shall also clean all faucet aerators.
 - 2. Subcontractor for heating work shall wash and leave clean all radiation covers, etc. Vacuum clean all air handling units, unit ventilators, unit heaters, and finned radiation, inside and out, cap, replace all filters with new filters if units have been used for temporary heating, and clean all motors.

3. Subcontractor for electrical work shall wash and clean all plates on switches and receptacles, light fixture lenses and trim reflectors, etc., and vacuum clean all panels (inside), etc.
4. The Contractor shall, after the above work has been done, completely vacuum all floors and walls, dust and clean all cabinet and wall materials, exposed steel and wood, clean all glass and scrub and clean all floors.
5. If Contractor does not remove rubbish or clean building as specified above, Owner reserves the right to have work done by others at Contractor's expense. If Subcontractors fail to perform their cleaning, the Contractor shall perform such work at the offending Subcontractor's expense.

1.3 ADJUSTING

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.

1.4 PROJECT RECORD DOCUMENTS

- A. Maintain one set of drawings with changes marked on record documents on site; record actual revisions to the work and turn over the following to the Architect:
 1. Drawings.
 2. Specifications.
 3. Addenda.
 4. Change orders and other modifications to the Contract.
 5. Reviewed shop drawings, product data, and samples.
 6. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.
- E. Specifications: Legibly mark and record at each Product Section description of actual products installed, including the following:
 1. Manufacturer's name and product model and number.
 2. Product substitutions or alternates utilized.
 3. Changes made by Addenda and modifications.
- F. Record Documents and Shop Drawings: Legibly mark each item to record actual construction including:
 1. Measured depths of foundations in relation to finish main floor datum.
 2. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 3. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 4. Field changes of dimension and detail.
 5. Details not on original Contract drawings.

- G. Submit documents to Engineer with claim for final Application for Payment.

1.5 OPERATION AND MAINTENANCE INSTRUCTIONS

- A. Submit three properly indexed copies of the Operations and Maintenance Instructions to the Engineer. Make all corrections or additions required.
- B. Operation and Maintenance Instructions shall include:
 - 1. Cover with printed title "Operation and Maintenance Instructions", title of project and subject matter are required.
 - 2. Title page with project title, Architect, Contractor and Subcontractors, with addresses, telephone numbers, and contacts.
 - 3. Table of Contents describing all index tabs.
 - 4. Listing of all Subcontractors and major equipment suppliers with addresses, telephone numbers, and contacts.
 - 5. Index tabs dividing information by specification section, major equipment, or systems. All tab titling shall be clearly printed under reinforced plastic tabs.
 - 6. Copies of warranties.
 - 7. Copies of all final approved shop drawings and submittals.
 - 8. Copies of all factory inspections and/or equipment start-up reports.

1.6 WARRANTIES

- A. Provide duplicate notarized copies.
- B. Execute and assemble transferable warranty documents from Subcontractors, suppliers, and manufacturers.
- C. Provide table of contents and assemble in three-ring binder with durable plastic cover.
- D. Submit prior to final Application for Payment.
- E. For items of work delayed beyond date of Substantial Completion, provide updated submittal within 15 days after acceptance, listing date of acceptance as start of warranty period.

1.7 SPARE PARTS AND MAINTENANCE MATERIALS

- A. Provide products, spare parts, maintenance and extra materials in quantities specified in individual specification sections.
- B. Deliver to project site; obtain receipt prior to final payment.

1.8 RECORD DRAWINGS

- A. At completion of work and prior to final payment, the Contractor and each Subcontractor shall provide the Architect with a complete, accurate, clean, and legible set of record drawings that indicate exact location of all material items recorded on a day to day basis during the construction period.

1.9 GUARANTEES AND WARRANTIES

- A. The Contractor shall deliver all guarantees and warranties to the Owner prior to final completion.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION 01 77 00

SECTION 01 78 23 - OPERATIONS AND MAINTENANCE MANUALS

PART 1 - GENERAL

1.1 SUMMARY

- A. Description of Work: This Section includes administrative and procedural requirements for preparing operation and maintenance manuals, including the following:
 - 1. Maintenance manuals for the care and maintenance of products, materials, and finishes, and systems and equipment.

1.2 DEFINITIONS

- A. System: An organized collection of parts, equipment, or subsystems united by regular interaction.
- B. Subsystem: A portion of a system with characteristics similar to a system.

1.3 SUBMISSION OF MANUALS

- A. Initial Submittal: Submit two draft copies of each manual at least 15 days before requesting inspection for Substantial Completion. Include a complete operation and maintenance directory. Architect/Engineer will return one copy of draft and mark whether general scope and content of manual are acceptable.
- B. Final Submittal: Submit one copy of each manual in final form at least 15 days before final inspection. Architect/Engineer will return copy with comments within 15 days after final inspection.
 - 1. Correct or modify each manual to comply with Architect/Engineer's comments. Submit two copies of each corrected manual within 15 days of receipt of Architect/Engineer's comments.

1.4 COORDINATION

- A. Where operation and maintenance documentation includes information on installations by more than one factory-authorized service representative, assemble and coordinate information furnished by representatives and prepare manuals.

PART 2 - PRODUCTS

2.1 SYSTEMS AND EQUIPMENT MAINTENANCE MANUAL

- A. Content: For each system, subsystem, and piece of equipment not part of a system, include source information, manufacturers' maintenance documentation, maintenance procedures, maintenance and service schedules, spare parts list and source information, maintenance service contracts, and warranty and bond information, as described below.
- B. Source Information: List each system, subsystem, and piece of equipment included in manual, identified by product name and arranged to match manual's table of contents. For each product, list name, address, and telephone number of installer or supplier and maintenance service agent, and cross-reference specification section number and title in Project Manual.
- C. Manufacturers' Maintenance Documentation: Manufacturers' maintenance documentation including the following information for each component part or piece of equipment:
 - 1. Standard printed maintenance instructions and bulletins.
 - 2. Drawings, diagrams, and instructions required for maintenance, including disassembly and component removal, replacement, and assembly.
 - 3. Identification and nomenclature of parts and components.
 - 4. List of items recommended to be stocked as spare parts.
- D. Maintenance Procedures: Include the following information and items that detail essential maintenance procedures:
 - 1. Test and inspection instructions.
 - 2. Troubleshooting guide.
 - 3. Precautions against improper maintenance.
 - 4. Disassembly; component removal, repair, and replacement; and reassembly instructions.
 - 5. Aligning, adjusting, and checking instructions.
 - 6. Demonstration and training videotape, if available.
- E. Maintenance and Service Schedules: Include service and lubrication requirements, list of required lubricants for equipment, and separate schedules for preventive and routine maintenance and service with standard time allotment.
 - 1. Scheduled Maintenance and Service: Tabulate actions for daily, weekly, monthly, quarterly, semiannual, and annual frequencies.
 - 2. Maintenance and Service Record: Include manufacturers' forms for recording maintenance.
- F. Spare Parts List and Source Information: Include lists of replacement and repair parts, with parts identified and cross-referenced to manufacturers' maintenance documentation and local sources of maintenance materials and related services.
- G. Maintenance Service Contracts: Include copies of maintenance agreements with name and telephone number of service agent.

H. Warranties and Bonds:

1. Include copies of warranties and bonds and lists of circumstances and conditions that would affect validity of warranties or bonds.
2. Include procedures to follow and required notifications for warranty claims.

PART 3 - EXECUTION

3.1 MANUAL PREPARATION

A. Manufacturers' Data:

1. Where manuals contain manufacturers' standard printed data, include only sheets pertinent to product or component installed. Mark each sheet to identify each product or component incorporated into the Work. If data include more than one item in a tabular format, identify each item using appropriate references from the Contract Documents. Identify data applicable to the Work and delete references to information not applicable.
2. Prepare supplementary text if manufacturers' standard printed data are not available and where the information is necessary for proper operation and maintenance of equipment or systems.

B. Drawings: Prepare drawings supplementing manufacturers' printed data to illustrate the relationship of component parts of equipment and systems and to illustrate control sequence and flow diagrams. Coordinate these drawings with information contained in Record Drawings to ensure correct illustration of completed installation.

1. Do not use original Project Record Documents as part of operation and maintenance manuals.
2. Comply with requirements of newly prepared Record Drawings in Division 01 Section PROJECT RECORD DOCUMENTS.

C. Comply with Division 01 Section CLOSEOUT PROCEDURES for schedule for submitting operation and maintenance documentation.

END OF SECTION 01 78 23

SECTION 22 05 00 - BASIC PLUMBING REQUIREMENTS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Requirements applicable to all Division 22 Sections. Also refer to Division 1 - General Requirements.
- B. All materials and installation methods shall conform to the applicable standards, guidelines and codes referenced herein and within each specification section.

1.2 SCOPE OF WORK

- A. This Specification and the associated drawings govern the furnishing, installing, testing and placing into satisfactory operation the Mechanical Systems.
- B. Each Contractor shall provide all new materials indicated on the drawings and/or in these specifications, and all items required to make the portion of the Mechanical Work a finished and working system.
- C. Separate contracts will be awarded for the following work:
- D. All work will be awarded under a single General Contract. The division of work listed below is for the Contractor's convenience and lists normal breakdown of the work.
- E. Separate contracts will be awarded for the following work. The division of work listed below is for the contractors' convenience and lists a normal breakdown of the work. Please refer to the Construction Manager's scope statements for complete scope of work description.
- F. Scope of Work:
 - 1. Plumbing Work shall include, but is not necessarily limited to:
 - a. Furnish and install gas piping.

1.3 QUALITY ASSURANCE

- A. Contractor's Responsibility Prior to Submitting Pricing Data:
 - 1. The Contractor is responsible for constructing complete and operating systems. The Contractor acknowledges and understands that the Contract Documents are a two-dimensional representation of a three-dimensional object, subject to human interpretation. This representation may include imperfect data, interpreted codes, utility guidelines, three-dimensional conflicts, and required field coordination items. Such deficiencies can be corrected when identified prior to ordering material and starting installation. The Contractor agrees to carefully study and compare the individual Contract Documents and report at once in writing to the Design Team any deficiencies the Contractor may discover. The Contractor further agrees to require each subcontractor to likewise study the documents and report at once any deficiencies discovered.

2. The Contractor shall resolve all reported deficiencies with the Architect/Engineer prior to awarding any subcontracts, ordering material, or starting any work with the Contractor's own employees. Any work performed prior to receipt of instructions from the Design Team will be done at the Contractor's risk.

B. Qualifications:

1. Only products of reputable manufacturers are acceptable.
2. All Contractors and subcontractors shall employ only workers skilled in their trades.

C. Compliance with Codes, Laws, Ordinances:

1. Conform to all requirements of the State of Colorado Codes, Laws, Ordinances and other regulations having jurisdiction.
2. Conform to all published standards of Poudre School District
3. Conform to Federal Act S.3874 requiring the reduction of lead in drinking water.
4. If there is a discrepancy between the codes and regulations and these specifications, the Architect/Engineer shall determine the method or equipment used.
5. If the Contractor notes, at the time of bidding, that any parts of the drawings or specifications do not comply with the codes or regulations, Contractor shall inform the Architect/Engineer in writing, requesting a clarification. If there is insufficient time for this procedure, Contractor shall submit with the proposal a separate price to make the system comply with the codes and regulations.
6. All changes to the system made after letting of the contract, to comply with codes or requirements of Inspectors, shall be made by the Contractor without cost to the Owner.
7. If there is a discrepancy between manufacturer's recommendations and these specifications, the manufacturer's recommendations shall govern.
8. All rotating shafts and/or equipment shall be completely guarded from all contact. Partial guards and/or guards that do not meet all applicable OSHA standards are not acceptable. Contractor is responsible for providing this guarding if it is not provided with the equipment supplied.

D. Permits, Fees, Taxes, Inspections:

1. Procure all applicable permits and licenses.
2. Abide by all laws, regulations, ordinances, and other rules of the State or Political Subdivision where the work is done, or as required by any duly constituted public authority.
3. Pay all charges for permits or licenses.
4. Pay all fees and taxes imposed by the State, Municipal and/or other regulatory bodies.
5. Pay all charges arising out of required inspections by an authorized body.
6. Pay all charges arising out of required contract document reviews associated with the project and as initiated by the Owner or authorized agency/consultant.
7. Where applicable, all fixtures, equipment and materials shall be listed by Underwriters' Laboratories, Inc. and approved by FM Global.

E. Utility Company Requirements:

1. Secure from the appropriate private or public utility company all applicable requirements.
2. Comply with all utility company requirements.
3. Make application for and pay for service connections, such as sewer and water and gas.

4. Make application for and pay for all meters and metering systems required by the utility company.

F. Examination of Drawings:

1. The drawings for the plumbing work are completely diagrammatic, intended to convey the scope of the work and to indicate the general arrangements and locations of equipment, outlets, etc., and the approximate sizes of equipment.
2. Contractor shall determine the exact locations of equipment and rough-ins, and the exact routing of pipes and ducts to best fit the layout of the job.
3. Scaling of the drawings is not sufficient or accurate for determining these locations.
4. Where job conditions require reasonable changes in indicated arrangements and locations, such changes shall be made by the Contractor at no additional cost to the Owner.
5. Because of the scale of the drawings, certain basic items, such as fittings, boxes, valves, unions, etc., may not be shown, but where required by other sections of the specifications or required for proper installation of the work, such items shall be furnished and installed.
6. If an item is either on the drawings or in the specifications, it shall be included in this contract.
7. Determination of quantities of material and equipment required shall be made by the Contractor from the documents. Where discrepancies arise between drawings, schedules and/or specifications, the greater number shall govern.
8. Where used in mechanical documents, the word "furnish" shall mean supply for use, the word "install" shall mean connect complete and ready for operation, and the word "provide" shall mean to supply for use and connect complete and ready for operation.
 - a. Any item listed as furnished shall also be installed, unless otherwise noted.
 - b. Any item listed as installed shall also be furnished, unless otherwise noted.

G. Field Measurements:

1. Verify all pertinent dimensions at the job site before ordering any materials or fabricating any supports, pipes or ducts.

H. Electronic Media/Files:

1. Construction drawings for this project have been prepared utilizing Revit.
2. Contractors and Subcontractors may request electronic media files of the contract drawings and/or copies of the specifications. Specifications will be provided in PDF format.
3. Upon request for electronic media, the Contractor shall complete and return a signed "Electronic File Transmittal" form provided by IMEG.
4. If the information requested includes floor plans prepared by others, the Contractor will be responsible for obtaining approval from the appropriate Design Professional for use of that part of the document.
5. The electronic contract documents can be used for preparation of shop drawings and as-built drawings only. The information may not be used in whole or in part for any other project.
6. The drawings prepared by IMEG for bidding purposes may not be used directly for ductwork layout drawings or coordination drawings.

7. The use of these CAD documents by the Contractor does not relieve them from their responsibility for coordination of work with other trades and verification of space available for the installation.
8. The information is provided to expedite the project and assist the Contractor with no guarantee by IMEG as to the accuracy or correctness of the information provided. IMEG accepts no responsibility or liability for the Contractor's use of these documents.

1.4 SUBMITTALS

- A. Submittals shall be required for the following items, and for additional items where required elsewhere in the specifications or on the drawings.
 1. Submittals List:

- B. General Submittal Procedures: In addition to the provisions of Division 1, the following are required:
 1. Transmittal: Each transmittal shall include the following:
 - a. Date
 - b. Project title and number
 - c. Contractor's name and address
 - d. Division of work (e.g., plumbing, heating, ventilating, etc.)
 - e. Description of items submitted and relevant specification number
 - f. Notations of deviations from the contract documents
 - g. Other pertinent data

 2. Submittal Cover Sheet: Each submittal shall include a cover sheet containing:
 - a. Date
 - b. Project title and number
 - c. Architect/Engineer
 - d. Contractor and subcontractors' names and addresses
 - e. Supplier and manufacturer's names and addresses
 - f. Division of work (e.g., plumbing, heating, ventilating, etc.)
 - g. Description of item submitted (using project nomenclature) and relevant specification number
 - h. Notations of deviations from the contract documents
 - i. Other pertinent data
 - j. Provide space for Contractor's review stamps

 3. Composition:
 - a. Submittals shall be submitted using specification sections and the project nomenclature for each item.
 - b. Individual submittal packages shall be prepared for items in each specification section. All items within a single specification section shall be packaged together where possible. An individual submittal may contain items from multiple specifications sections if the items are intimately linked (e.g., pumps and motors).

- c. All sets shall contain an index of the items enclosed with a general topic description on the cover.
4. Content: Submittals shall include all fabrication, erection, layout, and setting drawings; manufacturers' standard drawings; schedules; descriptive literature, catalogs and brochures; performance and test data; electrical power criteria (e.g., voltage, phase, amps, horsepower, kW, etc.) wiring and control diagrams; Short Circuit Current Rating (SCCR); dimensions; shipping and operating weights; shipping splits; service clearances; and all other drawings and descriptive data of materials of construction as may be required to show that the materials, equipment or systems and the location thereof conform to the requirements of the contract documents.
5. Contractor's Approval Stamp:
 - a. The Contractor shall thoroughly review and approve all shop drawings before submitting them to the Architect/Engineer. The Contractor shall stamp, date and sign each submittal certifying it has been reviewed.
 - b. Unstamped submittals will be rejected.
 - c. The Contractor's review shall include, but not be limited to, verification of the following:
 - 1) Only approved manufacturers are used.
 - 2) Addenda items have been incorporated.
 - 3) Catalog numbers and options match those specified.
 - 4) Performance data matches that specified.
 - 5) Electrical characteristics and loads match those specified.
 - 6) Equipment connection locations, sizes, capacities, etc. have been coordinated with other affected trades.
 - 7) Dimensions and service clearances are suitable for the intended location.
 - 8) Equipment dimensions are coordinated with support steel, housekeeping pads, openings, etc.
 - 9) Constructability issues are resolved (e.g., weights and dimensions are suitable for getting the item into the building and into place, sinks fit into countertops, etc.).
 - d. The Contractor shall review, stamp and approve all subcontractors' submittals as described above.
 - e. The Contractor's approval stamp is required on all submittals. Approval will indicate the Contractor's review of all material and a complete understanding of exactly what is to be furnished. Contractor shall clearly mark all deviations from the contract documents on all submittals. If deviations are not marked by the Contractor, then the item shall be required to meet all drawing and specification requirements.
6. Submittal Identification and Markings:
 - a. The Contractor shall clearly mark each item with the same nomenclature applied on the drawings or in the specifications.
 - b. The Contractor shall clearly indicate the size, finish, material, etc.
 - c. Where more than one model is shown on a manufacturer's sheet, the Contractor shall clearly indicate exactly which item and which data is intended.
 - d. All marks and identifications on the submittals shall be unambiguous.

7. Schedule submittals to expedite the project. Coordinate submission of related items.
8. Identify variations from the contract documents and product or system limitations that may be detrimental to the successful performance of the completed work.
9. Reproduction of contract documents alone is not acceptable for submittals.
10. Incomplete submittals will be rejected without review. Partial submittals will only be reviewed with prior approval from the Architect/Engineer.
11. Submittals not required by the contract documents may be returned without review.
12. The Architect/Engineer's responsibility shall be to review one set of shop drawing submittals for each product. If the first submittal is incomplete or does not comply with the drawings and/or specifications, the Contractor shall be responsible to bear the cost for the Architect/Engineer to recheck and handle the additional shop drawing submittals.
13. Submittals shall be reviewed and approved by the Architect/Engineer before releasing any equipment for manufacture or shipment.
14. Contractor's responsibility for errors, omissions or deviation from the contract documents in submittals is not relieved by the Architect/Engineer's approval.
15. Schedule shall allow for adequate time to perform orderly and proper review of submittals, including time for consultants and Owner if required, and resubmittals by Contractor if necessary, and to cause no delay in Work or in activities of Owner or other contractors.
 - a. Allow at least two weeks for ArchitectTMTM's/Engineer's review and processing of each submittal, excluding mailing.
16. Architect/Engineer reserves the right to withhold action on a submittal which, in the Architect/EngineerTMTM's opinion, requires coordination with other submittals until related submittals are received. The Architect/Engineer will notify the Contractor, in writing, when they exercise this right.

C. Electronic Submittal Procedures:

1. Distribution: Email submittals as attachments to all parties designated by the Architect/Engineer, unless a web-based submittal program is used.
2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.
3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. Submittal file name: 22 XX XX.description.YYYYMMDD
 - b. Transmittal file name: 22 XX XX.description.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.

1.5 SCHEDULE OF VALUES

- A. The requirements herein are in addition to the provisions of Division 1.

B. Format:

1. Use AIA Document Continuation Sheets G703 or another similar form approved by the Owner and Architect/Engineer.
2. Submit in Excel format.
3. Support values given with substantiating data.

C. Preparation:

1. Itemize work required by each specification section and list all providers. All work provided by subcontractors and major suppliers shall be listed on the Schedule of Values. List each subcontractor and supplier by company name.
2. Break down all costs into:
 - a. Material: Delivered cost of product with taxes paid.
 - b. Labor: Labor cost, excluding overhead and profit.
3. Itemize the cost for each of the following:
 - a. Overhead and profit.
 - b. Bonds.
 - c. Insurance.
 - d. General Requirements: Itemize all requirements.
4. For each line item having an installed cost of more than \$5,000, break down costs to list major products or operations under each item. At a minimum, provide material and labor cost line items for the following:
 - a. Excavation and backfill for underground piping systems inside the building.
 - b. Underground piping systems inside the building (sanitary, storm, etc.) listed separately. Break down the material and labor for each piping system based on geography (building, floor, wing and/or phase).
 - c. Each aboveground piping system (sanitary, storm, domestic water, etc.). Break down the material and labor for each piping system based on geography (building, floor, wing and/or phase).
 - d. Pipe insulation with separate material and labor line items for each piping system listed above.
 - e. Each piece of equipment requiring shop drawings (e.g., backflow preventer, water heater, water softener, etc.) using the project nomenclature (BFP-1, WH-1, WS-1, etc.).
 - f. Each plumbing fixture (e.g., WC, lavatory, sink, etc.). Multiple units of the same type can be listed together, provided quantities are also listed so unit costs can be determined.
 - g. Site utilities (5' beyond building)
 - h. Seismic design
 - i. Water balancing
 - j. Commissioning
 - k. Record drawings
 - l. Punchlist and closeout

- D. Update Schedule of Values when:
 - 1. Indicated by Architect/Engineer.
 - 2. Change of subcontractor or supplier occurs.
 - 3. Change of product or equipment occurs.

1.6 CHANGE ORDERS

- A. A detailed material and labor takeoff shall be prepared for each change order, along with labor rates and markup percentages. Change orders shall be broken down by sheet or associated individual line item indicated in the change associated narrative, whichever provides the most detailed breakdown. Change orders with inadequate breakdown will be rejected.
- B. Itemized pricing with unit cost shall be provided from all distributors and associated subcontractors.
- C. Change order work shall not proceed until authorized.

1.7 EQUIPMENT SUPPLIERS' INSPECTION

- A. The following equipment shall not be placed in operation until a competent installation and service representative of the manufacturer has inspected the installation and certified that the equipment is properly installed, adjusted and lubricated; that preliminary operating instructions have been given; and that the equipment is ready for operation:
 - 1. Fire Seal Systems
 - 2. Seismic Restraints and Equipment Bracing
- B. Contractor shall arrange for and obtain supplier's on-site inspection(s) at proper time(s) to assure each phase of equipment installation and/or connection is in accordance with the manufacturer's instructions.
- C. Submit copies of start-up reports to the Architect/Engineer and include copies of Owner's Operation and Maintenance Manuals.

1.8 PRODUCT DELIVERY, STORAGE, HANDLING & MAINTENANCE

- A. Exercise care in transporting and handling to avoid damage to materials. Store materials on the site to prevent damage. Keep materials clean, dry and free from harmful conditions. Immediately remove any materials that become wet or that are suspected of becoming contaminated with mold or other organisms.
- B. Keep all bearings properly lubricated and all belts properly tensioned and aligned.
- C. Coordinate the installation of heavy and large equipment with the General Contractor and/or Owner. If the Mechanical Contractor does not have prior documented experience in rigging and lifting similar equipment, he/she shall contract with a qualified lifting and rigging service that has similar documented experience. Follow all equipment lifting and support guidelines for handling and moving.

- D. Contractor is responsible for moving equipment into the building and/or site. Contractor shall review site prior to bid for path locations and any required building modifications to allow movement of equipment. Contractor shall coordinate the work with other trades.

1.9 NETWORK / INTERNET CONNECTED EQUIPMENT

- A. These specifications may require certain equipment or systems to have network, Internet and/or remote access capability ("Network Capability"). Any requirement for Network Capability shall be interpreted only as a functional capability and is not to be construed as authority to connect or enable any Network Capability. Network Capability may only be connected or enabled with the express written consent of the Owner.

1.10 WARRANTY

- A. Provide one-year warranty, unless otherwise noted, to the Owner for all fixtures, equipment, materials, and workmanship.
- B. The warranty period for all work in this Division of the specifications shall commence on the date of final acceptance, unless a whole or partial system or any separate piece of equipment or component is put into use for the benefit of any party other than the installing contractor with prior written authorization. In this instance, the warranty period shall commence on the date when such whole system, partial system or separate piece of equipment or component is placed in operation and accepted in writing by the Owner.
- C. Warranty requirements shall extend to correction, without cost to the Owner, of all Work found to be defective or nonconforming to the contract documents. The Contractor shall bear the cost of correcting all damage resulting from defects or nonconformance with contract documents.

1.11 INSURANCE

- A. Contractor shall maintain insurance coverage as set forth in Division 0 of these specifications.

1.12 MATERIAL SUBSTITUTION

- A. Where several manufacturers' names are given, the first manufacturer is the basis for job design and establishes the quality.
- B. Equivalent equipment manufactured by the other listed manufacturers may be used. Contractor shall ensure that all items submitted by these other manufacturers meet all requirements of the drawings and specifications and fits in the allocated space. When using other listed manufacturers, the Contractor shall assume responsibility for any and all modifications necessary (including, but not limited to structural supports, electrical connections, piping and ductwork connections and arrangement, plumbing connections and rough-in, and regulatory agency approval, etc.) and coordinate such with other contractors.
- C. Any material, article or equipment of other unnamed manufacturers which will adequately perform the services and duties imposed by the design and is of a quality equal to or better than the material, article or equipment identified by the drawings and specifications may be used if approval is secured in writing from the Architect/Engineer not later than ten days prior to the bid opening.

- D. This Contractor assumes all costs incurred as a result of using the offered material, article or equipment, on the Contractor's part or on the part of other Contractors whose work is affected.
- E. This Contractor may list voluntary add or deduct prices for alternate materials on the bid form. These items will not be used in determining the low bidder.
- F. All material substitutions requested later than ten (10) days prior to bid opening must be listed as voluntary changes on the bid form.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 JOBSITE SAFETY

- A. Neither the professional activities of the Architect/Engineer, nor the presence of the Architect/Engineer or the employees and subconsultants at a construction site, shall relieve the Contractor and other entity of their obligations, duties and responsibilities including, but not limited to, construction means, methods, sequence, techniques or procedures necessary for performing, superintending or coordinating all portions of the work of construction in accordance with the contract documents and any health or safety precautions required by any regulatory agencies. The Architect/Engineer and personnel have no authority to exercise any control over any construction contractor or other entity or their employees in connection with their work or any health or safety precautions. The Contractor is solely responsible for jobsite safety. The Architect/Engineer and the Architect/Engineer's consultants shall be indemnified and shall be made additional insureds under the Contractor's general liability insurance policy.

3.2 ARCHITECT/ENGINEER OBSERVATION OF WORK

- A. The Contractor shall provide seven (7) calendar days' notice to the Architect/Engineer prior to:
 - 1. Placing fill over underground and underslab utilities.
 - 2. Covering exterior walls, interior partitions and chases.
 - 3. Installing hard or suspended ceilings and soffits.
- B. The Architect/Engineer will have the opportunity to review the installation and provide a written report noting deficiencies requiring correction. The Contractor's schedule shall account for these reviews and show them as line items in the approved schedule.
- C. Above-Ceiling Final Observation
 - 1. All work above the ceilings must be complete prior to the Architect/Engineer's review. This includes, but is not limited to:
 - a. Pipe insulation is installed and fully sealed.
 - b. Pipe wall penetrations are sealed.
 - c. Pipe identification and valve tags are installed.

2. In order to prevent the Above-Ceiling Final Observation from occurring too early, the Contractor shall review the status of the work and certify, in writing, that the work is ready for the Above-Ceiling Final Observation.
3. It is understood that if the Architect/Engineer finds the ceilings have been installed prior to this review and prior to 7 days elapsing, the Architect/Engineer may not recommend further payments to the contractor until such time as full access has been provided.

3.3 PROJECT CLOSEOUT

- A. The following paragraphs supplement the requirements of Division 1.
- B. IDPH Final Occupancy Checklist for Request of Inspection:
 1. Each Contractor must submit all forms and certifications required by IDPH relating to their work at 85% completion of the project or when directed by the Owner/Architect/Engineer.
- C. Final Jobsite Observation:
 1. In order to prevent the Final Jobsite Observation from occurring too early, the Contractor is required to review the completion status of the project and certify that the job is ready for the final jobsite observation.
 2. Attached to the end of this section is a typical list of items that represent the degree of job completeness expected prior to requesting a review.
 3. Upon Contractor certification that the project is complete and ready for a final observation, the Contractor shall sign the attached certification and return it to the Architect/Engineer so that the final observation can be scheduled.
 4. It is understood that if the Architect/Engineer finds the job not ready for the final observation and that additional trips and observations are required to bring the project to completion, the costs incurred by the Architect/Engineer's additional time and expenses will be deducted from the Contractor's contract retainage prior to final payment at the completion of the job.
- D. Before final payment is authorized, this Contractor must submit the following:
 1. Operation and maintenance manuals with copies of approved shop drawings.
 2. Record documents including marked-up or reproducible drawings and specifications.
 3. A report documenting the instructions given to the Owner's representatives complete with the number of hours spent in the instruction. The report shall bear the signature of an authorized agent of This Contractor and shall be signed by the Owner's representatives.
 4. Start-up reports on all equipment requiring a factory installation inspection or start-up.
 5. Provide spare parts, maintenance, and extra materials in quantities specified in individual specification sections. Deliver to project site and place in location as directed; receipt by Architect/Engineer required prior to final payment approval.

3.4 OPERATION AND MAINTENANCE MANUALS

A. General:

1. Provide an electronic copy of the O&M manuals as described below for Architect/Engineer's review and approval. The electronic copy shall be corrected as required to address the Architect/Engineer's comments. Once corrected, electronic copies and paper copies shall be distributed as directed by the Architect/Engineer.
2. Approved O&M manuals shall be completed and in the Owner's possession prior to Owner's acceptance and at least 10 days prior to instruction of operating personnel.

B. Electronic Submittal Procedures:

1. Distribution: Email the O&M manual as attachments to all parties designated by the Architect/Engineer.
2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.
3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. O&M file name: O&M.div22.contractor.YYYYMMDD
 - b. Transmittal file name: O&Mtransmittal.div22.contractor.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.
6. Provide the Owner with an approved copy of the O&M manual on compact discs (CD), digital video discs (DVD), or flash drives with a permanently affixed label, printed with the title "Operation and Maintenance Instructions", title of the project and subject matter of disc/flash drive when multiple disc/flash drives are required.
7. All text shall be searchable.
8. Bookmarks shall be used, dividing information first by specification section, then systems, major equipment and finally individual items. All bookmark titles shall include the nomenclature used in the construction documents and shall be an active link to the first page of the section being referenced.

C. Operation and Maintenance Instructions shall include:

1. Title Page: Include title page with project title, Architect, Engineer, Contractor, all subcontractors, and major equipment suppliers, with addresses, telephone numbers, website addresses, email addresses and point of contacts. Website URLs and email addresses shall be active links in the electronic submittal.
2. Table of Contents: Include a table of contents describing specification section, systems, major equipment, and individual items.
3. Copies of all final approved shop drawings and submittals. Include Architect's/Engineer's shop drawing review comments. Insert the individual shop drawing directly after the Operation and Maintenance information for the item(s) in the review form.

4. Copy of final approved test and balance reports.
5. Copies of all factory inspections and/or equipment startup reports.
6. Copies of warranties.
7. Schematic electrical power/controls wiring diagrams of the equipment that have been updated for field conditions. Field wiring shall have label numbers to match drawings.
8. Dimensional drawings of equipment.
9. Capacities and utility consumption of equipment.
10. Detailed parts lists with lists of suppliers.
11. Operating procedures for each system.
12. Maintenance schedule and procedures. Include a chart listing maintenance requirements and frequency.
13. Repair procedures for major components.
14. List of lubricants in all equipment and recommended frequency of lubrication.
15. Instruction books, cards, and manuals furnished with the equipment.
16. Owner and Contractor attendance list for domestic water systems operation, maintenance, and flushing training.

3.5 INSTRUCTING THE OWNER'S REPRESENTATIVES

- A. Adequately instruct the Owner's designated representatives in the maintenance, care, and operation of all systems installed under this contract.
- B. Provide verbal and written instructions to the Owner's representatives by FACTORY PERSONNEL in the care, maintenance, and operation of the equipment and systems.
- C. Contractor shall make a DVD video recording of instructions to the Owner while explaining the system so additional personnel may view the instructions at a later date. The video recording shall be the property of the Owner.
- D. The Owner has the option to make a video recording of all instructions. Coordinate schedule of instructions to facilitate this recording.
- E. The instructions shall include:
 1. Explanation of all system flow diagrams.
 2. Maintenance of equipment.
 3. Start-up procedures for all major equipment.
 4. Explanation of seasonal system changes.
 5. Explanation of Owner's Responsibilities to operate, maintain, and flush domestic water system (i.e., ASHRAE Standard 188).
- F. Notify the Architect/Engineer of the time and place for the verbal instructions to be given to the Owner's representative so a representative can attend if desired.
- G. Minimum hours of instruction for each item shall be:
 1. Gas System(s) - 0.5 hours.

- H. The Contractor shall prepare a detailed, written training agenda and submit it to the Architect/Engineer a minimum of two weeks prior to the formal training for approval. The written agenda shall include specific training points within the items described above. For example: how to adjust setpoints, troubleshooting, proper start-up, proper shut-down, seasonal changes, draining, venting, changing filters, changing belts, etc. Failure to provide and follow an approved training agenda may result in additional training required at the expense of the Contractor.
- I. Operating Instructions:
 - 1. Contractor is responsible for all instructions to the Owner's representatives for the mechanical and control systems.
 - 2. If the Contractor does not have staff that can adequately provide the required instructions the Contractor shall include in the bid an adequate amount to reimburse the Owner for the Architect/Engineer to perform these services.

3.6 SYSTEM STARTING AND ADJUSTING

- A. The plumbing systems shall be complete and operating. System startup, testing, adjusting, and balancing to obtain satisfactory system performance is the responsibility of the Contractor. This includes calibration and adjustments of all controls, noise level adjustments and final adjustments as required.
- B. Complete all manufacturer-recommended startup procedures and checklists to verify proper motor rotation, electrical power voltage is within equipment limitations, equipment controls maintain pressures and temperatures within acceptable ranges, all filters and protective guards are in-place, acceptable access is provided for maintenance and servicing, and equipment operation does not pose a danger to personnel or property.
- C. Contractor shall adjust the plumbing systems and controls at season changes during the one year warranty period, as required, to provide satisfactory operation and to prove performance of all systems in all seasons.
- D. All operating conditions and control sequences shall be tested during the start-up period. Test all interlocks, safety shutdowns, controls, and alarms.
- E. The Contractor, subcontractors, and equipment suppliers shall have skilled technicians to ensure that all systems perform properly. If the Architect/Engineer is requested to visit the job site for trouble shooting, assisting in start-up, obtaining satisfactory equipment operation, resolving installation and/or workmanship problems, equipment substitution issues or unsatisfactory system performance, including call backs during the warranty period, through no fault of the design; the Contractor shall reimburse the Owner on a time and materials basis for services rendered at the Architect/Engineer's standard hourly rates in effect when the services are requested. The Contractor shall pay the Owner for services required that are product, installation or workmanship related. Payment is due within 30 days after services are rendered.

3.7 RECORD DOCUMENTS

- A. The following paragraphs supplement Division 1 requirements.

- B. Maintain at the job site a separate and complete set of plumbing drawings and specifications with all changes made to the systems clearly and permanently marked in complete detail.
- C. Mark drawings to indicate revisions to piping size and location, both exterior and interior; including locations devices, requiring periodic maintenance or repair; actual equipment locations, dimensioned from column lines; actual inverts and locations of underground piping; concealed equipment, dimensioned from column lines; mains and branches of piping systems, with valves and control devices located and numbered, concealed unions located, and with items requiring maintenance located; Change Orders; concealed control system devices.
- D. Before completion of the project, a set of reproducible plumbing drawings will be given to the Contractor for transfer of all as-built conditions from the paper set maintained at the job site. All marks on reproducibles shall be clear and permanent.
- E. Mark specifications to show approved substitutions; Change Orders, and actual equipment and materials used.
- F. Record changes daily and keep the marked drawings available for the Architect/Engineer's examination at any normal work time.
- G. Upon completing the job, and before final payment is made, give the marked-up drawings to the Architect/Engineer.

3.8 PAINTING

- A. This Contractor shall paint the following items:
 - 1. All Exposed piping.
- B. Paint all equipment that is marred or damaged prior to the Owner's acceptance. Paint and color shall match original equipment paint and shall be obtained from the equipment supplier if available.
- C. Equipment in finished areas that will be painted to match the room decor will be painted by others. Should this Contractor install equipment in a finished area after the area has been painted, the Contractor shall have the equipment and all its supports, hangers, etc., painted to match the room decor.
- D. Equipment cabinets, casings, covers, metal jackets, etc., in equipment rooms or concealed spaces, shall be furnished in standard or prime finish, free from scratches, abrasions, chips, etc.
- E. Equipment in occupied spaces, or if standard to the unit, shall have a baked primer with baked enamel finish coat free from scratches, abrasions, chips, etc. If color option is specified or is standard to the unit, this Contractor shall, before ordering, verify with the Architect/Engineer the color preference and furnish this color.
- F. Paint all equipment in unfinished areas such as boiler room, mechanical spaces, storage room, etc., furnished by this Contractor. Equipment furnished with a factory coat of paint and enamel need not be painted, provided the factory applied finish is not marred or spattered. If so, equipment shall be refinished with the same paint as was factory applied.

- G. Paint all outdoor uninsulated steel piping the color selected by Owner or Architect/Engineer.
- H. Paint all outdoor exposed natural gas piping the color selected by Owner or Architect/Engineer.
- I. After surfaces have been thoroughly cleaned and are free of oil, dirt, and other foreign matter; paint all pipes and equipment with the following:
 - 1. Bare Metal Surfaces - Apply one coat of primer suitable for the metal being painted. Finish with two coats of Alkyd base enamel paint.
 - 2. Insulated Surfaces - Paint insulation jackets with two coats of semi-gloss acrylic latex paint.
 - 3. Color of paint shall be as follows:
 - a. All piping in mechanical room:
 - 1) Natural Gas: Yellow pipe/black letters
 - b. Piping exposed in kitchen:
 - 1) All Piping: White

3.9 ADJUST AND CLEAN

- A. Thoroughly clean all equipment and systems prior to the Owner's final acceptance of the project. Clean all foreign paint, grease, oil, dirt, labels, stickers, and other foreign material from all equipment.
- B. Clean all areas where moisture is present. Immediately report any mold, biological growth, or water damage.
- C. Remove all rust, scale, dirt, oils, stickers and thoroughly clean exterior of all exposed piping, hangers, and accessories.
- D. Remove all rubbish, debris, etc., accumulated during construction from the premises.

3.10 SPECIAL REQUIREMENTS

- A. Contractor shall coordinate the installation of all equipment, valves, dampers, operators, etc., with other trades to maintain clear access area for servicing.
- B. All equipment shall be installed in such a way to maximize access to parts needing service or maintenance. Review the final field location, placement, and orientation of equipment with the Owner's designated representative prior to setting equipment.
- C. Installation of equipment or devices without regard to coordination of access requirements and confirmation with the Owner's designated representative will result in removal and reinstallation of the equipment at the Contractor's expense.

3.11 IAQ MAINTENANCE FOR OCCUPIED FACILITIES UNDER CONSTRUCTION

- A. Contractors shall make all reasonable efforts to prevent construction activities from affecting the air quality of the occupied areas of the building or outdoor areas near the building. These measures shall include, but not be limited to:
 - 1. All contractors shall endeavor to minimize the amount of contaminants generated during construction. Methods to be employed shall include, but not be limited to:
 - a. Minimizing the amount of dust generated.
 - b. Reducing solvent fumes and VOC emissions.
 - c. Maintain good housekeeping practices, including sweeping and periodic dust and debris removal. There should be no visible haze in the air.
 - d. Protect stored on-site and installed absorptive materials from moisture damage.

END OF SECTION 22 05 00

SECTION 22 05 03 - THROUGH PENETRATION FIRESTOPPING

PART 1 - GENERAL

1.1 REFERENCES

- A. UL 263 - Fire Tests of Building Construction and Materials
- B. UL 723 - Surface Burning Characteristics of Building Materials
- C. ANSI/UL 1479 - Fire Tests of Through Penetration Firestops
- D. UL 2079 - Tests for Fire Resistance of Building Joint Systems
- E. UL Fire Resistance Directory Through Penetration Firestop Systems (XHEZ)
- F. Intertek / Warnock Hersey - Directory of Listed Products
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials
- H. ASTM E814 - Standard Test Method for Fire Tests of Through-Penetration Firestops
- I. The Building Officials and Code Administrators National Building Code
- J. 1997 Uniform Building Code
- K. Wisconsin Administrative Code
- L. 2021 International Building Code
- M. NFPA 5000 - Building Construction Safety Code

1.2 DELIVERY, STORAGE, AND HANDLING

- A. Store, protect and handle products on site. Accept material on site in factory containers and packing. Inspect for damage. Protect from deterioration or damage due to moisture, temperature changes, contaminants, or other causes. Follow manufacturer's instructions for storage.
- B. Install material prior to expiration of product shelf life.

1.3 PERFORMANCE REQUIREMENTS

- A. General: For penetrations through the following fire-resistance-rated constructions, including both empty openings and openings containing penetrating items, provide through-penetration firestop systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of construction penetrated.
 - 1. Fire-resistance-rated walls including fire partitions, fire barriers, and smoke barriers.

2. Fire-resistance-rated horizontal assemblies including floors, floor/ceiling assemblies, and ceiling membranes of roof/ceiling assemblies.
- B. For through-penetration firestop systems exposed to light, traffic, moisture, or physical damage, provide products that, after curing, do not deteriorate when exposed to these conditions both during and after construction.
 - C. For through-penetration firestop systems exposed to view, provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E 84.
 - D. For through-penetration firestop systems in air plenums, provide products with flame-spread and smoke-developed indexes of less than 25 and 50, respectively, as determined per ASTM E 84.

1.4 MEETINGS

- A. Pre-installation meeting: A pre-installation meeting shall be scheduled and shall include the Construction Manager, all Subcontractors associated with the installation of systems penetrating fire barriers, Firestopping Manufacturer's Representative, and the Owner.
 1. Review foreseeable methods related to firestopping work.
 2. Tour representative areas where firestopping is to be installed; inspect and discuss each type of condition and each type of substrate that will be encountered, and preparation to be performed by other trades.

1.5 WARRANTY

- A. Provide one year warranty on parts and labor.
- B. Warranty shall cover repair or replacement of firestop systems which fail in joint adhesion, cohesion, abrasion resistance, weather resistance, extrusion resistance, migration resistance, stain resistance, general durability, or appear to deteriorate in any manner not clearly specified by the manufacturer as an inherent quality of the material.

PART 2 - PRODUCTS

<u>Penetrating Item</u>	<u>UL System No.</u>
No Penetrating Item	FC 0000-0999*
Metallic Pipe or Conduit	FC 1000-1999
Non-Metallic Pipe or Conduit	FC 2000-2999
Electrical Cables	FC 3000-3999
Cable Trays	FC 4000-4999
Insulated Pipes	FC 5000-5999
Bus Duct and Misc. Electrical	FC 6000-6999
Duct without Damper and Misc. Mechanical	FC 7000-7999
Multiple Penetrations	FC 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

<u>Penetrating Item</u>	<u>UL System No.</u>
No Penetrating Item	WL 0000-0999*
Metallic Pipe or Conduit	WL 1000-1999
Non-Metallic Pipe or Conduit	WL 2000-2999
Electrical Cables	WL 3000-3999
Cable Trays	WL 4000-4999
Insulated Pipes	WL 5000-5999
Bus Duct and Misc. Electrical	WL 6000-6999
Duct without Damper and Misc. Mechanical	WL 7000-7999
Multiple Penetrations	WL 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

<u>Penetrating Item</u>	<u>UL System No.</u>
No Penetrating Item	CAJ 0000-0999*
Metallic Pipe or Conduit	CAJ 1000-1999
Non-Metallic Pipe or Conduit	CAJ 2000-2999
Electrical Cables	CAJ 3000-3999
Cable Trays	CAJ 4000-4999
Insulated Pipes	CAJ 5000-5999
Bus Duct and Misc. Electrical	CAJ 6000-6999
Duct without Damper and Misc. Mechanical	CAJ 7000-7999
Multiple Penetrations	CAJ 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Ensure all surfaces that contact seal materials are free of dirt, dust, grease, oil, rust, or loose materials. Clean and repair surfaces as required. Remove laitance and form-release agents from concrete.
- B. Ensure substrate and penetrating items have been permanently installed prior to installing firestopping systems. Ensure penetrating items have been properly spaced and have proper clearance prior to installing firestopping systems.
- C. Surfaces to which sealing materials are to be installed must meet the selected UL or Intertek / Warnock Hersey system substrate criteria.
- D. Prime substrates where recommended in writing by through-penetration firestop system manufacturer. Confine primer to area of bond.

3.2 CLEANING AND PROTECTING

- A. Clean excess fill materials adjacent to openings as Work progresses by methods and with cleaning materials that are approved in writing by through-penetration firestop system manufacturers and that do not cause damage.
- B. Provide final protection and maintain conditions during and after installation that ensure that through-penetration firestop systems are without damage or deterioration at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, remove damaged or deteriorated through-penetration firestop systems immediately and install new materials to produce systems complying with specified requirements.

3.3 IDENTIFICATION

- A. Provide and install labels adjacent to each firestopping location. Label shall be provided by the firestop system supplier and contain the following information in a contrasting color:
 - 1. The words "Warning - Through Penetration Firestop System - Do Not Disturb. Notify Building Management of Any Damage."
 - 2. Firestop System Supplier; UL or listed by Intertek / Warnock Hersey system number; date installed; contractor name and phone number; manufacturer's representative name, address, and phone number.

3.4 INSPECTION

- A. All penetrations shall be inspected by the manufacturer's representative to ensure proper installation.
- B. Access to firestop systems shall be maintained for examination by the Authority Having Jurisdiction at their request.
- C. Proceed with enclosing through-penetration firestop system with other construction only after inspection reports are issued and firestop installations comply with requirements.
- D. The contractor shall allow for visual destructive review of 5% of installed firestop systems (minimum of one) to prove compliance with specifications and manufacturer's instructions and details. Destructive system removal shall be performed by the contractor and witnessed by the engineer and manufacturer's factory representative. The engineer shall have sole discretion of which firestop system installations will be reviewed. The contractor is responsible for all costs associated with this requirement including labor and material for removing and replacing the installed firestop system. If any firestop system is found to not be installed per manufacturer's specific instructions and details, all firestop systems are subject to destructive review and replacement at the engineer's discretion and the contractor's expense.

END OF SECTION 22 05 03

SECTION 22 05 05 - PLUMBING DEMOLITION FOR REMODELING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Plumbing Demolition.
- B. Cutting and Patching.

PART 2 - PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- A. Materials and equipment shall be as specified in individual Sections.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. THE DRAWINGS ARE INTENDED TO INDICATE THE GENERAL SCOPE OF WORK AND DO NOT SHOW EVERY PIPE, DUCT, OR PIECE OF EQUIPMENT THAT MUST BE REMOVED. THE CONTRACTOR SHALL VISIT THE SITE AND VERIFY CONDITIONS PRIOR TO SUBMITTING A BID.
- B. Where walls, ceilings, etc., are shown as being removed on general drawings, the Contractor shall remove all mechanical equipment, devices, fixtures, piping, ducts, systems, etc., from the removed area.
- C. Where ceilings, walls, partitions, etc., are temporarily removed and replaced by others, This Contractor shall remove, store, and replace equipment, devices, fixtures, pipes, ducts, systems, etc.
- D. Verify that abandoned utilities serve only abandoned equipment or facilities. Extend services to facilities or equipment that shall remain in operation following demolition.
- E. Coordinate work with all other Contractors and the Owner. Schedule removal of equipment to avoid conflicts.
- F. This Contractor shall verify all existing equipment sizes and capacities where equipment is scheduled to be replaced or modified, prior to ordering new equipment.
- G. Bid submittal shall mean the Contractor has visited the project site and verified existing conditions and scope of work.

3.2 PREPARATION

- A. Disconnect plumbing systems in walls, floors, and ceilings scheduled for removal.
- B. Provide temporary connections to maintain existing systems in service during construction. When work must be performed on operating equipment, use personnel experienced in such operations.
- C. Existing Plumbing System: Maintain service to all plumbing fixtures until new piping is installed. Obtain permission from Owner at least 48 hours before shutting down system for any reason. Make changeover to new piping with minimum outage. Do not disconnect any roof drainage piping until new piping is in place and operational.

3.3 DEMOLITION AND EXTENSION OF EXISTING MECHANICAL WORK

- A. Demolish and extend existing plumbing work under provisions of Division 2 and this Section.
- B. Remove, relocate, and extend existing installations to accommodate new construction.
- C. Remove abandoned piping to source of supply and/or main lines.
- D. Remove exposed abandoned pipes, including abandoned pipes above accessible ceilings. Cut pipes above ceilings, below floors and behind walls. Cap remaining lines. Repair building construction to match original. Remove all clamps, hangers, supports, etc. associated with pipe and duct removal.
- E. Disconnect and remove mechanical devices and equipment serving equipment that has been removed.
- F. Repair adjacent construction and finishes damaged during demolition and extension work.
- G. Extend existing installations using materials and methods compatible with existing installations, or as specified.
- H. Remove unused sections of domestic water piping back to mains and cap. Capped pipe shall be less than 2 feet from main to prevent "dead legs".
- I. Temporarily cap all openings to the sanitary and vent system to prevent odor from entering the work area and building.

3.4 CUTTING AND PATCHING

- A. This Contractor is responsible for all penetrations of existing construction required to complete the work of this project. Refer to Section 22 05 29 for additional requirements.
- B. Penetrations in existing construction should be reviewed carefully prior to proceeding with any work.
- C. Penetrations shall be neat and clean with smooth and/or finished edges. Core drill where possible for clean opening.

- D. Repair existing construction as required after penetration is complete to restore to original condition. Use similar materials and match adjacent construction unless otherwise noted or agreed to by the Architect/Engineer prior to start of work.
- E. This Contractor is responsible for all costs incurred in repair, relocations, or replacement of any cables, conduits, or other services if damaged without proper investigation.

3.5 CLEANING AND REPAIR

- A. Clean and repair existing materials and equipment which remain or are to be reused.
- B. Clean all systems adjacent to project which are affected by the dust and debris caused by this construction.
- C. PLUMBING ITEMS REMOVED AND NOT RELOCATED REMAIN THE PROPERTY OF THE OWNER. CONTRACTOR SHALL PLACE ITEMS RETAINED BY THE OWNER IN A LOCATION COORDINATED WITH THE OWNER. THE CONTRACTOR SHALL DISPOSE OF MATERIAL THE OWNER DOES NOT WANT TO REUSE OR RETAIN FOR MAINTENANCE PURPOSES.

3.6 SPECIAL REQUIREMENTS

- A. Install temporary filter media over outside air intakes which are within 100 feet of the limits of construction or as noted on the drawings. This Contractor shall complete any cleaning required for existing systems which are affected by construction dust and debris.
- B. Review locations of all new penetrations in existing floor slabs or walls. Determine construction type and review for possible interferences. Bring all concerns to the attention of the Architect/Engineer before proceeding.

END OF SECTION 22 05 05

SECTION 22 05 29 - PLUMBING SUPPORTS AND ANCHORS

PART 1 - GENERAL

1.1 REFERENCES

- A. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation.
- B. MSS SP 69 - Pipe Hangers and Supports - Selection and Application.
- C. MSS SP 89 - Pipe Hangers and Supports - Fabrication and Installation Practices
- D. MSS SP-127 - Bracing for Piping Systems Seismic-Wind-Dynamic Design, Selection, Application.

1.2 WORK FURNISHED BUT INSTALLED UNDER OTHER SECTIONS

- A. Furnish sleeves and hanger inserts to General Contractor for placement into formwork.

PART 2 - PRODUCTS

Pipe Size	Hanger Rod Diameter	
	Column #1	Column #2
2-1/2" and smaller	3/8"	3/8"
3" through 3-5/8"	3/8"	3/8"
4" and 5"	1/2"	1/2"
6"	3/4"	5/8"
8" through 12"	7/8"	3/4"
14"	1"	7/8"
16" and 18"	1"	N/A
20" and 24"	1-1/4"	N/A

Column #1: Steel, cast iron, and glass pipe.

Column #2: Copper and plastic pipe.

Model	Service	Element Material	Temperature Range
S	Standard (Stainless)	EPDM	-40°F to 250°F
T	High/Low Temperature (Steam)	Silicone	-67°F to 400°F
T	Fire Seals (1 hour)	Silicone	-67°F to 400°F
FS	Fire Seals (3 hours)	Silicone	-67°F to 400°F
OS	Oil Resistant/Stainless	Nitrile	-40°F to 210°F

PART 3 - EXECUTION

3.1 PLUMBING SUPPORTS AND ANCHORS

A. General Installation Requirements:

1. Install all items per manufacturer's instructions.
2. Coordinate the location and method of support of piping systems with all installations under other Divisions and Sections of the Specifications.
3. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding.
4. Supports shall extend directly to building structure. Do not support piping from duct hangers unless coordinated with sheet metal contractor prior to installation. Do not allow lighting or ceiling supports to be hung from piping supports.

B. Supports Requirements:

1. Where building structural steel is fireproofed, all hangers, clamps, auxiliary steel, etc., which attach to it shall be installed prior to application of fireproofing. Repair all fireproofing damaged during pipe installation.
2. Set all concrete inserts in place before pouring concrete.
3. Furnish, install and prime all auxiliary structural steel for support of piping systems that are not shown on the Drawings as being by others.
4. Install hangers and supports complete with lock nuts, clamps, rods, bolts, couplings, swivels, inserts and required accessories.
5. Hangers for horizontal piping shall have adequate means of vertical adjustment for alignment.

C. Provided the installation complies with all loading requirements of truss and joist manufacturers, the following practices are acceptable:

1. Loads of 100 lbs. or less may be attached anywhere along the top or bottom chords of trusses or joists with a minimum 3' spacing between loads.
2. Loads greater than 100 lbs. must be hung concentrically and may be hung from top or bottom chord, provided one of the following conditions is met:
 - a. The hanger is attached within 6" from a web/chord joint.
 - b. Additional L2x2x1/4 web reinforcement is installed per manufacturer's requirements.
3. It is prohibited to cantilever a load using an angle or other structural component that is attached to a truss or joist in such a fashion that a torsional force is applied to that structural member.
4. If conditions cannot be met, coordinate installation with truss or joist manufacturer and contact Architect/Engineer.

D. After piping and insulation installation are complete, cut hanger rods back at trapeze supports so they do not extend more than 3/4" below bottom face of lowest fastener and blunt any sharp edges.

- E. Do not exceed 25 lbs. per hanger and a minimum spacing of 2'-0" on center when attaching to metal roof decking (limitation not required with concrete on metal deck). This 25 lbs. load and 2'-0" spacing include adjacent electrical and architectural items hanging from deck. If the hanger restrictions cannot be achieved, supplemental framing off steel framing will need to be added.
- F. Do not exceed the manufacturer's recommended maximum load for any hanger or support.
- G. Steel/Concrete Structure: Spacing of hangers shall not exceed the compressive strength of the insulation inserts, and in no case shall exceed the following:
 - 1. Steel and Fiberglass (Std. Weight or Heavier - Liquid Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" & under: 7'-0"
 - 2) 1-1/2": 9'-0"
 - 3) 2": 10'-0"
 - 4) 2-1/2": 11'-0"
 - 5) 3": 12'-0"
 - 6) 4" & larger: 12'-0"
 - 2. Steel (Std. Weight or Heavier - Vapor Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" and under: 9'-0"
 - 2) 1-1/2": 12'-0"
 - 3) 2" & larger: 12'-0"
 - 3. Hard Drawn Copper & Brass (Liquid Service):
 - a. Maximum Spacing:
 - 1) 3/4" and under: 5'-0"
 - 2) 1": 6'-0"
 - 3) 1-1/4": 7'-0"
 - 4) 1-1/2" 8'-0"
 - 5) 2": 8'-0"
 - 6) 2-1/2": 9'-0"
 - 7) 3": 10'-0"
 - 8) 4": 12'-0"
 - 9) 6": 12'-0"
 - 4. Hard Drawn Copper & Brass (Vapor Service):
 - a. Maximum Spacing:
 - 1) 3/4" & under: 7'-0"
 - 2) 1": 8'-0"
 - 3) 1-1/4": 9'-0"

- 4) 1-1/2": 10'-0"
- 5) 2": 11'-0"
- 6) 2-1/2" & larger: 12'-0"

5. Flexible Plastic Pipe, Flexible Hose, and Soft Copper Tubing:

- a. Continuous channel with hangers maximum 8'-0" OC.

6. Rigid Plastic Pipe:

- a. Hangers shall be spaced based on the piping system manufacturers' instructions or, if no system instructions are available, space hangers at 4'-0" maximum centers.

H. Installation of hangers shall conform to MSS SP-58, 69, 89 and the applicable Plumbing Code.

END OF SECTION 22 05 29

SECTION 22 05 53 - PLUMBING IDENTIFICATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Identification of products installed under Division 22.

1.2 REFERENCES

- A. ANSI/ASME A13.1 - Scheme for the Identification of Piping Systems.
- B. ASTM B-1, B-3, and B-8 for copper conductors.
- C. ASTM D-1248 for Polyethylene Extrusion Materials, ICEA S-70-547 Weatherproof Resistant Polyethylene Conductors, ICEA S-61-402/NEMA WC5 Thermoplastic Insulated Wire & Cable, ICEA S-95-658/NEMA WC70 Non-Shielded 0 “ 2kV Cables.
- D. CGA Pamphlet C-9, Standard Color-Marking of Compressed Gas Cylinders for Medical Use.
- E. NFPA-99 “ Health Care Facilities.
- F. UL 1581 Standard for Electrical Wires, Cables, and Flexible Cords.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

OD of Pipe or Insulation	Marker Length	Size of Letters
Up to and including 1-1/4"	8"	1/2"
1-1/2" to 2"	8"	3/4"
2-1/2" to 6"	12"	1-1/4"
8" to 10"	24"	2-1/2"
Over 10"	32"	3-1/2"

Plastic tags may be used for outside diameters under 3/4"

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install all products per manufacturer's recommendations.
- B. Degrease and clean surfaces to receive adhesive for identification materials.
- C. Valves:
 - 1. All valves (except shutoff valves at equipment) shall have numbered tags.

2. Provide or replace numbered tags on all existing valves that are connected to new systems or that have been revised.
3. Provide all existing valves used to extend utilities to this project with numbered tags. Review tag numbering sequence with the Owner prior to ordering tags.
4. Secure tags with heavy duty key chain and brass "S" link or with mechanically fastened plastic straps.
5. Attach to handwheel or around valve stem. On lever operated valves, drill the lever to attach tags.
6. Number all tags and show the service of the pipe.
7. Provide one Plexiglas framed valve directory listing all valves, with respective tag numbers, uses and locations. Mount directory in location chosen by the Architect/Engineer.
8. Provide one 36" x 24" minimum Plexiglas framed piping schematic showing valve locations with respective tag numbers. Mount directory in location chosen by the Architect/Engineer.
9. Provide two sets of laminated 8-1/2" x 11" (letter size) copies of a valve directory listing all valves, with respective tag numbers, uses, and locations. The directory shall be reviewed by the Owner and Architect/Engineer prior to laminating final copies. Laminated copies shall have brass eyelet in at least one corner for easy hanging.

D. Equipment:

1. All equipment not easily identifiable such as controls, relays, gauges, etc.; and all equipment in an area remote from its function shall have nameplates or plastic tags listing name, function, and drawing symbol. Do not label exposed equipment in public areas.
2. Mechanical equipment that is not covered by the U.S. National Appliance Energy Conservation Act (NAECA) of 1987 shall carry a permanent label installed by the manufacturer stating that the equipment complies with the requirements of ASHRAE 90.1.

3.2 SCHEDULE

- A. Pipes to be marked shall be labeled with text as follows, regardless of which method or material is used:
1. NATURAL GAS: Black lettering; yellow background

END OF SECTION 22 05 53

PART 1 - SECTION 22 10 23 - NATURAL GAS AND PROPANE PIPING GENERAL

1.1 SECTION INCLUDES

- A. Pipe and Pipe Fittings.
- B. Valves.
- C. Natural Gas Piping System.

1.2 QUALITY ASSURANCE

- A. Valves: Manufacturer's name and pressure rating marked on valve body. Remanufactured valves are not acceptable.
- B. Welding Materials, Procedures, and Operators: Conform to ASME Section 9, ANSI/AWS D1.1, and applicable state labor regulations.
- C. Welders Certification: In accordance with ANSI/ASME Sec 9 or ANSI/AWS D1.1.

1.3 REFERENCES

- A. ANSI/AWS D1.1 - Structural Welding Code.
- B. ANSI AGA-LC1 - Standards for Fuel Gas Piping Systems Using Corrugated Stainless Steel Tubing.
- C. ANSI/AWWA C111/A21.11 - Rubber Gasket Joints for Ductile Iron Pressure Pipe and Fittings.
- D. ASME - Boiler and Pressure Vessel Code - Section 9.
- E. ASME B1.20.1 - Pipe Threads, General Purpose.
- F. ASME B16.3 - Malleable Iron Threaded Fittings Class 150 and 300.
- G. ASME B16.5 - Pipe Flanges and Flanged Fittings.
- H. ASME B16.9 - Factory-Made Wrought Steel Butt Welding Fittings.
- I. ASME B16.11 - Forged Steel Fittings, Socket-Welding and Threaded.
- J. ASME B16.21 - Nonmetallic Flat Gaskets for Pipes Flanges.
- K. ASME B16.39 - Malleable Iron Threaded Pipe Unions.
- L. ASME B18.2.1 - Square and Hex Bolts and Screws, Inch Series.
- M. ASME B18.2.2 - Square and Hex Nuts, Inch Series.
- N. ASTM A53 - Pipe, Steel, Black and Hot-Dipped Zinc Coated, Welded and Seamless.

- O. ASTM A105 - Standard Specification for Carbon Steel Forgings for Piping Applications.
- P. ASTM A181 - Forgings, Carbon Steel for General Purpose Piping.
- Q. ASTM A197 - Standard Specification for Cupola Malleable Iron.
- R. ASTM A234 - Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service.
- S. ASTM A240 - Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications.
- T. ASTM A307 - Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
- U. ASTM D2513 - Thermoplastic Gas Pressure Pipe, Tubing and Fittings.
- V. ASTM D2683 - Socket-Type Polyethylene Fittings for Outside Diameter-Controlled Polyethylene Pipe.
- W. ASTM D2774 - Standard Practice for Underground Installation of Thermoplastic Pressure Piping.
- X. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials.
- Y. NFPA 54 - National Fuel Gas Code.

1.4 SUBMITTALS

- A. Submit product data under provisions of Section 22 05 00. Include data on pipe materials, fittings, valves, and accessories.
- B. Test Reports: Provide results of piping system pressure test.
- C. Welders Certificates: Certify welders employed on the Work, verifying AWS qualification within previous 12 months.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store and protect piping to prevent entrance of foreign matter into pipe and to prevent exterior corrosion.
- B. Deliver and store valves in shipping containers with labeling in place.

PART 2 - PRODUCTS

2.1 NATURAL GAS (0 to 125 PSI)

- A. Design Pressure: 125 psi. Maximum Design Temperature: 350°F

B. Piping - 2" and Under:

1. Pipe: Standard weight steel, threaded and coupled, ASTM A53.
2. Joints: Screwed. (NOTE: For below ground, all sizes to have welded joints.)
3. Fittings: 150# steam - 300# CWP, black malleable iron, banded, ASTM A197, ANSI B16.3.
4. Unions: 250# - 500# CWP, black malleable iron, ANSI B16.39, ground joint with brass seat.

C. Piping - 2-1/2" and Over:

1. Pipe: Standard weight steel, beveled ends, ASTM A53.
2. Joints: Butt welded or flanged.
3. Fittings: Standard weight seamless steel, butt weld type, ASTM A234, Grade I, ANSI B16.9.
4. Flanges: 150# forged steel, weld neck or slip-on, ASTM A181, Grade I, ANSI B16.5. Flange face seal weld (backweld) is required for slip-on flanges.

D. Piping - All Sizes:

1. Pipe: Polyethylene pipe, ASTM D2513, SDR 11.5.
2. Joints: Fusion welded.
3. Fittings: Socket type, ASTM D2683 or ASTM D2513.
4. Limits: Use only below ground outside of buildings.

E. For Underground Gas Piping - Refer to paragraph "Underground Piping Protection."

F. Shutoff Valves/Throttling Valves:

1. For pipe systems where mechanical press connections are allowed, shutoff valves with mechanical press connections are acceptable subject to the requirements in the paragraphs below.
2. PL-1: 2" and under, 125# steam @ 450°F, 175# CWP @ 180°F, cast iron body, screwed, full port.
 - a. Manufacturers:
 - 1) Jenkins, Lunkenheimer, Stockham.
3. PL-2: 2-1/2" thru 4", 125# steam @ 450°F, 175# CWP @ 180°F, flanged, cast iron body, full port.
 - a. Manufacturers:
 - 1) Jenkins, Lunkenheimer, Stockham.

4. PL-3: 6" and larger, 125# steam @ 450°F, 175# CWP, cast iron body, flanged, resilient faced plug, gear and handwheel operator, full port.

- a. Manufacturers:

- 1) Jenkins, Lunkenheimer, Stockham.

- G. Design Pressure: 300 psi.

1. Maximum Design Temperature: 400°F

PART 3 - EXECUTION

3.1 PREPARATION

- A. Ream pipe and tube ends, remove burrs, bevel plain end ferrous pipe.
- B. Remove scale and dirt on inside and outside before assembly.
- C. Remove all scale, rust, dirt, oils, stickers and thoroughly clean exterior of all bare metal exposed piping, hangers, and accessories in preparation to be painted.
- D. Connect to all equipment with flanges or unions.
- E. After completion, fill, clean, and treat systems. Refer to Section 23 25 00 for treatment.

3.2 TESTING PIPING

- A. Low Pressure - Up to 1 psi:
 1. Test piping with 20 psi air pressure. System must hold this pressure without adding air for two hours.
- B. High Pressure - Above 1 psi:
 1. Test piping with compressed air at twice the operating gas pressure, but at least 20 psi. System must hold this pressure without adding air for two hours.
- C. A non-combustible odorant, such as oil of wintergreen, may be added to help locate leaks.

3.3 CLEANING PIPING

- A. Assembly:
 1. Prior to assembly of pipe and piping components, remove all loose dirt, scale, oil and other foreign matter on internal or external surfaces by means consistent with good piping practice subject to approval of the Architect/Engineer. Blow chips and burrs out of pipe before assembly. Wipe cutting oil from internal and external surfaces.

2. During fabrication and assembly, remove slag and weld spatter from both internal and external joints by peening, chipping and wire brushing to the degree consistent with good piping practices.
3. Notify the Architect/Engineer prior to starting any post erection cleaning operation in time to allow witnessing the operation. Properly dispose of cleaning and flushing fluids.
4. Prior to blowing or flushing erected piping systems, disconnect all instrumentation and equipment, open wide all valves, control valves, and balance valves, and verify all strainer screens are in place.

3.4 INSTALLATION

- A. Route piping in orderly manner, straight, plumb, with consistent pitch, parallel to building structure, with minimum use of offsets and couplings. Provide only offsets required for needed headroom or clearance and needed flexibility in pipe system.
- B. Install piping to conserve building space, and not interfere with other work.
- C. Do not install piping or other equipment above electrical switchboards or panelboards. This includes a dedicated space extending 25 feet from the floor to the structural ceiling with width and depth equal to the equipment.
- D. Group piping whenever practical at common elevations.
- E. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- F. Install thrust blocking and restraints on all buried piping at elbows and other changes in pipe direction.
- G. Provide chain operators for all valves over 2" size that are over 10'-0" above finished floor. Extend to 7'-0" above finished floor.
- H. Provide valve position indicator on all valves 10'-0" or greater above finish floor and not located above ceiling.
- I. Provide clearance for access to valves and fittings.
- J. Provide access doors where valves are not exposed.
- K. Prepare pipe, fittings, supports, and accessories for finish painting.
- L. Install valves with stems upright or horizontal, not inverted.
- M. Provide shutoff valves and flanges or unions at all connections to equipment, traps, and items that require servicing.
- N. Provide shutoff valves to isolate part of systems and vertical risers.
- O. Arrange piping and piping connections so equipment may be serviced or totally removed without disturbing piping beyond final connections and associated shutoff valves.

- P. Reducers are generally not shown. Where pipe sizes are not shown, the larger size in either direction shall continue through the fitting nearest to the indication of a smaller pipe size.
- Q. Lay all underground piping in trenches. Provide and operate pumping equipment to keep trenches free of water.
- R. Seal pipes passing through exterior walls with a wall seal per Section 23 05 29. Provide Schedule 40 galvanized sleeve at least 2 pipe sizes larger than the pipe.
- S. Refer to Section 23 05 00 for Excavation, Fill, Backfill and Compaction requirements.
- T. Underground Piping Protection:
 - 1. Direct buried, uninsulated steel pipe shall have a factory applied external protective coating consisting of two coats with an intermediate layer of 18 mil fibrous glass mat. Coating thickness shall total not less than 3/32". The outer coating shall be further protected by a wrapping of heavy Kraft paper. This external protection shall extend and be exposed for a minimum of 1 foot beyond the buried or concealed portion of the pipe.
 - 2. As an option, the Contractor may provide factory applied protective coatings consisting of a polyethylene plastic film bonded to the pipe surface by a hot applied thermo-plastic adhesive.
 - a. Manufacturer:
 - 1) Republic Steel Corp. "X-Tru-Coat"
 - 3. Exercise care in handling, storing and laying pipe to avoid damaging factory applied coatings. If any damage occurs, repair the coating to a condition equal to the original.
 - 4. Field application of protective coatings to joints, fittings and to any damaged factory applied coatings shall be similar to factory applied coatings specified above and shall be done in strict accordance with recommendations of the supplier of pipe coatings.
 - 5. After completion of the fabrication, laying and field coating of the joints and fittings, but prior to backfilling, inspect the entire line in the presence of the Architect/Engineer's representative with an electronic holiday detector. Any defects in the protective coatings shall be repaired in accordance with requirements for original coatings.
 - 6. Coat flange bolts and nuts in pits and below ground at the time of installation with a corrosion protective coating.
- U. All vertical pipe drops to equipment installed below the ceiling shall be routed within a wall cavity, unless specifically noted otherwise to be surface mounted. For renovation projects, this Contractor is responsible for opening and patching existing walls for installation of piping. Wall patching shall match existing condition.
- V. Install underground plastic pipe with an electrically continuous corrosion-resistant tracer wire (minimum AWG 14) or tape per section 22 05 53 to facilitate locating. One end of the tracer wire or tape shall be brought aboveground at a building wall or riser.
- W. Install corrugated, stainless steel tubing system according to manufacturer's written instructions. Include striker plates to protect tubing from puncture where tubing is restrained and cannot move.

- X. Install underground, sleeved, corrugated, stainless steel tubing system according to manufacturer's written instructions. Extend vent from sleeve to exterior of building and terminate with screened elbow.

3.5 BONDING AND GROUNDING

- A. Each above ground portion of a corrugated stainless steel tubing gas piping systems shall be bonded to the electrical service grounding electrode system. The bonding jumper shall connect to a metallic pipe or fitting between the point of delivery and the first downstream corrugated stainless steel tube fitting. The bonding jumper shall not be smaller than 6 AWG copper wire or equivalent. Gas piping systems that contain one or more segments of corrugated stainless steel tubing shall be bonded in accordance with this section.
- B. Each above ground portion of a gas piping system, other than corrugated stainless steel tubing systems, that is likely to become energized shall be electrically continuous and bonded to an effective ground-fault current path. Gas piping, other than corrugated stainless steel tubing, shall be considered to be bonded when it is connected to appliances that are connected to the appliance grounding conductor of the circuit supplying that appliance.
- C. Gas piping shall not be used as a grounding conductor or electrode.
- D. Where a lightning protection system is installed, the bonding of the gas piping shall be in accordance with NFPA 780, Standard for the Installation of Lightning Protection Systems.

3.6 PIPE ERECTION AND LAYING

- A. Carefully inspect all pipe, fittings, valves, equipment and accessories prior to installation. Immediately reject and remove from the job any items which are unsuitable, cracked or otherwise defective.
- B. All pipe, fittings, valves, equipment and accessories shall have factory-applied markings, stampings, or nameplates sufficient to determine their conformance with specified requirements.
- C. Exercise care at every stage of storage, handling, laying and erecting to prevent entry of foreign matter into piping, fittings, valves, equipment and accessories. Do not erect or install any unclean item.
- D. During construction, until system is fully operational, keep all openings in piping and equipment closed at all times except when actual work is being performed on that item. Closures shall be plugs, caps, blind flanges or other items designed for this purpose.
- E. Change direction of pipes only with fittings or pipe bends. Change size only with fittings. Do not use miter fittings, face or flush bushings, or street elbows. All fittings shall be long radius type, unless otherwise shown on the drawings or specified. Construct welded elbows of angles not available as standard fittings by cutting and welding standard elbows to form smooth, long radius fittings.
- F. Use full and double lengths of pipe wherever possible.
- G. Cut all pipe to exact measurement and install without springing or forcing.

- H. Do not create, even temporarily, undue loads, forces or strains on valves, equipment or building elements.
- I. Underground pipe shall be laid in dry trenches maintained free of accumulated water. Provide and operate sufficient pumping equipment to maintain excavations, trenches and pits free of water. Dispose of pumped water so operation areas and other facilities are not flooded. Pipe laying shall follow excavating as closely as possible.

3.7 DRAINING AND VENTING

- A. Unless otherwise indicated on the drawings, all horizontal pipes, including branches, shall pitch 1" in 40 feet to low points for complete drainage.
- B. Use eccentric reducing fittings on horizontal runs when changing size for proper drainage and venting. Install gas pipes with bottom of pipe and eccentric reducers in a continuous line.
- C. Provide drip legs at low points and at the base of all risers in gas pipes. Drip legs shall be full line size on pipes through 4" and at least 4", but not less than half line size over 4". Drip legs shall be 12" minimum length, capped with a reducer to a drain valve.

3.8 BRANCH CONNECTIONS

- A. Make branch connections with standard tee or cross fittings of the type required for the service unless otherwise specified herein or detailed on the drawings.
- B. At the option of the Contractor, branch connections from headers and mains may be cut into black steel pipe using forged weld-on fittings.
- C. Use of forged weld-on fittings is also limited as follows:
 - 1. Must have at least same pressure rating as the main.
 - 2. Header or main must be 2-1/2" or over.
 - 3. Branch line is at least two pipe sizes under header or main size.
- D. Reducers are generally not shown. Where pipe sizes change at tee, the tee shall be the size of the largest pipe shown connecting to it.
- E. All branch piping connections for natural gas shall take off on the top or on the side of the main.

3.9 JOINING OF PIPE

- A. Threaded Joints:
 - 1. Ream pipe ends and remove all burrs and chips.
 - 2. Protect plated pipe and valve bodies from wrench marks when making up joints.
 - 3. Apply Teflon tape to male threads.
- B. Flanged Joints:
 - 1. Steel flanges shall be raised face.

2. Bolting for services up to 500°F shall be ASTM A307 Grade B with square head bolts and heavy hexagonal nuts conforming to ANSI B18.2.1 "Square and Hex Bolts" and B18.2.2 "Square and Hex Nuts".
3. Torque bolts in at least three passes, tightening to 1/3, 2/3, and final torque in a cross pattern with an indicating torque wrench for equal tension in all bolts.
4. Gaskets for flat face flanges shall be full face type. Gaskets for raised faced flanges shall conform to requirements for "Group I Gaskets" in ANSI B16.5. Unless otherwise specified gaskets shall meet the following requirements:
 - a. Gasket material and thickness approved by manufacturer for intended service, chemical compatibility, pipe system test pressure, and operating temperature range.
 - b. Maximum pressure rating of at least 250 psig.
 - c. Minimum temperature rating: -10°F.
 - d. Maximum temperature rating of at least 170°F for water systems operating 140°F and less.

C. Welded Joints:

1. Welding of all pipe joints, both as to procedures and qualification of welders, shall be in accordance with Section IX, ASME "Boiler & Pressure Vessel Code" unless local codes take precedence.
2. Furnish certificates qualifying each welder to the Owner's Representative prior to start of work.
3. The Owner's Representative reserves the right to require qualifying demonstration, at the Contractor's expense, of any welders assigned to the job.
4. Ends of pipe and fittings to be joined by butt-welding shall be beveled, cleaned to bare metal and internal diameters aligned before tack welding.

D. Fusion Weld:

1. Make all field cuts of pipe square and true using a pipe cutter designed for plastic pipe.
2. Make sure proper heating heads are used for male and female situations.
3. Bevel the leading edge of pipe section with a 45° chamfer.
4. Utilize a fusion welding tool recommended and/or provided by the pipe and fitting manufacturer.
5. Not recommended for temperatures below 40°F.
6. Follow the manufacturer's cold weather installation procedures.
7. All installers shall undergo training provided by the manufacturer or manufacturer's representative.
8. Follow all manufacturers' installation instructions.

END OF SECTION 22 10 23

SECTION 23 05 00 - BASIC HVAC REQUIREMENTS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Requirements applicable to all Division 23 Sections. Also refer to Division 01 - General Requirements.
- B. All materials and installation methods shall conform to the applicable standards, guidelines and codes referenced herein and within each specification section.

1.2 SCOPE OF WORK

- A. This Specification and the associated drawings govern the furnishing, installing, testing and placing into satisfactory operation the Mechanical Systems.
- B. Each Contractor shall provide all new materials indicated on the drawings and/or in these specifications, and all items required to make the portion of the Mechanical Work a finished and working system.
- C. Separate contracts will be awarded for the following work:
- D. All work will be awarded under a single General Contract. The division of work listed below is for the Contractor's convenience and lists normal breakdown of the work.
- E. Separate contracts will be awarded for the following work. The division of work listed below is for the contractors' convenience and lists a normal breakdown of the work. Please refer to the Construction Manager's scope statements for complete scope of work description.
- F. Scope of Work:
 - 1. Plumbing Work: Refer to Section 22 05 00 "Basic Plumbing Requirements".
 - 2. Heating Work shall include, but is not necessarily limited to:
 - a. Furnish and install heating hydronic boilers and accessories.
 - b. Furnish and install a complete heating water system including pumps, piping, insulation, air control equipment, terminal heating equipment, and specialties. Make final connections to all coils, including those furnished by others.
 - c. Furnish and install firestopping systems for penetrations of fire-rated construction associated with this Contractor's work.
 - 3. Air Conditioning and Ventilating Work shall include, but is not necessarily limited to:
 - a. Furnish and install gas flues, stacks, and breechings.
 - b. Furnish and install all temperature control systems.
 - c. Furnish and install all fire dampers.
 - d. Furnish and install firestopping systems for penetrations of fire-rated construction associated with this Contractor's work.

4. Temperature Control Work shall include, but is not necessarily limited to:
 - a. Furnish and install a complete temperature control system as specified in Section 23 09 00.
 - b. Temperature control system shall consist of a full Direct Digital Control (DDC) system including all accessories, sensors, and programming.
 - c. Furnish and install firestopping systems for penetrations of fire-rated construction associated with this Contractor's work.
5. Testing, Adjusting, and Balancing Work shall include, but is not necessarily limited to:
 - a. Furnish complete testing, adjusting, and balancing as specified in Section 23 05 93, including, but not limited to, air systems, hydronic systems, plumbing systems, and verification of control systems.

1.3 WORK SEQUENCE

- A. All work that will produce excessive noise or interference with normal building operations, as determined by the Owner, shall be scheduled with the Owner. It may be necessary to schedule such work during unoccupied hours. The Owner reserves the right to determine when restricted construction hours will be required.
- B. Itemize all work and list associated hours and pay scale for each item.

1.4 DIVISION OF WORK BETWEEN MECHANICAL, ELECTRICAL & CONTROL CONTRACTORS

A. Definitions:

1. "Mechanical Contractors" refers to the following:
 - a. Plumbing Contractor.
 - b. Heating Contractor.
 - c. Air Conditioning and Ventilating Contractor.
 - d. Temperature Control Contractor.
 - e. Fire Protection Contractor.
 - f. Testing, Adjusting, and Balancing Contractor.
2. Motor Control Wiring: The wiring associated with the remote operation of the magnetic coils of magnetic motor starters or relays, or the wiring that permits direct cycling of motors by means of devices in series with the motor power wiring. In the latter case the devices are usually single phase and are usually connected to the motor power wiring through a manual motor starter having "Manual-Off-Auto" provisions.
3. Control devices such as start-stop push buttons, thermostats, pressure switches, flow switches, relays, etc., generally represent the types of equipment associated with motor control wiring.
4. Motor control wiring is single phase and usually 120 volts. In some instances, the voltage will be the same as the motor power wiring. Generally, where the motor power wiring exceeds 120 volts, a control transformer is used to give a control voltage of 120 volts.

5. Temperature Control Wiring: The wiring associated with the operation of a motorized damper, solenoid valve or motorized valve, etc., either modulating or two-position, as opposed to wiring which directly powers or controls a motor used to drive equipment such as fans, pumps, etc.
 - a. This wiring will be from a 120 volt source and may continue as 120 volt, or be reduced in voltage (24 volt) in which case a control transformer shall be furnished as part of the temperature control wiring.
6. Control Motor: An electric device used to operate dampers, valves, etc. It may be two-position or modulating. Conventional characteristics of such a motor are 24 volts, 60 cycles, 1 phase, although other voltages may be encountered.
7. Voltage is generally specified and scheduled as distribution voltage. Motor submittals may be based on utilization voltage if it corresponds to the correct distribution voltage.

Distribution/Nominal Voltage	Utilization Voltage
120	115
208	200
240	230
277	265
480	460

B. General:

1. The purpose of these Specifications is to outline the Electrical and Mechanical Contractor's responsibilities related to electrical work required for items such as temperature controls, mechanical equipment, fans, chillers, compressors and the like. The exact wiring requirements for much of the equipment cannot be determined until the systems have been selected and submittals reviewed. Therefore, the electrical drawings show only known wiring related to such items. All wiring not shown on the electrical drawings, but required for mechanical systems, is the responsibility of the Mechanical Contractor.
2. Where the drawings require the Electrical Contractor to wire between equipment furnished by the Mechanical Contractor, such wiring shall terminate at terminals provided in the equipment. The Mechanical Contractor shall provide complete electrical power/controls wiring diagrams and supervision to the Electrical Contractor and designate the terminal numbers for correct wiring.
3. All electrical work shall conform to the National Electrical Code. All provisions of the Electrical Specifications concerning wiring, protection, etc., apply to wiring provided by the Mechanical Contractor unless noted otherwise.
4. Control low (24V) and control line (120V) voltage wiring, conduit, and related switches and relays required for the automatic control and/or interlock of motors and equipment, including final connection, are to be furnished and installed under Divisions 21, 22 and 23. Materials and installation to conform to Class 1 or 2 requirements.
5. All Contractors shall establish utility elevations prior to fabrication and shall coordinate their material and equipment with other trades. When a conflict arises, priority is as follows:
 - a. Light fixtures.

- b. Gravity flow piping, including steam and condensate.
- c. Electrical busduct.
- d. Sheet metal.
- e. Electrical cable trays, including access space.
- f. Sprinkler piping and other piping.
- g. Electrical conduits and wireway.

C. Mechanical Contractor's Responsibility:

1. Assumes responsibility for internal wiring of all equipment provided by the Mechanical Contractor, for example:
 - a. Boiler Feed Pumps.
 - b. Burners.
2. Assumes all responsibility for the Temperature Control wiring, when the Temperature Control Contractor is a Subcontractor to the Mechanical Contractor.
3. Shall verify all existing equipment sizes and capacities where units are to be modified, moved or replaced. Contractor shall notify Architect/Engineer of any discrepancies prior to ordering new units or replacement parts, including replacements of equipment motors.
4. Temperature Control Subcontractor's Responsibility:
 - a. Wiring of all devices needed to make the Temperature Control System functional.
 - b. Verifying any control wiring on the electrical drawings as being by the Electrical Contractor. All wiring required for the Control System, but not shown on the electrical drawings, is the responsibility of the Temperature Control Subcontractor.
 - c. Coordinating equipment locations (such as relays, transformers, etc.) with the Electrical Contractor, where wiring of the equipment is by the Electrical Contractor.
5. This Contractor is responsible for coordination of utilities with all other Contractors. If any field coordination conflicts are found, the Contractor shall coordinate with other Contractors to determine a viable layout.

D. Electrical Contractor's Responsibility:

1. Provides all combination starters, manual starters and disconnect devices shown on the Electrical Drawings or indicated to be by the Electrical Contractor on the Mechanical Drawings or Specifications.
2. Installs and wires all remote control devices furnished by the Mechanical Contractor or Temperature Control Subcontractor when so noted on the Electrical Drawings.
3. Provides motor control and temperature control wiring, where so noted on the drawings.
4. Coordinate with the Mechanical Contractor for size of motors and/or other electrical devices involved with repair or replacement of existing equipment.
5. Furnishes, installs and connects all relays, etc., for automatic shutdown of certain fans upon actuation of the Fire Alarm System as indicated and specified in Division 28.
6. This Contractor is responsible for coordination of utilities with all other Contractors. If any field coordination conflicts are found, the Contractor shall coordinate with other Contractors to determine a viable layout.

1.5 QUALITY ASSURANCE

A. Contractor's Responsibility Prior to Submitting Pricing Data:

1. The Contractor is responsible for constructing complete and operating systems. The Contractor acknowledges and understands that the Contract Documents are a two-dimensional representation of a three-dimensional object, subject to human interpretation. This representation may include imperfect data, interpreted codes, utility guidelines, three-dimensional conflicts, and required field coordination items. Such deficiencies can be corrected when identified prior to ordering material and starting installation. The Contractor agrees to carefully study and compare the individual Contract Documents and report at once in writing to the Design Team any deficiencies the Contractor may discover. The Contractor further agrees to require each subcontractor to likewise study the documents and report at once any deficiencies discovered.
2. The Contractor shall resolve all reported deficiencies with the Architect/Engineer prior to awarding any subcontracts, ordering material, or starting any work with the Contractor's own employees. Any work performed prior to receipt of instructions from the Design Team will be done at the Contractor's risk.

B. Qualifications:

1. Only products of reputable manufacturers are acceptable.
2. All Contractors and subcontractors shall employ only workers skilled in their trades.

C. Compliance with Codes, Laws, Ordinances:

1. Conform to all requirements of the State of Colorado Codes, Laws, Ordinances and other regulations having jurisdiction.
2. Conform to all published standards of Poudre School District.
3. Conform to all State Codes.
4. If there is a discrepancy between the codes and regulations and these specifications, the Architect/Engineer shall determine the method or equipment used.
5. If the Contractor notes, at the time of bidding, that any parts of the drawings or specifications do not comply with the codes or regulations, Contractor shall inform the Architect/Engineer in writing, requesting a clarification. If there is insufficient time for this procedure, Contractor shall submit with the proposal a separate price to make the system comply with the codes and regulations.
6. All changes to the system made after letting of the contract, to comply with codes or requirements of Inspectors, shall be made by the Contractor without cost to the Owner.
7. If there is a discrepancy between manufacturer's recommendations and these specifications, the manufacturer's recommendations shall govern.
8. All rotating shafts and/or equipment shall be completely guarded from all contact. Partial guards and/or guards that do not meet all applicable OSHA standards are not acceptable. Contractor is responsible for providing this guarding if it is not provided with the equipment supplied.

D. Permits, Fees, Taxes, Inspections:

1. Procure all applicable permits and licenses.

2. Abide by all laws, regulations, ordinances, and other rules of the State or Political Subdivision where the work is done, or as required by any duly constituted public authority.
3. Pay all charges for permits or licenses.
4. Pay all fees and taxes imposed by the State, Municipal and/or other regulatory bodies.
5. Pay all charges arising out of required inspections by an authorized body.
6. Pay all charges arising out of required contract document reviews associated with the project and as initiated by the Owner or authorized agency/consultant.
7. Where applicable, all fixtures, equipment and materials shall be listed by Underwriters' Laboratories, Inc. and approved by FM Global.

E. Utility Company Requirements:

1. Secure from the appropriate private or public utility company all applicable requirements.
2. Comply with all utility company requirements.
3. Make application for and pay for service connections, such as gas.
4. Make application for and pay for all meters and metering systems required by the utility company.

F. Examination of Drawings:

1. The drawings for the mechanical work are completely diagrammatic, intended to convey the scope of the work and to indicate the general arrangements and locations of equipment, outlets, etc., and the approximate sizes of equipment.
2. Contractor shall determine the exact locations of equipment and rough-ins, and the exact routing of pipes and ducts to best fit the layout of the job.
3. Scaling of the drawings is not sufficient or accurate for determining these locations.
4. Where job conditions require reasonable changes in indicated arrangements and locations, such changes shall be made by the Contractor at no additional cost to the Owner.
5. Because of the scale of the drawings, certain basic items, such as fittings, boxes, valves, unions, etc., may not be shown, but where required by other sections of the specifications or required for proper installation of the work, such items shall be furnished and installed.
6. If an item is either on the drawings or in the specifications, it shall be included in this contract.
7. Determination of quantities of material and equipment required shall be made by the Contractor from the documents. Where discrepancies arise between drawings, schedules and/or specifications, the greater number shall govern.
8. Where used in mechanical documents, the word "furnish" shall mean supply for use, the word "install" shall mean connect complete and ready for operation, and the word "provide" shall mean to supply for use and connect complete and ready for operation.
 - a. Any item listed as furnished shall also be installed, unless otherwise noted.
 - b. Any item listed as installed shall also be furnished, unless otherwise noted.

G. Field Measurements:

1. Verify all pertinent dimensions at the job site before ordering any materials or fabricating any supports, pipes or ducts.

H. Electronic Media/Files:

1. Construction drawings for this project have been prepared utilizing Revit.
2. Contractors and Subcontractors may request electronic media files of the contract drawings and/or copies of the specifications. Specifications will be provided in PDF format.
3. Upon request for electronic media, the Contractor shall complete and return a signed "Electronic File Transmittal" form provided by IMEG.
4. If the information requested includes floor plans prepared by others, the Contractor will be responsible for obtaining approval from the appropriate Design Professional for use of that part of the document.
5. The electronic contract documents can be used for preparation of shop drawings and as-built drawings only. The information may not be used in whole or in part for any other project.
6. The drawings prepared by IMEG for bidding purposes may not be used directly for ductwork layout drawings or coordination drawings.
7. The use of these CAD documents by the Contractor does not relieve them from their responsibility for coordination of work with other trades and verification of space available for the installation.
8. The information is provided to expedite the project and assist the Contractor with no guarantee by IMEG as to the accuracy or correctness of the information provided. IMEG accepts no responsibility or liability for the Contractor's use of these documents.

1.6 SUBMITTALS

- A. Submittals shall be required for the following items, and for additional items where required elsewhere in the specifications or on the drawings.

1. Submittals List:

Referenced Specification Section	Submittal Item
23 05 00	Owner Training Agenda
23 05 03	Fire Seal Systems
23 05 13	Motors
23 05 15	Variable Frequency Drives
23 05 29	Hangers and Supports
23 05 48	Vibration Isolation Equipment
23 05 53	HVAC Identification
23 05 93	Testing, Adjusting, and Balancing
23 07 19	HVAC Pipe Insulation
23 09 00	Controls
23 09 13	Instrumentation
23 21 00	Hydronic Piping Systems and Valves
23 21 23	HVAC Pumps
23 52 16	Condensing Boilers

- B. General Submittal Procedures: In addition to the provisions of Division 01, the following are required:
1. Transmittal: Each transmittal shall include the following:
 - a. Date
 - b. Project title and number
 - c. Contractor's name and address
 - d. Division of work (e.g., plumbing, heating, ventilating, etc.)
 - e. Description of items submitted and relevant specification number
 - f. Notations of deviations from the contract documents
 - g. Other pertinent data
 2. Submittal Cover Sheet: Each submittal shall include a cover sheet containing:
 - a. Date
 - b. Project title and number
 - c. Architect/Engineer
 - d. Contractor and subcontractors' names and addresses
 - e. Supplier and manufacturer's names and addresses
 - f. Division of work (e.g., plumbing, heating, ventilating, etc.)
 - g. Description of item submitted (using project nomenclature) and relevant specification number
 - h. Notations of deviations from the contract documents
 - i. Other pertinent data
 - j. Provide space for Contractor's review stamps
 3. Composition:
 - a. Submittals shall be submitted using specification sections and the project nomenclature for each item.
 - b. Individual submittal packages shall be prepared for items in each specification section. All items within a single specification section shall be packaged together where possible. An individual submittal may contain items from multiple specifications sections if the items are intimately linked (e.g., pumps and motors).
 - c. All sets shall contain an index of the items enclosed with a general topic description on the cover.
 4. Content: Submittals shall include all fabrication, erection, layout, and setting drawings; manufacturers' standard drawings; schedules; descriptive literature, catalogs and brochures; performance and test data; electrical power criteria (e.g., voltage, phase, amps, horsepower, kW, etc.) wiring and control diagrams; Short Circuit Current Rating (SCCR); dimensions; shipping and operating weights; shipping splits; service clearances; and all other drawings and descriptive data of materials of construction as may be required to show that the materials, equipment or systems and the location thereof conform to the requirements of the contract documents.
 5. Contractor's Approval Stamp:
 - a. The Contractor shall thoroughly review and approve all shop drawings before submitting them to the Architect/Engineer. The Contractor shall stamp, date and sign each submittal certifying it has been reviewed.

- b. Unstamped submittals will be rejected.
 - c. The Contractor's review shall include, but not be limited to, verification of the following:
 - 1) Only approved manufacturers are used.
 - 2) Addenda items have been incorporated.
 - 3) Catalog numbers and options match those specified.
 - 4) Performance data matches that specified.
 - 5) Electrical characteristics and loads match those specified.
 - 6) Equipment connection locations, sizes, capacities, etc. have been coordinated with other affected trades.
 - 7) Dimensions and service clearances are suitable for the intended location.
 - 8) Equipment dimensions are coordinated with support steel, housekeeping pads, openings, etc.
 - 9) Constructability issues are resolved (e.g., weights and dimensions are suitable for getting the item into the building and into place, sinks fit into countertops, etc.).
 - d. The Contractor shall review, stamp and approve all subcontractors' submittals as described above.
 - e. The Contractor's approval stamp is required on all submittals. Approval will indicate the Contractor's review of all material and a complete understanding of exactly what is to be furnished. Contractor shall clearly mark all deviations from the contract documents on all submittals. If deviations are not marked by the Contractor, then the item shall be required to meet all drawing and specification requirements.
6. Submittal Identification and Markings:
- a. The Contractor shall clearly mark each item with the same nomenclature applied on the drawings or in the specifications.
 - b. The Contractor shall clearly indicate the size, finish, material, etc.
 - c. Where more than one model is shown on a manufacturer's sheet, the Contractor shall clearly indicate exactly which item and which data is intended.
 - d. All marks and identifications on the submittals shall be unambiguous.
- 7. Schedule submittals to expedite the project. Coordinate submission of related items.
 - 8. Identify variations from the contract documents and product or system limitations that may be detrimental to the successful performance of the completed work.
 - 9. Reproduction of contract documents alone is not acceptable for submittals.
 - 10. Incomplete submittals will be rejected without review. Partial submittals will only be reviewed with prior approval from the Architect/Engineer.
 - 11. Submittals not required by the contract documents may be returned without review.
 - 12. The Architect/Engineer's responsibility shall be to review one set of shop drawing submittals for each product. If the first submittal is incomplete or does not comply with the drawings and/or specifications, the Contractor shall be responsible to bear the cost for the Architect/Engineer to recheck and handle the additional shop drawing submittals.
 - 13. Submittals shall be reviewed and approved by the Architect/Engineer before releasing any equipment for manufacture or shipment.
 - 14. Contractor's responsibility for errors, omissions, or deviation from the contract documents in submittals is not relieved by the Architect/Engineer's approval.

15. Schedule shall allow for adequate time to perform orderly and proper review of submittals, including time for consultants and Owner if required, and resubmittals by Contractor if necessary, and to cause no delay in Work or in activities of Owner or other contractors.
 - a. Allow at least two weeks for ArchitectTMs/Engineer's review and processing of each submittal, excluding mailing.
16. Architect/Engineer reserves the right to withhold action on a submittal which, in the Architect/EngineerTMs opinion, requires coordination with other submittals until related submittals are received. The Architect/Engineer will notify the Contractor, in writing, when they exercise this right.

C. Electronic Submittal Procedures:

1. Distribution: Email submittals as attachments to all parties designated by the Architect/Engineer, unless a web-based submittal program is used.
2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.
3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. Submittal file name: 23 XX XX.description.YYYYMMDD
 - b. Transmittal file name: 23 XX XX.description.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.

1.7 SCHEDULE OF VALUES

A. The requirements herein are in addition to the provisions of Division 01.

B. Format:

1. Use AIA Document Continuation Sheets G703 or another similar form approved by the Owner and Architect/Engineer.
2. Submit in Excel format.
3. Support values given with substantiating data.

C. Preparation:

1. Itemize work required by each specification section and list all providers. All work provided by subcontractors and major suppliers shall be listed on the Schedule of Values. List each subcontractor and supplier by company name.

2. Break down all costs into:
 - a. Material: Delivered cost of product with taxes paid.
 - b. Labor: Labor cost, excluding overhead and profit.
3. Itemize the cost for each of the following:
 - a. Overhead and profit.
 - b. Bonds.
 - c. Insurance.
 - d. General Requirements: Itemize all requirements.
4. For each line item having an installed cost of more than \$5,000, break down costs to list major products or operations under each item. At a minimum, provide material and labor cost line items for the following:
 - a. Each piece of equipment requiring shop drawings (e.g., each air handling unit, pump, exhaust fan, etc.). Use the equipment nomenclature (AHU-1, P-1, EF-1, etc.) on the Schedule of Values.
 - b. Each type of small unitary equipment (e.g., FCUs, UHs, CABs, etc.). Multiple units of the same type can be listed together, provided quantities are also listed so unit costs can be determined.
 - c. Each piping system (chilled water, heating water, steam, condensate, etc.). In addition, for larger projects, break down the material and labor for each piping system based on geography (building, floor, and/or wing).
 - d. Each duct system (supply, return, relief, outside air, etc.) listed separately for each unit they serve (AHU-1 supply air ductwork, AHU-1 return air ductwork, etc.).
 - e. Pipe insulation with separate material and labor line items for each piping system listed above.
 - f. Duct insulation with separate material and labor line items for each duct system listed above.
 - g. Temperature controls broken down into material and labor for the following:
 - 1) Engineering
 - 2) Controllers, devices, sensors, etc.
 - 3) Control valves
 - 4) Control dampers
 - 5) Conduit
 - 6) Wiring
 - 7) Programming
 - 8) Commissioning
 - h. Site utilities (5' beyond building)
 - i. Seismic design
 - j. Air balancing
 - k. Water balancing
 - l. Commissioning
 - m. Record drawings
 - n. Punchlist and closeout

- D. Update Schedule of Values when:
 - 1. Indicated by Architect/Engineer.
 - 2. Change of subcontractor or supplier occurs.
 - 3. Change of product or equipment occurs.

1.8 CHANGE ORDERS

- A. A detailed material and labor takeoff shall be prepared for each change order, along with labor rates and markup percentages. Change orders shall be broken down by sheet or associated individual line item indicated in the change associated narrative, whichever provides the most detailed breakdown. Change orders with inadequate breakdown will be rejected.
- B. Itemized pricing with unit cost shall be provided from all distributors and associated subcontractors.
- C. Change order work shall not proceed until authorized.

1.9 EQUIPMENT SUPPLIERS' INSPECTION

- A. The following equipment shall not be placed in operation until a competent installation and service representative of the manufacturer has inspected the installation and certified that the equipment is properly installed, adjusted and lubricated; that preliminary operating instructions have been given; and that the equipment is ready for operation:
 - 1. Boilers, Burners and Boiler Trim
 - 2. Fire Seal Systems
- B. Contractor shall arrange for and obtain supplier's on-site inspection(s) at proper time(s) to assure each phase of equipment installation and/or connection is in accordance with the manufacturer's instructions.
- C. Submit copies of start-up reports to the Architect/Engineer and include copies of Owner's Operation and Maintenance Manuals.

1.10 PRODUCT DELIVERY, STORAGE, HANDLING & MAINTENANCE

- A. Exercise care in transporting and handling to avoid damage to materials. Store materials on the site to prevent damage. Keep materials clean, dry and free from harmful conditions. Immediately remove any materials that become wet or that are suspected of becoming contaminated with mold or other organisms.
- B. Keep all bearings properly lubricated and all belts properly tensioned and aligned.
- C. Coordinate the installation of heavy and large equipment with the General Contractor and/or Owner. If the Mechanical Contractor does not have prior documented experience in rigging and lifting similar equipment, he/she shall contract with a qualified lifting and rigging service that has similar documented experience. Follow all equipment lifting and support guidelines for handling and moving.

- D. Contractor is responsible for moving equipment into the building and/or site. Contractor shall review site prior to bid for path locations and any required building modifications to allow movement of equipment. Contractor shall coordinate the work with other trades.

1.11 NETWORK / INTERNET CONNECTED EQUIPMENT

- A. These specifications may require certain equipment or systems to have network, Internet and/or remote access capability ("Network Capability"). Any requirement for Network Capability shall be interpreted only as a functional capability and is not to be construed as authority to connect or enable any Network Capability. Network Capability may only be connected or enabled with the express written consent of the Owner.

1.12 WARRANTY

- A. Provide one-year warranty, unless otherwise noted, to the Owner for all fixtures, equipment, materials, and workmanship.
- B. The warranty period for all work in this Division of the specifications shall commence on the date of final acceptance, unless a whole or partial system or any separate piece of equipment or component is put into use for the benefit of any party other than the installing contractor with prior written authorization. In this instance, the warranty period shall commence on the date when such whole system, partial system or separate piece of equipment or component is placed in operation and accepted in writing by the Owner.
- C. Warranty requirements shall extend to correction, without cost to the Owner, of all Work found to be defective or nonconforming to the contract documents. The Contractor shall bear the cost of correcting all damage resulting from defects or nonconformance with contract documents.

1.13 INSURANCE

- A. Contractor shall maintain insurance coverage as set forth in Division 0 of these specifications.

1.14 CONTINGENCY

- A. Include in the Base Bid a contingency of 5% percent to be used only by change orders issued by the Architect/Engineer. The unused portion of the contingency shall be deducted from the Contract price before final payment is made.

1.15 MATERIAL SUBSTITUTION

- A. Where several manufacturers' names are given, the scheduled manufacturer is the basis for job design and establishes the quality required.
- B. Equivalent equipment manufactured by the other listed manufacturers may be used. Contractor shall ensure that all items submitted by these other manufacturers meet all requirements of the drawings and specifications and fits in the allocated space. When using other listed manufacturers, the Contractor shall assume responsibility for any and all modifications necessary (including, but not limited to structural supports, electrical connections, piping and ductwork connections and arrangement, plumbing connections and rough-in, and regulatory agency approval, etc.) and coordinate such with other contractors.

- C. Any material, article or equipment of other unnamed manufacturers which will adequately perform the services and duties imposed by the design and is of a quality equal to or better than the material, article or equipment identified by the drawings and specifications may be used if approval is secured in writing from the Architect/Engineer not later than ten days prior to the bid opening.
- D. This Contractor assumes all costs incurred as a result of using the offered material, article or equipment, on the Contractors part or on the part of other Contractors whose work is affected.
- E. This Contractor may list voluntary add or deduct prices for alternate materials on the bid form. These items will not be used in determining the low bidder.
- F. All material substitutions requested later than ten (10) days prior to bid opening must be listed as voluntary changes on the bid form.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION

3.1 JOBSITE SAFETY

- A. Neither the professional activities of the Architect/Engineer, nor the presence of the Architect/Engineer or the employees and subconsultants at a construction site, shall relieve the Contractor and other entity of their obligations, duties and responsibilities including, but not limited to, construction means, methods, sequence, techniques or procedures necessary for performing, superintending or coordinating all portions of the work of construction in accordance with the contract documents and any health or safety precautions required by any regulatory agencies. The Architect/Engineer and personnel have no authority to exercise any control over any construction contractor or other entity or their employees in connection with their work or any health or safety precautions. The Contractor is solely responsible for jobsite safety. The Architect/Engineer and the Architect/Engineer's consultants shall be indemnified and shall be made additional insureds under the Contractor's general liability insurance policy.

3.2 ENGINEER OBSERVATION OF WORK

- A. The Contractor shall provide seven (7) calendar days' notice to the Engineer prior to:
 - 1. Placing fill over underground and underslab utilities.
 - 2. Covering exterior walls, interior partitions and chases.
 - 3. Installing hard or suspended ceilings and soffits.
- B. The Engineer will have the opportunity to review the installation and provide a written report noting deficiencies requiring correction. The Contractor's schedule shall account for these reviews and show them as line items in the approved schedule.
- C. Above-Ceiling Final Observation
 - 1. All work above the ceilings must be complete prior to the Architect/Engineer's review. This includes, but is not limited to:

- a. Pipe insulation is installed and fully sealed.
 - b. Pipe and duct wall penetrations are sealed.
 - c. Pipe identification and valve tags are installed.
 - d. Main, branch and flexible ducts are installed.
 - e. Diffusers, registers and grilles are installed and connected to ductwork.
 - f. Terminal air box reheat coil piping or wiring is complete.
 - g. Terminal air box control wiring is complete and all control boxes are closed.
2. In order to prevent the Above-Ceiling Final Observation from occurring too early, the Contractor shall review the status of the work and certify, in writing, that the work is ready for the Above-Ceiling Final Observation.
 3. It is understood that if the Architect/Engineer finds the ceilings have been installed prior to this review and prior to 7 days elapsing, the Architect/Engineer may not recommend further payments to the contractor until such time as full access has been provided.

3.3 PROJECT CLOSEOUT

- A. The following paragraphs supplement the requirements of Division 01.
- B. IDPH Final Occupancy Checklist for Request of Inspection:
 1. Each Contractor must submit all forms and certifications required by IDPH relating to their work at 85% completion of the project or when directed by the Owner/Architect/Engineer.
- C. Final Jobsite Observation:
 1. In order to prevent the Final Jobsite Observation from occurring too early, the Contractor is required to review the completion status of the project and certify that the job is ready for the final jobsite observation.
 2. Attached to the end of this section is a typical list of items that represent the degree of job completeness expected prior to requesting a review.
 3. Upon Contractor certification that the project is complete and ready for a final observation, the Contractor shall sign the attached certification and return it to the Architect/Engineer so that the final observation can be scheduled.
 4. It is understood that if the Architect/Engineer finds the job not ready for the final observation and that additional trips and observations are required to bring the project to completion, the costs incurred by the Architect/Engineer's additional time and expenses will be deducted from the Contractor's contract retainage prior to final payment at the completion of the job.
- D. Before final payment is authorized, this Contractor must submit the following:
 1. Operation and maintenance manuals with copies of approved shop drawings.
 2. Record documents including [marked-] [reproducible] drawings and specifications.
 3. A report documenting the instructions given to the Owner's representatives complete with the number of hours spent in the instruction. The report shall bear the signature of an authorized agent of This Contractor and shall be signed by the Owner's representatives.
 4. Inspection by State Boiler Inspector.
 5. Start-up reports on all equipment requiring a factory installation inspection or start-up.

6. Provide spare parts, maintenance, and extra materials in quantities specified in individual specification sections. Deliver to project site; receipt by Architect/Engineer required prior to final payment approval.

3.4 OPERATION AND MAINTENANCE MANUALS

A. General:

1. Provide an electronic copy of the O&M manuals as described below for Architect/Engineer's review and approval. The electronic copy shall be corrected as required to address the Architect/Engineer's comments. Once corrected, electronic copies and paper copies shall be distributed as directed by the Architect/Engineer.
2. Approved O&M manuals shall be completed and in the Owner's possession prior to Owner's acceptance and at least 10 days prior to instruction of operating personnel.

B. Electronic Submittal Procedures:

1. Distribution: Email the O&M manual as attachments to all parties designated by the Architect/Engineer.
2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.
3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. O&M file name: O&M.div23.contractor.YYYYMMDD
 - b. Transmittal file name: O&Mtransmittal.div23.contractor.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.
6. Provide the Owner with an approved copy of the O&M manual on compact discs (CD), digital video discs (DVD), or flash drives with a permanently affixed label, printed with the title "Operation and Maintenance Instructions", title of the project and subject matter of disc/flash drive when multiple disc/flash drives are required.
7. All text shall be searchable.
8. Bookmarks shall be used, dividing information first by specification section, then systems, major equipment and finally individual items. All bookmark titles shall include the nomenclature used in the construction documents and shall be an active link to the first page of the section being referenced.

C. Operation and Maintenance Instructions shall include:

1. Title Page: Include title page with project title, Architect, Engineer, Contractor, all subcontractors, and major equipment suppliers, with addresses, telephone numbers, website addresses, email addresses and point of contacts. Website URLs and email addresses shall be active links in the electronic submittal.

2. Table of Contents: Include a table of contents describing specification section, systems, major equipment, and individual items.
3. Copies of all final approved shop drawings and submittals. Include Architect's/Engineer's shop drawing review comments. Insert the individual shop drawing directly after the Operation and Maintenance information for the item(s) in the review form.
4. Refer to Section 23 09 00 for additional requirements for Temperature Control submittals.
5. Copy of final approved test and balance reports.
6. Copies of all factory inspections and/or equipment startup reports.
7. Copies of warranties.
8. Schematic electrical power/controls wiring diagrams of the equipment that have been updated for field conditions. Field wiring shall have label numbers to match drawings.
9. Dimensional drawings of equipment.
10. Capacities and utility consumption of equipment.
11. Detailed parts lists with lists of suppliers.
12. Operating procedures for each system.
13. Maintenance schedule and procedures. Include a chart listing maintenance requirements and frequency.
14. Repair procedures for major components.
15. List of lubricants in all equipment and recommended frequency of lubrication.
16. Instruction books, cards, and manuals furnished with the equipment.

3.5 INSTRUCTING THE OWNER'S REPRESENTATIVES

- A. Adequately instruct the Owner's designated representatives in the maintenance, care, and operation of all systems installed under this contract.
- B. Provide verbal and written instructions to the Owner's representatives by FACTORY PERSONNEL in the care, maintenance, and operation of the equipment and systems.
- C. Contractor shall make a DVD video recording of instructions to the Owner while explaining the system so additional personnel may view the instructions at a later date. The video recording shall be the property of the Owner.
- D. The Owner has the option to make a video recording of all instructions. Coordinate schedule of instructions to facilitate this recording.
- E. The instructions shall include:
 1. Explanation of all system flow diagrams.
 2. Explanation of all air handling systems.
 3. Temperature control system operation including calibration, adjustment and proper operating conditions of all sensors.
 4. Maintenance of equipment.
 5. Smoke control systems.
 6. Stairwell pressurization systems.
 7. Start-up procedures for all major equipment.
 8. Explanation of seasonal system changes.
 9. Description of emergency system operation.

- F. Notify the Architect/Engineer of the time and place for the verbal instructions to be given to the Owner's representative so a representative can attend if desired.
- G. Minimum hours of instruction for each item shall be:
 - 1. Heating Water System - 2 hours.
 - 2. Temperature Controls - As defined in Section 23 09 00.
- H. The Contractor shall prepare a detailed, written training agenda and submit it to the Architect/Engineer a minimum of two weeks prior to the formal training for approval. The written agenda shall include specific training points within the items described above. For example: how to adjust setpoints, troubleshooting, proper start-up, proper shut-down, seasonal changes, draining, venting, changing filters, changing belts, etc. Failure to provide and follow an approved training agenda may result in additional training required at the expense of the Contractor.
- I. Operating Instructions:
 - 1. Contractor is responsible for all instructions to the Owner's representatives for the mechanical and control systems.
 - 2. If the Contractor does not have staff that can adequately provide the required instructions the Contractor shall include in the bid an adequate amount to reimburse the Owner for the Architect/Engineer to perform these services.

3.6 SYSTEM STARTING AND ADJUSTING

- A. The mechanical systems shall be complete and operating. System startup, testing, adjusting, and balancing to obtain satisfactory system performance is the responsibility of the Contractor. This includes calibration and adjustments of all controls, noise level adjustments and final comfort adjustments as required.
- B. Complete all manufacturer-recommended startup procedures and checklists to verify proper motor rotation, electrical power voltage is within equipment limitations, equipment controls maintain pressures and temperatures within acceptable ranges, all filters and protective guards are in-place, acceptable access is provided for maintenance and servicing, and equipment operation does not pose a danger to personnel or property.
- C. Operate all HVAC systems continuously for at least one week prior to occupancy to bring construction materials to suitable moisture levels. Areas with mechanical cooling shall be maintained below 60% RH.
- D. Contractor shall adjust the mechanical systems and controls at season changes during the one year warranty period, as required, to provide satisfactory operation and to prove performance of all systems in all seasons.
- E. All operating conditions and control sequences shall be tested during the start-up period. Test all interlocks, safety shutdowns, controls, and alarms.

- F. The Contractor, subcontractors, and equipment suppliers shall have skilled technicians to ensure that all systems perform properly. If the Architect/Engineer is requested to visit the job site for trouble shooting, assisting in start-up, obtaining satisfactory equipment operation, resolving installation and/or workmanship problems, equipment substitution issues or unsatisfactory system performance, including call backs during the warranty period, through no fault of the design; the Contractor shall reimburse the Owner on a time and materials basis for services rendered at the Architect/Engineer's standard hourly rates in effect when the services are requested. The Contractor shall pay the Owner for services required that are product, installation or workmanship related. Payment is due within 30 days after services are rendered.

3.7 RECORD DOCUMENTS

- A. The following paragraphs supplement Division 01 requirements.
- B. Maintain at the job site a separate and complete set of mechanical drawings and specifications with all changes made to the systems clearly and permanently marked in complete detail.
- C. Mark drawings to indicate revisions to piping and ductwork, size and location, both exterior and interior; including locations of coils, dampers, other control devices, filters, and other units requiring periodic maintenance or repair; actual equipment locations, dimensioned from column lines; actual inverts and locations of underground piping; concealed equipment, dimensioned from column lines; mains and branches of piping systems, with valves and control devices located and numbered, concealed unions located, and with items requiring maintenance located (e.g., traps, strainers, expansion compensators, tanks, etc.); Change Orders; concealed control system devices.
- D. Refer to Section 23 09 00 for additional requirements for Temperature Control documents.
- E. Before completion of the project, a set of reproducible mechanical drawings will be given to the Contractor for transfer of all as-built conditions from the paper set maintained at the job site. All marks on reproducibles shall be clear and permanent.
- F. Mark specifications to show approved substitutions; Change Orders, and actual equipment and materials used.
- G. Record changes daily and keep the marked drawings available for the Architect/Engineer's examination at any normal work time.
- H. Upon completing the job, and before final payment is made, give the marked-up drawings to the Architect/Engineer.

3.8 PAINTING

- A. This Contractor shall paint the following items:
 - 1. All exposed piping.
- B. Paint all equipment that is marred or damaged prior to the Owner's acceptance. Paint and color shall match original equipment paint and shall be obtained from the equipment supplier if available.

- C. Equipment in finished areas that will be painted to match the room decor will be painted by others. Should this Contractor install equipment in a finished area after the area has been painted, the Contractor shall have the equipment and all its supports, hangers, etc., painted to match the room decor.
- D. Equipment cabinets, casings, covers, metal jackets, etc., in equipment rooms or concealed spaces, shall be furnished in standard or prime finish, free from scratches, abrasions, chips, etc.
- E. Equipment in occupied spaces, or if standard to the unit, shall have a baked primer with baked enamel finish coat free from scratches, abrasions, chips, etc. If color option is specified or is standard to the unit, this Contractor shall, before ordering, verify with the Architect/Engineer the color preference and furnish this color.
- F. Paint all equipment in unfinished areas such as boiler room, mechanical spaces, storage room, etc., furnished by this Contractor. Equipment furnished with a factory coat of paint and enamel need not be painted, provided the factory applied finish is not marred or spattered. If so, equipment shall be refinished with the same paint as was factory applied.
- G. Paint all outdoor uninsulated steel piping the color selected by Owner or Architect/Engineer.
- H. After surfaces have been thoroughly cleaned and are free of oil, dirt, and other foreign matter; paint all pipes and equipment with the following:
 - 1. Bare Metal Surfaces - Apply one coat of primer suitable for the metal being painted. Finish with two coats of Alkyd base enamel paint.
 - 2. Insulated Surfaces - Paint insulation jackets with two coats of semi-gloss acrylic latex paint.
 - 3. Color of paint shall be as follows:
 - a. Piping exposed :
 - 1) All Piping: White

3.9 ADJUST AND CLEAN

- A. Thoroughly clean all equipment and systems prior to the Owner's final acceptance of the project. Clean all foreign paint, grease, oil, dirt, labels, stickers, and other foreign material from all equipment.
- B. Clean all drain pans and areas where moisture is present. Immediately report any mold, biological growth, or water damage.
- C. Remove all rust, scale, dirt, oils, stickers and thoroughly clean exterior of all exposed bare metal ductwork, piping, hangers, and accessories.
- D. Remove all rubbish, debris, etc., accumulated during construction from the premises.

3.10 SPECIAL REQUIREMENTS

- A. Contractor shall coordinate the installation of all equipment, valves, dampers, operators, etc., with other trades to maintain clear access area for servicing.

- B. All equipment shall be installed in such a way to maximize access to parts needing service or maintenance. Review the final field location, placement, and orientation of equipment with the Owner's designated representative prior to setting equipment.
- C. Installation of equipment or devices without regard to coordination of access requirements and confirmation with the Owner's designated representative will result in removal and reinstallation of the equipment at the Contractor's expense.

3.11 IAQ MAINTENANCE FOR OCCUPIED FACILITIES UNDER CONSTRUCTION

- A. Contractors shall make all reasonable efforts to prevent construction activities from affecting the air quality of the occupied areas of the building or outdoor areas near the building. These measures shall include, but not be limited to:
 - 1. All contractors shall endeavor to minimize the amount of contaminants generated during construction. Methods to be employed shall include, but not be limited to:
 - a. Minimizing the amount of dust generated.
 - b. Reducing solvent fumes and VOC emissions.
 - c. Maintain good housekeeping practices, including sweeping and periodic dust and debris removal. There should be no visible haze in the air.
 - d. Protect stored on-site and installed absorptive materials from moisture damage.
 - 2. Request that the Owner designate an IAQ representative.
 - 3. Review and receive approval from the Owner's IAQ representative for all IAQ-related construction activities and negative pressure containment plans.
 - 4. Inform the IAQ representative of all conditions that could adversely impact IAQ, including operations that will produce higher than normal dust production or odors.
 - 5. Schedule activities that may cause IAQ conditions that are not acceptable to the Owner's IAQ representative during unoccupied periods.
 - 6. Request copies of and follow all of the Owner's IAQ and infection control policies.
 - 7. Unless no other access is possible, the entrance to construction site shall not be through the existing facility.
 - 8. To minimize growth of infectious organisms, do not permit damp areas in or near the construction area to remain for over 24 hours.
 - 9. In addition to the criteria above, provide measures as recommended in the SMACNA "IAQ Guidelines for Occupied Buildings Under Construction".
 - 10. If permanently installed air handlers are used to serve both construction and occupied areas, all return grilles throughout construction areas shall be sealed to prevent air from construction areas being supplied to occupied areas.
 - 11. If permanently installed air handlers are used during construction to serve only construction areas and do not supply air to adjacent occupied areas, MERV 8 filtration media shall be used to protect each return air grille or opening. The intent of this will be to prevent construction dust and debris from entering any return or supply air ductwork in the facility. All filtration media shall be replaced immediately prior to occupancy.
 - 12. Construction areas shall be maintained at a negative pressure at all times during construction. When areas are under construction, HEPA filtered exhaust fan(s) shall be installed in sufficient quantities as required to maintain construction areas at sufficient negative pressure as called for in the Owner's Infection Control Risk Assessment (ICRA). HEPA filtered exhaust fan discharge shall be ducted either outdoors or back into designated hospital areas as called for in the Owner's ICRA.

13. For each area under construction, the Contractor shall install a negative pressure indicator equivalent to Lamiflow Model L-102F as manufactured by Lamiflow Technologies. Contractor shall regularly monitor and record the negative pressure condition of the construction areas as called for in the Owner's ICRA.

3.12 MAINTAINING CLEAN DUCTWORK THROUGHOUT CONSTRUCTION

- A. Throughout the duration of construction, all ductwork shall be capped or sealed with sheet metal caps, polyethylene film, or other airtight protective to keep dust, dirt, and construction debris out of ducts. Similar means shall be used to seal air-side connections of HVAC equipment to include, but not limited to, air handling units, fans, terminal air boxes, fan coil units, cabinet heaters, blower coils, and the like.
- B. When air terminal devices are installed, contractors shall seal all supply, return, and exhaust grilles with polyethylene film or other airtight protective to keep dust, dirt, and construction debris out of ducts.
- C. Should HVAC equipment be started during construction, Contractor shall remove airtight protectives and shall install one-inch thick MERV 8 filter media over all return and exhaust grilles to prevent dust, dirt, and construction debris from entering ductwork. Filter media shall cover the entire grille face and shall be secured such that air cannot bypass filter media.
- D. Should filter media become laden with dust and dirt, Contractor shall replace filter media with new media to prevent damage to air distribution system and equipment.
- E. The following steps shall be taken during testing, adjusting, and balancing of each air system:
 1. All construction activities in all spaces served by the air system shall stop.
 2. All airtight protectives and temporary filter media shall be removed from all portions of the air system.
 3. Testing, adjusting, and balancing work shall not commence until all construction activity is stopped and all airtight protectives and temporary filter media is removed.
 4. Once testing, adjusting, and balancing work is complete for the air system, airtight protectives or temporary filter media shall be installed over all ductwork openings and air terminals on the air system prior to resuming construction activities in any spaces served by the air system.

END OF SECTION 23 05 00

SECTION 23 05 03 - THROUGH PENETRATION FIRESTOPPING

PART 1 - GENERAL

1.1 REFERENCES

- A. UL 263 - Fire Tests of Building Construction and Materials
- B. UL 723 - Surface Burning Characteristics of Building Materials
- C. ANSI/UL 1479 - Fire Tests of Through Penetration Firestops
- D. UL 2079 - Tests for Fire Resistance of Building Joint Systems
- E. UL Fire Resistance Directory Through Penetration Firestop Systems (XHEZ)
- F. Intertek / Warnock Hersey - Directory of Listed Products
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials
- H. ASTM E814 - Standard Test Method for Fire Tests of Through-Penetration Firestops
- I. The Building Officials and Code Administrators National Building Code
- J. 1997 Uniform Building Code
- K. Wisconsin Administrative Code
- L. 2021 International Building Code
- M. NFPA 5000 - Building Construction Safety Code

1.2 DELIVERY, STORAGE, AND HANDLING

- A. Store, protect and handle products on site. Accept material on site in factory containers and packing. Inspect for damage. Protect from deterioration or damage due to moisture, temperature changes, contaminants, or other causes. Follow manufacturer's instructions for storage.
- B. Install material prior to expiration of product shelf life.

1.3 PERFORMANCE REQUIREMENTS

- A. General: For penetrations through the following fire-resistance-rated constructions, including both empty openings and openings containing penetrating items, provide through-penetration firestop systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of construction penetrated.
 - 1. Fire-resistance-rated walls including fire partitions, fire barriers, and smoke barriers.

2. Fire-resistance-rated horizontal assemblies including floors, floor/ceiling assemblies, and ceiling membranes of roof/ceiling assemblies.

- B. For through-penetration firestop systems exposed to light, traffic, moisture, or physical damage, provide products that, after curing, do not deteriorate when exposed to these conditions both during and after construction.
- C. For through-penetration firestop systems exposed to view, provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E 84.
- D. For through-penetration firestop systems in air plenums, provide products with flame-spread and smoke-developed indexes of less than 25 and 50, respectively, as determined per ASTM E 84.

1.4 MEETINGS

- A. Pre-installation meeting: A pre-installation meeting shall be scheduled and shall include the Construction Manager, General Contractor, all Subcontractors associated with the installation of systems penetrating fire barriers, Firestopping Manufacturer's Representative, and the Owner.
 - 1. Review foreseeable methods related to firestopping work.
 - 2. Tour representative areas where firestopping is to be installed; inspect and discuss each type of condition and each type of substrate that will be encountered, and preparation to be performed by other trades.

1.5 WARRANTY

- A. Provide one year warranty on parts and labor.
- B. Warranty shall cover repair or replacement of firestop systems which fail in joint adhesion, cohesion, abrasion resistance, weather resistance, extrusion resistance, migration resistance, stain resistance, general durability, or appear to deteriorate in any manner not clearly specified by the manufacturer as an inherent quality of the material.

PART 2 - PRODUCTS

Penetrating Item	UL System No.
No Penetrating Item	FC 0000-0999*
Metallic Pipe or Conduit	FC 1000-1999
Non-Metallic Pipe or Conduit	FC 2000-2999
Electrical Cables	FC 3000-3999
Cable Trays	FC 4000-4999
Insulated Pipes	FC 5000-5999
Bus Duct and Misc. Electrical	FC 6000-6999
Duct without Damper and Misc. Mechanical	FC 7000-7999
Multiple Penetrations	FC 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

Penetrating Item	UL System No.
No Penetrating Item	WL 0000-0999*
Metallic Pipe or Conduit	WL 1000-1999
Non-Metallic Pipe or Conduit	WL 2000-2999
Electrical Cables	WL 3000-3999
Cable Trays	WL 4000-4999
Insulated Pipes	WL 5000-5999
Bus Duct and Misc. Electrical	WL 6000-6999
Duct without Damper and Misc. Mechanical	WL 7000-7999
Multiple Penetrations	WL 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

Penetrating Item	UL System No.
No Penetrating Item	CAJ 0000-0999*
Metallic Pipe or Conduit	CAJ 1000-1999
Non-Metallic Pipe or Conduit	CAJ 2000-2999
Electrical Cables	CAJ 3000-3999
Cable Trays	CAJ 4000-4999
Insulated Pipes	CAJ 5000-5999
Bus Duct and Misc. Electrical	CAJ 6000-6999
Duct without Damper and Misc. Mechanical	CAJ 7000-7999
Multiple Penetrations	CAJ 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Ensure all surfaces that contact seal materials are free of dirt, dust, grease, oil, rust, or loose materials. Clean and repair surfaces as required. Remove laitance and form-release agents from concrete.
- B. Ensure substrate and penetrating items have been permanently installed prior to installing firestopping systems. Ensure penetrating items have been properly spaced and have proper clearance prior to installing firestopping systems.
- C. Surfaces to which sealing materials are to be installed must meet the selected UL or Intertek / Warnock Hersey system substrate criteria.
- D. Prime substrates where recommended in writing by through-penetration firestop system manufacturer. Confine primer to area of bond.

3.2 CLEANING AND PROTECTING

- A. Clean excess fill materials adjacent to openings as Work progresses by methods and with cleaning materials that are approved in writing by through-penetration firestop system manufacturers and that do not cause damage.
- B. Provide final protection and maintain conditions during and after installation that ensure that through-penetration firestop systems are without damage or deterioration at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, remove damaged or deteriorated through-penetration firestop systems immediately and install new materials to produce systems complying with specified requirements.

3.3 IDENTIFICATION

- A. Provide and install labels adjacent to each firestopping location. Label shall be provided by the firestop system supplier and contain the following information in a contrasting color:
 - 1. The words "Warning - Through Penetration Firestop System - Do Not Disturb. Notify Building Management of Any Damage."
 - 2. Firestop System Supplier; UL or listed by Intertek / Warnock Hersey system number; date installed; contractor name and phone number; manufacturer's representative name, address, and phone number.

3.4 INSPECTION

- A. All penetrations shall be inspected by the manufacturer's representative to ensure proper installation.
- B. Access to firestop systems shall be maintained for examination by the Authority Having Jurisdiction at their request.
- C. Proceed with enclosing through-penetration firestop system with other construction only after inspection reports are issued and firestop installations comply with requirements.
- D. The contractor shall allow for visual destructive review of 5% of installed firestop systems (minimum of one) to prove compliance with specifications and manufacturer's instructions and details. Destructive system removal shall be performed by the contractor and witnessed by the Architect/Engineer and manufacturer's factory representative. The Architect/Engineer shall have sole discretion of which firestop system installations will be reviewed. The contractor is responsible for all costs associated with this requirement including labor and material for removing and replacing the installed firestop system. If any firestop system is found to not be installed per manufacturer's specific instructions and details, all firestop systems are subject to destructive review and replacement at the Architect/Engineer's discretion and the contractor's expense.

END OF SECTION 23 05 03

SECTION 23 05 05 - HVAC DEMOLITION FOR REMODELING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Mechanical demolition.
- B. Cutting and Patching.

PART 2 - PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- A. Materials and equipment shall be as specified in individual Sections.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. THE DRAWINGS ARE INTENDED TO INDICATE THE GENERAL SCOPE OF WORK AND DO NOT SHOW EVERY PIPE, DUCT, OR PIECE OF EQUIPMENT THAT MUST BE REMOVED. THE CONTRACTOR SHALL VISIT THE SITE AND VERIFY CONDITIONS PRIOR TO SUBMITTING A BID.
- B. Where walls, ceilings, etc., are shown as being removed on general drawings, the Contractor shall remove all mechanical equipment, devices, fixtures, piping, ducts, systems, etc., from the removed area.
- C. Where ceilings, walls, partitions, etc., are temporarily removed and replaced by others, This Contractor shall remove, store, and replace equipment, devices, fixtures, pipes, ducts, systems, etc.
- D. Verify that abandoned utilities serve only abandoned equipment or facilities. Extend services to facilities or equipment that shall remain in operation following demolition.
- E. Coordinate work with all other Contractors and the Owner. Schedule removal of equipment to avoid conflicts.
- F. This Contractor shall verify all existing equipment sizes and capacities where equipment is scheduled to be replaced or modified, prior to ordering new equipment.
- G. Bid submittal shall mean the Contractor has visited the project site and verified existing conditions and scope of work.

3.2 PREPARATION

- A. Disconnect mechanical systems in walls, floors, and ceilings scheduled for removal.

- B. Provide temporary connections to maintain existing systems in service during construction. When work must be performed on operating equipment, use personnel experienced in such operations.
- C. Existing Heating System: Maintain existing system in service until new system is complete and ready for service. Drain system only to make switchovers and connections. Obtain permission from the Owner at least 48 hours before partially or completely draining system. Minimize outage duration.

3.3 DEMOLITION AND EXTENSION OF EXISTING MECHANICAL WORK

- A. Demolish and extend existing mechanical work under provisions of Division 2 and this Section.
- B. Remove, relocate, and extend existing installations to accommodate new construction.
- C. Remove abandoned ducts and piping to source of supply and/or main lines.
- D. Remove exposed abandoned pipes and ducts, including abandoned pipes and ducts above accessible ceilings. Cut ducts flush with walls and floors, cap duct that remains, and patch surfaces. Cut pipes above ceilings, below floors and behind walls. Cap remaining lines. Repair building construction to match original. Remove all clamps, hangers, supports, etc. associated with pipe and duct removal.
- E. Disconnect and remove mechanical devices and equipment serving equipment that has been removed.
- F. Repair adjacent construction and finishes damaged during demolition and extension work.
- G. Maintain access to existing mechanical installations which remain. Modify installation or provide access panels as appropriate.
- H. Remove unused sections of supply and return air ductwork back to mains. Patch opening with sheet metal and seal airtight. Patch existing insulation to match existing. Where existing ductwork is to be capped and reused, locate the end cap within 6" of the last branch. End caps shall be 3" pressure class and seal class "A".
- I. Extend existing installations using materials and methods compatible with existing installations, or as specified.
- J. Properly reclaim and dispose of all refrigerant in demolished equipment and as required for extension of existing equipment.

3.4 CUTTING AND PATCHING

- A. This Contractor is responsible for all penetrations of existing construction required to complete the work of this project. Refer to Section 23 05 29 for additional requirements.
- B. Penetrations in existing construction should be reviewed carefully prior to proceeding with any work.

- C. Penetrations shall be neat and clean with smooth and/or finished edges. Core drill where possible for clean opening.
- D. Repair existing construction as required after penetration is complete to restore to original condition. Use similar materials and match adjacent construction unless otherwise noted or agreed to by the Architect/Engineer prior to start of work.
- E. This Contractor is responsible for all costs incurred in repair, relocations, or replacement of any cables, conduits, or other services if damaged without proper investigation.

3.5 CLEANING AND REPAIR

- A. Clean and repair existing materials and equipment which remain or are to be reused.
- B. Clean all systems adjacent to project which are affected by the dust and debris caused by this construction.
- C. MECHANICAL ITEMS REMOVED AND NOT RELOCATED REMAIN THE PROPERTY OF THE OWNER. CONTRACTOR SHALL PLACE ITEMS RETAINED BY THE OWNER IN A LOCATION COORDINATED WITH THE OWNER. THE CONTRACTOR SHALL DISPOSE OF MATERIAL THE OWNER DOES NOT WANT TO REUSE OR RETAIN FOR MAINTENANCE PURPOSES.

3.6 SPECIAL REQUIREMENTS

- A. Install temporary filter media over outside air intakes which are within 100 feet of the limits of construction or as noted on the drawings. This Contractor shall complete any cleaning required for existing systems which are affected by construction dust and debris.
- B. Review locations of all new penetrations in existing floor slabs or walls. Determine construction type and review for possible interferences. Bring all concerns to the attention of the Architect/Engineer before proceeding.
- C. Connection to Existing Glycol Systems:
 - 1. Where existing piping system is maintained and only "hot taps" or existing valves are used as connection points, flush and clean the components in advance of connecting to the existing system.
 - a. Provide additional glycol solution to be added to the system due to the increased volume associated with the new work and provide new solution for the portion of the added system.
 - b. Use existing glycol feeder to add to the system.
 - 2. Where existing piping system is reused in parts, existing system in its entirety shall be drained.
 - a. Prior to starting work, provide an analysis of the existing glycol solution and make a report to the Owner/Engineer. The report shall include the level of glycol concentration as well as a statement regarding the overall condition of the solution about cleanliness of the solution.

- 1) If the existing concentration is below the design level, the Contactor shall coordinate with the Owner to provide the additional quantity of glycol as added scope to the project.
 - 2) If the overall condition of glycol solution is poor and not worthy of being placed back into the system, the Contactor shall coordinate with the Owner to provide the additional quantity of glycol as added scope to the project.
- b. Provide means to store the existing glycol solution drained from the system for the duration of the work. Glycol may be stored on site or removed and brought back to the site when the system is ready to be refilled.
- c. Once the new work is attached to the system and installation has been completed, pressure test the system in its entirety as a complete system. Anticipate leaks will occur in the existing piping system.
- 1) Repair all leaks.
 - 2) Coordinate with Owner at the time of the pressure test and aid Owner in identification of leaks that they will repair.
- d. Upon completion of an acceptable pressure test, flush the system in its entirety. Provide enough chemicals and flow to clean and flush the system as a whole.
- e. In addition to the stored glycol solution, provide additional glycol solution to be added to the system due to the increased volume associated with the new work. Provide new solution for the portion of the added system. Use existing glycol feeder to add to the system.

END OF SECTION 23 05 05

SECTION 23 05 13 - MOTORS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Single Phase and Three Phase Electric Motors.

1.2 REFERENCES

- A. AFBMA 9 - Load Ratings and Fatigue Life for Ball Bearings.
- B. AFBMA 11 - Load Ratings and Fatigue Life for Roller Bearings.
- C. ANSI/ASHRAE/IES Standard 90.1 (latest published edition) - Energy Standard for Buildings Except Low-Rise Residential Buildings.
- D. ANSI/IEEE 112 - Test Procedure for Polyphase Induction Motors and Generators.
- E. ANSI/NEMA MG 1 - Motors and Generators.
- F. ANSI/NFPA 70 - National Electrical Code.
- G. Energy Independence and Security Act of 2007.

1.3 SUBMITTALS

- A. Submit shop drawings under provisions of Section 23 05 00. Include nominal efficiency and power factor for all premium efficiency motors. Efficiencies must meet or exceed the nominal energy efficiency levels presented below.
- B. Submit shop drawings for all three phase motors.
- C. Submit motor data with equipment when motor is installed by the manufacturer at the factory.
- D. Submit shaft grounding device for all motors as required.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Protect motors stored on site from weather and moisture by maintaining factory covers and suitable weatherproof coverings. For extended outdoor storage, follow manufacturer's recommendations for equipment and motor.

1.5 OPERATION AND MAINTENANCE DATA

- A. Submit operation and maintenance data including assembly drawings, bearing data including replacement sizes, and lubrication instructions.

1.6 QUALIFICATIONS

- A. Manufacturer: Company specializing in the manufacture of commercial and industrial motors and accessories, with a minimum of three years documented manufacturing experience.

PART 2 - PRODUCTS

2.1 MOTORS - GENERAL CONSTRUCTION AND REQUIREMENTS

- A. Refer to the drawings for required electrical characteristics. Voltage is generally specified and scheduled as distribution voltage. Motor submittals may be based on utilization voltage if it corresponds to the correct distribution voltage.

Distribution/Nominal Voltage	Utilization Voltage
120	115
208	200
240	230
277	265
480	460

- B. Design motors for continuous operation in 40°C environment, and for temperature rise in accordance with ANSI/NEMA MG 1 limits for insulation class, service factor, and motor enclosure type.
- C. Visible Nameplate: Indicating horsepower, voltage, phase, hertz, RPM, full load amps, locked rotor amps, frame size, manufacturer's name and model number, service factor, power factor, insulation class.
- D. Electrical Connection: Boxes, threaded for conduit. For fractional horsepower motors where connection is made directly, provide conduit connection in end frame.
- E. Unless otherwise indicated, motors 3/4 HP and smaller shall be single phase, 60 hertz, open drip-proof or totally enclosed fan-cooled type.
- F. Unless otherwise indicated, motors 1 HP and larger shall be three phase, 60 hertz, squirrel cage type, NEMA Design Code B (low current in-rush, normal starting torque), open drip-proof or totally enclosed fan-cooled type.
- G. Each contractor shall set all motors furnished by the contractor.
- H. All motors shall have a minimum service factor of 1.15.
- I. All motors shall have ball or roller bearings with a minimum L-10 fatigue life of 150,000 hours in direct-coupled applications and 50,000 hours for belted applications. Belted rating shall be based on radial loads and pulley sizes called out in NEMA MG1-14.43.
- J. Bearings shall be sealed type for 10 HP and smaller motors. Bearings shall be regreasable type for larger motors.

- K. Aluminum end housings are not permitted on motors 15 HP or larger.
- L. Motor Driven Equipment:
 - 1. No equipment shall be selected or operate above 90% of its motor nameplate rating. Motor size may not be increased to compensate for equipment with efficiency lower than that specified.
 - 2. If a larger motor than specified is required on equipment, the contractor supplying the equipment is responsible for all additional costs due to larger starters, wiring, etc.
- M. Provide all belted motors with a means of moving and securing the motor to tighten belts. Motors over 2 HP shall have screw type tension adjustment. Motors over 40 HP shall have dual screw adjusters. Slide bases shall conform to NEMA standards.
- N. Motors for fans and pumps 1/12 HP or greater and less than 1 HP shall be electronically-commutated motors or shall have a minimum motor efficiency of 70% when rated in accordance with DOE 10 CFR 431. These motors shall also have the means to adjust motor speed for either balancing or remote control. Belt-driven fans may use sheave adjustments for airflow balancing in lieu of varying motor speed.

2.2 ELECTRICALLY COMMUTATED MOTORS (ECM)

- A. Motor shall be variable speed, constant torque, brushless DC motor for direct-drive applications. Electronics shall be encapsulated for moisture protection and shall integral surge protection. Motor shall be pre-wired for specific voltage and phase.
- B. Motor frame shall be NEMA 48; UL recognized components shall be provided for the motor construction.
- C. All EC motors shall be a minimum of 85% efficient at all speeds.
- D. Motors shall be permanently lubricated; utilize ball bearings to match with the connected driven equipment.
- E. Provide motor with on-board motor control module. Motor speed shall be limited to provide electronic over current protection. Starter shall provide soft start to reduce inrush current and shall be controllable from 20% to 100% of full rated speed.
- F. Operational mode shall be as scheduled and shall be one of the following:
 - 1. Constant Flow
 - 2. Constant Temperature
 - 3. Constant Pressure

2.3 PREMIUM EFFICIENCY MOTORS (INCLUDING MOST 3-PHASE GENERAL PURPOSE MOTORS)

- A. All motors, unless exempted by EPA legislation that became federal law on December 19, 2010, shall comply with the efficiencies listed in that standard, which are reprinted below. These match the 2010 NEMA premium efficiency ratings. All ratings listed are nominal full load efficiencies, verified in accordance with IEEE Standard 112, Test Method B. Average expected (not guaranteed minimum) power factors shall also be at least the following:

HP	Full-Load Efficiencies %					
	Open Drip-Proof			Totally Enclosed Fan Cooled		
	1200 rpm	1800 rpm	3600 rpm	1200 rpm	1800 rpm	3600 rpm
1.0	82.5	85.5	77.0	82.5	85.5	77.0
1.5	86.5	86.5	84.0	87.5	86.5	84.0
2.0	87.5	86.5	85.5	88.5	86.5	85.5
3.0	88.5	89.5	85.5	89.5	89.5	86.5
5.0	89.5	89.5	86.5	89.5	89.5	88.5
7.5	90.2	91.0	88.5	91.0	91.7	89.5
10.0	91.7	91.7	89.5	91.0	91.7	90.2
15.0	91.7	93.0	90.2	91.7	92.4	91.0
20.0	92.4	93.0	91.0	91.7	93.0	91.0
25.0	93.0	93.6	91.7	93.0	93.6	91.7
30.0	93.6	94.1	91.7	93.0	93.6	91.7
40.0	94.1	94.1	92.4	94.1	94.1	92.4
50.0	94.1	94.5	93.0	94.1	94.5	93.0
60.0	94.5	95.0	93.6	94.5	95.0	93.6
75.0	94.5	95.0	93.6	94.5	95.4	93.6
100.0	95.0	95.4	93.6	95.0	95.4	94.1

- B. Motor nameplate shall be noted with the above ratings.

2.4 MOTORS ON VARIABLE FREQUENCY DRIVES

- A. All motors driven by VFDs shall be premium efficiency type.
- B. Motors shall be designed for use with VFDs in variable torque applications with 1.15 service factor. Motors shall not be equipped with auxiliary blowers.
- C. Motors driven by VFDs shall have Class F or H insulation and be designated by the motor manufacturer to be suitable for inverter duty service in accordance with NEMA MG 1 Section IV, "Performance Standards Applying to All Machines," Part 31 "Definite-Purpose Inverter-Fed Polyphase Motors.
- D. All 480-volt motors controlled by VFDs shall be equipped with an alternate discharge path, such as a shaft grounding ring or grounding brush, to divert adverse shaft currents from the motor bearings on the drive end of the motor shaft. Motor shafts 2"50 mm and larger require shaft grounding on the drive end and the non-drive end. This Contractor shall ensure (via field observation and measurement) that the shaft is effectively grounded upon startup.

1. Providing grounding rings internal to the motor housing is an acceptable solution, provided the motor is affixed with a label clearly indicating the presence of a grounding assembly. The grounding ring shall be listed for 40,000 hours of motor service and shall be accessible via the drive endplate.
2. The following critical motors shall also be equipped with shaft grounding kits:
 - a. All.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. All rotating shafts and/or equipment shall be completely guarded from all contact. Partial guards and/or guards that do not meet all applicable OSHA standards are not acceptable. Contractor is responsible for providing this guarding if it is not provided with the equipment supplied.
- B. For flexible coupled drive motors, mount coupling to the shafts in accordance with the coupling manufacturer's recommendations. Align shafts to manufacturer's requirements or within 0.002 inch per inch diameter of coupling hub.
- C. For belt drive motors, mount sheaves on the appropriate shafts per manufacturer's instructions. Use a straight edge to check alignment of the sheaves. Reposition sheaves as necessary so the straight edge contacts both sheave faces squarely. After sheaves are aligned, loosen the adjustable motor base so the belt(s) can be added, and tighten the base so the belt tension is in accordance with the drive manufacturer's recommendations. Frequently check belt tension and adjust if necessary during the first day of operation and again after 80 hours of operation.

END OF SECTION 23 05 13

SECTION 23 05 29 - HVAC SUPPORTS AND ANCHORS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Hangers, Supports, and Associated Anchors.
- B. Equipment Bases and Supports.
- C. Sleeves and Seals.
- D. Flashing and Sealing of Equipment and Pipe Stacks.
- E. Cutting of Openings.
- F. Escutcheon Plates and Trim.

1.2 REFERENCES

- A. ANSI/ASME B31.1 - Power Piping.
- B. MSS SP-58 - Pipe Hangers and Supports - Materials, Design, Manufacture, Selection, Application, and Installation.
- C. MSS SP 69 - Pipe Hangers and Supports - Selection and Application.
- D. MSS SP 89 - Pipe Hangers and Supports - Fabrication and Installation Practices.
- E. MSS SP-127 - Bracing for Piping Systems Seismic-Wind-Dynamic Design, Selection, Application

1.3 SUBMITTALS

- A. Submit shop drawings and product data under provisions of Section 23 05 00. Include plastic pipe manufacturers' support spacing requirements.

1.4 WORK FURNISHED BUT INSTALLED UNDER OTHER SECTIONS

- A. Furnish sleeves and hanger inserts to General Contractor for placement into formwork.

PART 2 - PRODUCTS

2.1 HANGER RODS

- A. Hanger rods for single rod hangers shall conform to the following:

Pipe Size	Hanger Rod Diameter	
	Column #1	Column #2
2-1/2" and smaller	3/8"	3/8"
3" through 3-5/8"	3/8"	3/8"
4" and 5"	1/2"	1/2"
6"	3/4"	5/8"
8" through 12"	7/8"	3/4"
14"	1"	7/8"
16" and 18"	1"	N/A
20" and 24"	1-1/4"	N/A

Column #1: Steel pipe.

Column #2: Copper, plastic and fiberglass reinforced pipe.

- B. Rods for double rod hangers may be reduced one size. Minimum rod diameter is 3/8 inches.
- C. Hanger rods and accessories used in mechanical spaces or otherwise dry areas shall have ASTM B633 electro-plated zinc finish.
- D. All hanger rods, nuts, washers, clevises, etc., in damp areas shall have ASTM A123 hot-dip galvanized finish applied after fabrication. This applies to the following areas:
 - 1. Insert.

2.2 PIPE AND STRUCTURAL SUPPORTS

- A. General:
 - 1. Pipe hangers, clamps, and supports shall conform to Manufacturers Standardization Society MSS SP-58, 69, 89, and 127 (where applicable).
 - 2. On all insulated piping, provide at each support an insert of same thickness and contour as adjoining insulation, between the pipe and insulation jacket, to prevent insulation from sagging and crushing. Refer to insulation specifications for materials and additional information.
- B. Vertical Supports:
 - 1. Support and laterally brace vertical pipes at every floor level in multi-story structures, unless otherwise noted by applicable codes, but never at intervals over 15 feet. Support vertical pipes with riser clamps installed below hubs, couplings, or lugs. Provide sufficient flexibility to accommodate expansion and contraction to avoid compromising fire barrier penetrations or stressing piping at fixed takeoff locations.
 - a. Products:
 - 1) Cooper/B-Line Fig B3373 Series
 - 2) Erico 510 Series
 - 3) Nibco/Tolco Fig. 82

2. Cold Pipe: Place restrained neoprene mounts beneath vertical pipe riser clamps to prevent sweating of cold pipes. Select neoprene mounts based on the weight of the pipe to be supported. Insulate over mounts.
 - a. Products:
 - 1) Mason RBA, RCA or RDA
 - 2) Mason BR
3. Cold Pipe Alternative: Insulated pipe riser clamp with no thermal bridging between clamp and pipe; water repellant calcium silicate insulation material adhered inside the clamp; ASTM A653 galvanized steel clamp.
 - a. Products:
 - 1) Pipeshields E100
4. Wall supports shall be used where vertical height of structure exceeds minimum spacing requirements. Install wall supports at same spacing as hangers or strut supports along vertical length of pipe runs. Wall supports shall be coordinated with the Structural Engineer.
5. Masonry Anchors: Fasten to concrete masonry units with expansion anchors or self-tapping masonry screws. For expansion anchors into hollow concrete block, use sleeve-type anchors designed for the specific application. Do not fasten in masonry joints. Do not use powder actuated fasteners, wooden plugs, or plastic inserts.

C. Hangers and Clamps:

1. Oversize all hangers, clamps, and supports on insulated piping to allow insulation and jacket to pass through unbroken. This applies to both hot and cold pipes.
2. Hangers in direct contact with bare copper pipe shall include plastic pipe insert similar to Unistrut Cush-A-Clamp, Hydra-Zorb, Erico Cushion Clamp or Cooper Vibra-Clamp within their temperature limits of -65°F to +275°F.
3. On all insulated piping, provide a semi-cylindrical metallic shield and vapor barrier jacket.
4. Ferrous hot piping 4 inches and larger shall have steel saddles tack welded to the pipe at each support with a depth not less than specified for the insulation. Factory fabricated inserts may be used.
 - a. Products:
 - 1) Anvil Fig. 160, 161, 162, 163, 164, 165
 - 2) Cooper/B-Line Fig. 3160, 3161, 3162, 3163, 3164, 3165
 - 3) Erico Model 630, 631, 632, 633, 634, 635
 - 4) Nibco/Tolco Fig. 260-1, 261-1 1/2, 262-2, 263-2 1/2, 264-3, 265-4
5. Unless otherwise indicated, hangers shall be as follows:
 - a. Clevis Type: Service: Bare Metal Pipe, Rigid Plastic Pipe, Insulated Cold Pipe, Insulated Hot Pipe - 3 inches and Smaller:

- 1) Products: Bare Steel, Plastic or Insulated Pipe:
 - a) Anvil Fig. 260
 - b) Cooper/B-Line Fig. 3100
 - c) Erico Model 400
 - d) Nibco/Tolco Fig. 1
 - 2) Products: Bare Copper Pipe:
 - a) Cooper/B-Line Fig. B3100C
 - b) Nibco/Tolco Fig. 81PVC
- b. Roller Type: Service: Insulated Hot Pipe - 4 inches and Larger:
- 1) Products: 4" through 6":
 - a) Anvil Fig. 181, 271
 - b) Cooper/B-Line Fig. 3110, 3117
 - c) Erico Model 610
 - d) Nibco/Tolco Fig. 324, 327
 - 2) Products: 8" and Above:
 - a) Anvil Fig. 171, 271
 - b) Cooper/B-Line Fig. 3114, 3117
 - c) Erico Model 605
 - d) Nibco/Tolco Fig. 322, 327
- c. Continuous Channel with Clevis Type: Service: Plastic Tubing, Flexible Hose, Soft Copper Tubing:
- 1) Products:
 - a) Cooper/B-Line Fig. B3106, with Fig. B3106V
 - b) Erico Model 104, with Model 104V
 - c) Nibco/Tolco Fig. 1V
- d. Adjustable Swivel Ring Type: Service: Bare Metal Pipe - 4 inches and Smaller:
- 1) Products: Bare Steel Pipe:
 - a) Anvil Fig. 69
 - b) Cooper/B-Line Fig. B3170NF
 - c) Erico Model FCN
 - d) Nibco/Tolco Fig. 200.
 - 2) Products: Bare Copper Pipe:
 - a) Cooper/B-Line Fig. B3170CTC
 - b) Erico 102A0 Series
 - c) Nibco/Tolco Fig. 203

6. Support may be fabricated from U-channel strut or similar shapes. Piping less than 4" in diameter shall be secured to strut with clamps of proper design and capacity as required to maintain spacing and alignment. Strut shall be independently supported from hanger drops or building structure. Size and support shall be per manufacturer's installation requirements for structural support of piping. Clamps shall not interrupt piping insulation.
 - a. Strut used in mechanical spaces or otherwise dry areas shall have ASTM B633 electro-plated zinc finish.
 - b. Strut used in damp areas listed in hanger rods shall have ASTM A123 hot-dip galvanized finish applied after fabrication.
 7. Unless otherwise indicated, pipe supports for use with struts shall be as follows:
 - a. Clamp Type: Service: Bare Metal Pipe, Rigid Plastic Pipe, Insulated Cold Pipe, Insulated Hot Pipe - 3 inches and smaller:
 - 1) Clamps in direct contact with copper pipe shall include plastic pipe insert similar to Unistrut Cush-A-Clamp, Hydra-Zorb, Erico Cushion Clamp or Cooper Vibra-Clamp.
 - 2) Pipes subject to expansion and contraction shall have clamps oversized to allow limited pipe movement.
 - 3) Products: Bare Steel, Plastic or Insulated Pipe:
 - a) Unistrut Fig. P1100 or P2500
 - b) Cooper/B-Line Fig. B2000 or B2400
 - c) Nibco/Tolco Fig. A-14 or 2STR
 - 4) Products: Bare Copper Pipe:
 - a) Cooper/B-Line Fig. BVT
 - b. Roller Type: Service: Insulated Hot Pipe - 4 inches and larger:
 - 1) Products: 4" through 6":
 - a) Unistrut Fig. P2474
 - b) Cooper/B-Line Fig. B218
 - c) Nibco/Tolco Fig. ROL-12
 - 2) Products: 8" and Above:
 - a) Unistrut Fig. P2474-1
 - b) Cooper/B-Line Fig. B219
 - c) Nibco/Tolco Fig. ROL-13
- D. Upper (Structural) Attachments:
1. Unless otherwise shown, upper attachments for hanger rods or support struts shall be as follows:

- a. Steel Structure Clamps: C-Type Wide Flange Beam Clamps (for use on top and/or bottom of wide flanges. Not permitted for use with bar-joists.):
 - 1) Products:
 - a) Anvil Fig. 92
 - b) Cooper/B-Line Fig. B3033/B3034
 - c) Erico Model 300
 - d) Nibco/Tolco 68
- b. Scissor Type Beam Clamps (for use with bar-joists and wide flange):
 - 1) Products:
 - a) Anvil Fig. 228, 292
 - b) Cooper/B-Line Fig. B3054
 - c) Erico Model 360
 - d) Nibco/Tolco Fig. 329
- c. Concentrically Loaded Open Web Joist Hangers (for use with bar joists):
 - 1) Products:
 - a) MCL. M1, M2 or M3
- d. Concrete: Inserts Single Rod Galvanized:
 - 1) Products:
 - a) Anvil Fig. 282
 - b) Cooper/B-Line Fig. B3014
 - c) Erico Model 355
 - d) Nibco/Tolco Fig. 310
- e. Concrete: Inserts Continuous Strip Galvanized:
 - 1) Products:
 - a) Unistrut Corp P3200 Series
 - b) Cooper/B-Line Fig. B22-J
 - c) Erico CONCT
- f. Concrete Anchors: Fasten to concrete using cast-in or post-installed anchors designed per the requirements of Appendix D of ACI 318-05. Post-installed anchors shall be qualified for use in cracked concrete by ACI-355.2.
- g. Masonry Anchors: Fasten to concrete masonry units with expansion anchors or self-tapping masonry screws. For expansion anchors into hollow concrete block, use sleeve-type anchors designed for the specific application. Do not fasten in masonry joints. Do not use powder actuated fasteners, wooden plugs, or plastic inserts.

- h. Steel Structure Welding:
 - 1) Unless otherwise noted, hangers, clips, and auxiliary support steel may be welded in lieu of bolting, clamping, or riveting to the building structural frame. Take adequate precautions during all welding operations for fire prevention and protecting walls and ceilings from smoke damage.
- i. Wood Anchors: Tension wood rod hanger for suspending 3/8" threaded rod. Zinc plated carbon steel.
 - 1) Minimum allowable tension loads for Douglass Fir/Southern Pine:
 - a) 3/8" diameter rod; 2-1/2" shank: 600 lb/590 lb.
 - b) Load values are based on full shank penetration into wood member. Minimum edge distance 3/4". Minimum end distance 3-1/4".
 - 2) Limitations:
 - a) Truss: Do not hang from wood trusses without truss manufacturer or Structural Engineer^{TMTM}s approval.
 - b) Sheetrock/Gypsum Ceiling: When drilling through non-wood materials (e.g., sheet rock, gypsum, etc.), increase shank length by depth of non-wood materials.
 - c) Plywood Flooring/Roofing: Do not hang from plywood floor or roofing.
 - d) Spacing: Refer to wood structure spacing of hangers.
 - 3) Products:
 - a) Simpson RWV
 - b) DeWALT
 - c) ITI Sammys GT25

2.3 FOUNDATIONS, BASES, AND SUPPORTS

A. Basic Requirements:

- 1. Furnish and install foundations, bases, and supports (not specifically indicated on the Drawings or in the Specifications of either the General Construction or Mechanical work as provided by another Contractor) for mechanical equipment.
- 2. All concrete foundations, bases and supports, shall be reinforced. All steel bases and supports shall receive a prime coat of zinc chromate or red metal primer. After completion of work, give steel supports a final coat of gray enamel.

B. Concrete Bases (Housekeeping Pads):

- 1. Unless shown otherwise on the drawings, concrete bases shall be nominal 4 inches thick and shall extend 3 inches on all sides of the equipment (6 inches larger than factory base).
- 2. Where a base is less than 12 inches from a wall, extend the base to the wall to prevent a "dirt-trap".

3. Concrete materials and workmanship required for the Contractor's work shall be provided by the Contractor. Materials and workmanship shall conform to the applicable standards of the Portland Cement Association. Reinforce with 6"x6", W1.4-W1.4 welded wire fabric. Concrete shall withstand 3,000 pounds compression per square inch at 28 days (be 20 MPa strength).
4. Equipment requiring bases is as follows:
 - a. Boiler
 - b. Boiler Feed Pump/Tank
 - c. Chemical Feed Equipment
 - d. Pump
 - e. Tank

C. Supports:

1. Provide sufficient clips, inserts, hangers, racks, rods, and auxiliary steel to securely support all suspended material, equipment and conduit without sag.
2. Hang heavy equipment from concrete floors or ceilings with Architect/Engineer-approved concrete inserts, furnished and installed by the Contractor whose work requires them, except where indicated otherwise.

D. Grout:

1. Grout shall be non-shrinking premixed (Master Builders Company "Embecco"), unless otherwise indicated on the drawings or approved by the Architect/Engineer.
2. Use Mix No. 1 for clearances of 1" or less, and Mix No. 2 for all larger clearances.
3. Grout under equipment bases, around pipes, at pipe sleeves, etc., and where shown on the drawings.

2.4 OPENINGS IN FLOORS, WALLS AND CEILINGS

- A. Exact locations of all openings for the installation of materials shall be determined by the Contractor and given to the General Contractor for installation or construction as the structure is built.
- B. Coordinate all openings with other Contractors.
- C. Hire the proper tradesman and furnish all labor, material and equipment to cut openings in or through existing structures, or openings in new structures that were not installed, or additional openings. Repair all spalling and damage to the satisfaction of the Architect/Engineer. Make saw cuts before breaking out concrete to ensure even and uniform opening edges.
- D. Said cutting shall be at the complete expense of each Contractor. Failure to coordinate openings with other Contractors shall not exempt the Contractor from providing openings at Contractor's expense.
- E. Do not cut structural members without written approval of the Architect or Structural Engineer.
- F. Exposed Housing Penetrations: Seal pipes with surface temperature below 150°F, penetrating housings with conical stepped, white silicone, EPDM or neoprene pipe flashings and stainless steel clamps equal to Portals Plus Pipe Boots or Pipetite.

2.5 ROOF PENETRATIONS

- A. Roof Curb Enclosure: Provide weatherproof roof curb and enclosure for pipe penetrations. Refer to drawings for details.
- B. Conical Pipe Boot: Seal pipes with surface temperature below 150°F penetrating single-ply roofs with conical stepped, UV-resistant silicone, EPDM or neoprene pipe flashings and stainless steel clamps equal to Portals Plus Pipe Boots or Pipetite. Color: White shall match roofing material.
- C. Break insulation only at the clamp for pipes between 60°F and 150°F. Seal outdoor insulation edges watertight.

2.6 SLEEVES AND LINTELS

- A. Each Contractor shall provide sleeves and lintels for all duct and pipe openings required for the Contractor's work in masonry walls and floors, unless specifically shown as being by others.
- B. Fabricate all sleeves from standard weight black steel pipe or as indicated on the drawings. Provide continuous sleeve. Cut or split sleeves are not acceptable.
- C. Fabricate all lintels for masonry walls from structural steel shapes or as indicated on the drawings. Have all lintels approved by the Architect or Structural Engineer.
- D. Sleeves through the floors on exposed risers shall be flush with the ceiling, with planed squared ends extending 1" above the floor in unfinished areas, and flush with the floor in finished areas, to accept spring closing floor plates.
- E. Sleeves shall not penetrate structural members or masonry walls without approval from the Structural Engineer. Sleeves shall then comply with the Architect/Engineer's design.
- F. Openings through unexcavated floors and/or foundation walls below the floor shall have a smooth finish with sufficient annular space around material passing through opening so slight settling will not place stress on the material or building structure.
- G. Install all sleeves concentric with pipes. Secure sleeves in concrete to wood forms. This Contractor is responsible for sleeves dislodged or moved when pouring concrete.
- H. Where pipes rise through concrete floors that are on earthen grade, provide 3/4" resilient expansion joint material (e.g., foam, rubber, asphalt-coated fiber, bituminous-impregnated felt, or cork) wrapped around the pipe, the full depth of concrete, at the point of penetration. Secure to prevent shifting during concrete placement and finishing.
- I. Size sleeves large enough to allow expansion and contraction movement. Provide continuous insulation wrapping.

J. Wall Seals ("Link-Seals"):

1. Where shown on the drawings, pipes passing through walls, ceilings, or floors shall have their annular space (sleeve or drilled hole - not tapered hole made with knockout plug) sealed by properly sized sealing elements consisting of a synthetic rubber material compounded to resist aging, ozone, sunlight, water and chemical action.
2. Sleeves, if used, shall be standard weight steel with primed finish and waterstop/anchor continuously welded to sleeve. If piping carries only fluids below 120°F, sleeves may be thermoplastic with integral water seal and textured surface.
3. Sleeves shall be at least 2 pipe sizes larger than the pipes.
4. Pressure shall be maintained by stainless steel bolts and other parts. Pressure plates may be of composite material for Models S and OS.
5. Sealing element shall be as follows:

<u>Model</u>	<u>Service</u>	<u>Element Material</u>	<u>Temperature Range</u>
S	Standard (Stainless)	EPDM	-40°F to 250°F
T	High/Low Temperature (Steam)	Silicone	-67°F to 400°F
T	Fire Seals (1 hour)	Silicone	-67°F to 400°F
FS	Fire Seals (3 hours)	Silicone	-67°F to 400°F
OS	Oil Resistant/Stainless	Nitrile	-40°F to 210°F

6. Manufacturers:
 - a. Thunderline Corporation "Link-Seals"
 - b. O-Z/Gedney Company
 - c. Calpico, Inc.
 - d. Innerlynx
 - e. Metraflex Company (cold service only)

2.7 ESCUTCHEON PLATES AND TRIM

- A. Fit escutcheons to all insulated or uninsulated exposed pipes passing through walls, floors, or ceilings of finished rooms.
- B. Escutcheons shall be heavy gauge, cold rolled steel, copper coated under a chromium plated finish, heavy spring clip, rigid hinge and latch.
- C. Install galvanized steel (unless otherwise indicated) trim strip to cover vacant space and raw construction edges of all rectangular openings in finished rooms. This includes pipe openings.

2.8 PIPE PENETRATIONS

- A. Seal all pipe penetrations. Seal non-rated walls and floor penetrations with grout or caulk. Backing material may be used.
- B. Seal fire rated wall and floor penetrations with fire seal system as specified.

2.9 PIPE ANCHORS

- A. Provide all items needed to allow adequate expansion and contraction of all piping. All piping shall be supported, guided, aligned, and anchored as required.
- B. Repair all piping leaks and associated damage. Pipes shall not rub on any part of the building.

2.10 FINISH

- A. Prime coat exposed steel hangers and supports. Hangers and supports in crawl spaces, pipe shafts, and suspended ceiling spaces are not considered exposed.

PART 3 - EXECUTION

3.1 HVAC SUPPORTS AND ANCHORS

A. General Installation Requirements:

- 1. Install all items per manufacturer's instructions.
- 2. Coordinate the location and method of support of piping systems with all installations under other Divisions and Sections of the Specifications.
- 3. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding.
- 4. Supports shall extend directly to building structure. Do not support piping from duct hangers unless coordinated with sheet metal contractor prior to installation. Do not allow lighting or ceiling supports to be hung from piping supports.

B. Supports Requirements:

- 1. Where building structural steel is fireproofed, all hangers, clamps, auxiliary steel, etc., which attach to it shall be installed prior to application of fireproofing. Repair all fireproofing damaged during pipe installation.
- 2. Set all concrete inserts in place before pouring concrete.
- 3. Furnish, install and prime all auxiliary structural steel for support of piping systems that are not shown on the Drawings as being by others.
- 4. Install hangers and supports complete with lock nuts, clamps, rods, bolts, couplings, swivels, inserts and required accessories.
- 5. Hangers for horizontal piping shall have adequate means of vertical adjustment for alignment.

C. Pipe Requirements:

- 1. Support all piping and equipment, including valves, strainers, traps and other specialties and accessories to avoid objectionable or excessive stress, deflection, swaying, sagging or vibration in the piping or building structure during erection, cleaning, testing and normal operation of the systems.
- 2. Do not, however, restrain piping to cause it to snake or buckle between supports or to prevent proper movement due to expansion and contraction.
- 3. Support piping at equipment and valves so they can be disconnected and removed without further supporting the piping.

4. Piping shall not introduce strains or distortion to connected equipment.
 5. Parallel horizontal pipes may be supported on trapeze hangers made of structural shapes and hanger rods; otherwise, pipes shall be supported with individual hangers.
 6. Trapeze hangers may be used where ducts interfere with normal pipe hanging.
 7. Provide additional supports where pipe changes direction, adjacent to flanged valves and strainers, at equipment connections and heavy fittings.
 8. Provide at least one hanger adjacent to each joint in grooved end steel pipe with mechanical couplings.
- D. Provided the installation complies with all loading requirements of truss and joist manufacturers, the following practices are acceptable:
1. Loads of 100 lbs. or less may be attached anywhere along the top or bottom chords of trusses or joists with a minimum 3' spacing between loads.
 2. Loads greater than 100 lbs. must be hung concentrically and may be hung from top or bottom chord, provided one of the following conditions is met:
 - a. The hanger is attached within 6" from a web/chord joint.
 - b. Additional L2x2x1/4 web reinforcement is installed per manufacturer's requirements.
 3. It is prohibited to cantilever a load using an angle or other structural component that is attached to a truss or joist in such a fashion that a torsional force is applied to that structural member.
 4. If conditions cannot be met, coordinate installation with truss or joist manufacturer and contact Architect/Engineer.
- E. After piping and insulation installation are complete, cut hanger rods back at trapeze supports so they do not extend more than 3/4" below bottom face of lowest fastener and blunt any sharp edges.
- F. Do not exceed 25 lbs. per hanger and a minimum spacing of 2'-0" on center when attaching to metal roof decking (limitation not required with concrete on metal deck). This 25 lbs. load and 2'-0" spacing include adjacent electrical and architectural items hanging from deck. If the hanger restrictions cannot be achieved, supplemental framing off steel framing will need to be added.
- G. Do not exceed the manufacturer's recommended maximum load for any hanger or support.
- H. Steel/Concrete Structure: Spacing of hangers shall not exceed the compressive strength of the insulation inserts, and in no case shall exceed the following:
1. Steel and Fiberglass (Std. Weight or Heavier - Liquid Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" & under: 7'-0"
 - 2) 1-1/2": 9'-0"
 - 3) 2": 10'-0"
 - 4) 2-1/2": 11'-0"

- 5) 3": 12'-0"
 - 6) 4" & larger: 12'-0"
2. Steel (Std. Weight or Heavier - Vapor Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" and under: 9'-0"
 - 2) 1-1/2": 12'-0"
 - 3) 2" & larger: 12'-0"
 3. Hard Drawn Copper & Brass (Liquid Service):
 - a. Maximum Spacing:
 - 1) 3/4" and under: 5'-0"
 - 2) 1": 6'-0"
 - 3) 1-1/4": 7'-0"
 - 4) 1-1/2" 8'-0"
 - 5) 2": 8'-0"
 - 6) 2-1/2": 9'-0"
 - 7) 3": 10'-0"
 - 8) 4": 12'-0"
 - 9) 6": 12'-0"
 4. Hard Drawn Copper & Brass (Vapor Service):
 - a. Maximum Spacing:
 - 1) 3/4" & under: 7'-0"
 - 2) 1": 8'-0"
 - 3) 1-1/4": 9'-0"
 - 4) 1-1/2": 10'-0"
 - 5) 2": 11'-0"
 - 6) 2-1/2" & larger: 12'-0"
 5. Flexible Plastic Pipe, Flexible Hose, and Soft Copper Tubing:
 - a. Continuous channel with hangers maximum 8'-0" OC.
 6. Rigid Plastic Pipe:
 - a. Hangers shall be spaced based on the piping system manufacturers' instructions or, if no system instructions are available, space hangers at 4'-0" maximum centers.
- I. Wood Structure: Spacing of hangers shall not exceed the compressive strength of the insulation inserts, and in no case shall exceed the following:
 1. Steel and Fiberglass (Std. Weight or Heavier - Liquid Service):

- a. Maximum Spacing:
 - 1) 1-1/4" & under: 7'-0"
 - 2) 1-1/2": 9'-0"
 - 3) 2": 10'-0"
 - 4) 2-1/2": 11'-0"
 - 5) 3": 12'-0"
 - 6) 4" through 6": 12'-0" 8": 9^{TMTM}-0" 10": 6^{TMTM}-0" 12": 4^{TMTM}-0"
2. Steel (Std. Weight or Heavier - Vapor Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" and under: 9'-0"
 - 2) 1-1/2": 12'-0"
 - 3) 2" & larger: 12'-0"
 - 4) 2-1/2": 11'-0"
 - 5) 3": 12'-0"
 - 6) 4" through 8": 12'-0"
 - 7) 10": 9^{TMTM}-0"
 - 8) 12": 6^{TMTM}-0"
3. Hard Drawn Copper & Brass (Liquid Service):
 - a. Maximum Spacing:
 - 1) 3/4" and under: 5'-0"
 - 2) 1": 6'-0"
 - 3) 1-1/4": 7'-0"
 - 4) 1-1/2" 8'-0"
 - 5) 2": 8'-0"
 - 6) 2-1/2": 9'-0"
 - 7) 3": 10'-0"
 - 8) 4": 12'-0"
 - 9) 6": 12'-0"
4. Hard Drawn Copper & Brass (Vapor Service):
 - a. Maximum Spacing:
 - 1) 3/4" & under: 7'-0"
 - 2) 1": 8'-0"
 - 3) 1-1/4": 9'-0"
 - 4) 1-1/2": 10'-0"
 - 5) 2": 11'-0"
 - 6) 2-1/2" & larger: 12'-0"
5. Flexible Plastic Pipe, Flexible Hose, and Soft Copper Tubing:
 - a. Continuous channel with hangers maximum 8'-0" OC.

6. Rigid Plastic Pipe:
 - a. Hangers shall be spaced based on the piping system manufacturers' instructions or, if no system instructions are available, space hangers at 4'-0" maximum centers.

- J. Wood Structure: Spacing of hangers shall not exceed the compressive strength of the insulation inserts, and in no case shall exceed the following:
 1. Steel and Fiberglass (Std. Weight or Heavier - Liquid Service):
 - a. Maximum Spacing:
 - 1) 1-1/4" & under: 7'-0"
 - 2) 1-1/2": 9'-0"
 - 3) 2": 10'-0"
 - 4) 2-1/2": 11'-0"
 - 5) 3": 12'-0"
 - 6) 4" through 6": 12'-0" 8": 9'-0" 10": 6'-0" 12": 4'-0"

 2. Steel (Std. Weight or Heavier - Vapor Service):
 - a. Maximum Spacing:
 - 1) 1/2" and under: 6'-0"
 - 2) 3/4" to 1": 8'-0"
 - 3) 1-1/4" and under: 9'-0"
 - 4) 1-1/2": 10'-0"
 - 5) 2" & larger: 10'-0"
 - 6) 3": 12'-0"
 - 7) 4" through 8": 12'-0"
 - 8) 10": 9'-0"
 - 9) 12": 6'-0"

 3. Hard Drawn Copper & Brass (Liquid Service):
 - a. Maximum Spacing:
 - 1) 3/4" & under: 5'-0"
 - 2) 1": 6'-0"
 - 3) 1-1/4": 6'-0"
 - 4) 1-1/2": 6'-0"
 - 5) 2": 8'-0"
 - 6) 2-1/2": 9'-0"
 - 7) 3": 10'-0"
 - 8) 4": 10'-0"
 - 9) 6": 10'-0"

4. Hard Drawn Copper & Brass (Vapor Service):
 - a. Maximum Spacing:
 - 1) 3/4" & under: 6'-0"
 - 2) 1": 6'-0"
 - 3) 1-1/4": 6'-0"
 - 4) 1-1/2": 6'-0"
 - 5) 2": 10'-0"
 - 6) 2-1/2" & larger: 10'-0"
 5. Flexible Plastic Pipe, Flexible Hose, and Soft Copper Tubing:
 - a. Continuous channel with hangers maximum 8'-0" OC.
 6. Rigid Plastic Pipe:
 - a. Hangers shall be spaced based on the piping system manufacturers' instructions or, if no system instructions are available, space hangers at 4'-0" maximum centers.
- K. Installation of hangers shall conform to MSS SP-58, 69, and 89.

END OF SECTION 23 05 29

SECTION 23 05 48 - HVAC VIBRATION ISOLATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Bases.
- B. Vibration Isolation.
- C. Flexible Connectors.

1.2 SUBMITTALS

- A. Submit shop drawings per Section 23 05 00 and the Vibration Isolation Submittal Form at the end of this section.
- B. Vibration isolation submittals may be included with equipment being isolated, but must comply with this section.
- C. Base submittals shall include equipment served, construction, coatings, weights, and dimensions.
- D. Isolator submittals shall include:
 - 1. Equipment served
 - 2. Type of Isolator
 - 3. Load in Pounds per Isolator
 - 4. Recommended Maximum Load for Isolator
 - 5. Spring Constants of Isolators (for Spring Isolators)
 - 6. Load vs. Deflection Curves (for Neoprene Isolators)
 - 7. Specified Deflection
 - 8. Deflection to Solid (at least 150% of calculated deflection)
 - 9. Loaded (Operating) Deflection
 - 10. Free Height
 - 11. Loaded Height
 - 12. K_x/K_y (horizontal to vertical stiffness ratio - for spring isolators)
 - 13. Materials and Coatings
 - 14. Spring Diameters
- E. Make separate calculations for each isolator on equipment where the load is not equally distributed.
- F. Flexible connector shop drawings shall include overall face-to-face length and all specified properties.
- G. Submit certification that equipment, accessories, and components will withstand seismic forces defined in Section 23 05 50. Include the following:

1. Basis for Certification: Indicate whether certification is based on actual test of assembled components or on calculation.
 - a. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified."
 - b. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified and the unit will be fully operational after the seismic event."
2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.

PART 2 - PRODUCTS

2.1 BASIC CONSTRUCTION AND REQUIREMENT

- A. Vibration isolation for this project is subject to seismic restraint requirements of Section 23 05 50.
- B. Vibration isolators shall have either known undeflected heights or other markings so deflection under load can be verified.
- C. All isolators shall operate in the linear portion of their load versus deflection curve. The linear portion of the deflection curve of all spring isolators shall extend 50% beyond the calculated operating deflection (e.g., 3" for 2" calculated deflection). The point of 50% additional deflection shall not exceed the recommended load rating of the isolator.
- D. The lateral to vertical stiffness ratio (K_x/K_y) of spring isolators shall be between 0.8 and 2.0.
- E. All neoprene shall have UV resistance sufficient for 20 years of outdoor service.
- F. All isolators shall be designed or treated for corrosion resistance. Steel bases shall be cleaned of welding slag and primed for interior use, and hot dip galvanized after fabrication for exterior use. All bolts and washers over 3/8" diameter located outdoors shall be hot dip galvanized per ASTM A153. All other bolts, nuts and washers shall be zinc electroplated. All ferrous portions of isolators, other than springs, for exterior use shall be hot dip galvanized after fabrication. Outdoor springs shall be neoprene dipped or hot dip galvanized. All damage to coatings shall be field repaired with two coats of zinc rich coating.
- G. Equip all mountings used with structural steel bases with height-saving brackets. Bottoms of the brackets shall be 1-1/2" to 2-1/2" above the floor or housekeeping pad, unless shown otherwise on the drawings. Steel bases shall have at least four points of support.
- H. Provide motor slide rails for belt-driven equipment per Section 23 05 13.
- I. All isolators, except M1, shall have provision for leveling.

2.2 MOUNTINGS

A. Type M1:

1. 0.75" thick waffled neoprene pad with minimum static deflection of 0.07" at calculated load and 0.11" at maximum load. For loads less than 15 pounds, the deflection at calculated load requirement is waived, but the isolator must have a maximum stiffness of the ratio of 45#/0.35".
2. Units need not be bolted down unless called for or needed to prevent movement. If bolted down, prevent short circuiting with neoprene bushings and washers between bolts and isolators.
3. Manufacturers:
 - a. Mason "Super W"
 - b. Kinetics "NGS"
 - c. Amber/Booth "SPNR"
 - d. Vibration Eliminator Co. "400N"

B. Type M2:

1. Double deflection neoprene with minimum static deflection of 0.15" at calculated load and 0.35" at maximum rated load.
 - a. All metal shall be neoprene covered. Mounting shall have friction pads both top and bottom.
2. All units shall have bolt holes and be bolted down.
3. Use steel rails above the mountings to compensate for the overhang of equipment such as small vent sets and close coupled pumps.
4. Manufacturers:
 - a. Mason Industries "ND" or "DNR"
 - b. Amber/Booth "RVD"
 - c. Kinetics "RD"
 - d. Vibration Mountings and Controls "RD"
 - e. Vibration Eliminator Co. "T22" or "T44"

C. Type M3:

1. Free standing, laterally stable spring isolators without housings and complete with 1/4" neoprene friction pads.
2. Units shall have bolt holes but need not be bolted down unless called for or needed to prevent movement. If bolted down, prevent short circuiting with neoprene bushings and washers between bolts and isolators. Bolt holes shall not be within the springs.
3. All mountings shall have leveling bolts.
4. Manufacturers:
 - a. Mason "SLFH"
 - b. Kinetics "FDS"
 - c. Amber/Booth SW-3 [4"][, 5"][, or][6"]
 - d. Vibration Eliminator Co. "OST"

D. Type M4:

1. Use restrained spring mountings for equipment with operating weight different from the installed weight such as chillers and boilers, and equipment exposed to the wind such as cooling towers.
2. Spring isolators shall be free-standing with 1/4" neoprene acoustical friction pads.
3. All units shall have bolt holes and be bolted down. Prevent short circuiting with neoprene bushings and washers between bolts and isolators.
4. All mountings shall have leveling bolts.
5. Housings with vertical resilient limit stops shall prevent spring extension when weight is removed. Housings shall serve as blocking during erection and the installed and operating heights shall be the same.
6. Maintain a minimum clearance of 1/2" around restraining bolts and between the housings and the springs so as not to interfere with the spring action.
7. Limit stops shall be out of contact during normal operation.
8. Select isolators for equipment subjected to wind loads in conformance with ASCE 7-02.
9. Manufacturers:
 - a. Mason "SLRS"
 - b. Kinetics "FLS"
 - c. Aeroflex "AWRS"
 - d. Vibration Eliminator Co. "KW"

2.3 THRUST RESTRAINTS

A. Type TR1:

1. Horizontal thrust restraints shall consist of spring elements in neoprene cups with grommets to prevent short circuiting hanger rods and nuts and washers for pre-compression.
2. Select springs for deflection of 0.75" to 1.50" at maximum calculated thrust. Springs shall be field adjusted for 1/2" movement. Spring constant may not exceed 50% of the vertical stiffness of the mounts (M3, etc.).
3. Centrifugal fans shall incline slightly forward when off and discharge directly in line with the ductwork at maximum static pressure.
4. Fabricate structural supports as needed to attach thrust restraints.
5. If connected to a housing, check maximum thrust the housing can restrain and connections required.
6. Manufacturers:
 - a. Mason "WB" or "PC30"
 - b. Kinetics
 - c. Vibration Eliminator Co. "HTR-1"

2.4 HANGERS

A. Type H1:

1. Vibration hangers shall consist of a double-deflection neoprene element with a projecting bushing or oversized opening to prevent steel-to-steel contact.

2. Static deflection shall be at least 0.15" at calculated load and 0.35" at maximum rated load.
3. Provide hangers with end connections as required for hanging ductwork or piping.
4. Manufacturers:
 - a. Mason "HD"
 - b. Kinetics "RH"
 - c. Aeroflex "RHD"
 - d. Vibration Eliminator Co. "IC/3C/3CTD"
 - e. Vibro Acoustics "RH"

B. Type H2:

1. Vibration hangers shall contain a steel spring in a neoprene cup with a grommet to prevent short circuiting the hanger rod.
2. The cup shall have a steel washer to distribute load on the neoprene and prevent its extrusion.
3. Spring diameters and hanger box lower hole sizes shall be large enough to permit the hanger rod to swing through a 30° arc before contacting the grommet and short circuiting the spring.
4. Provide end connections for hanging ductwork or piping.
5. Manufacturers:
 - a. Mason "30"
 - b. Kinetics "SRH"
 - c. Amber/Booth "BSRA"
 - d. Aeroflex "RSH"
 - e. Vibration Eliminator Co. "SNC"
 - f. Vibro Acoustics "SH/SHC"

C. Type H3:

1. Vibration hangers shall have a steel spring in a neoprene cup with a grommet to prevent short circuiting of the hanger rod.
2. The cup shall have a steel washer to distribute load on the neoprene and prevent its extrusion.
3. Spring diameters and hanger box lower hole sizes shall be large enough to permit the hanger rod to swing through a 30° arc before contacting the grommet and short circuiting the spring.
4. Provide end connections for hanging ductwork or piping.
5. Hangers shall be capable of holding the load at a fixed elevation during installation. They shall have a secondary adjustment to transfer the load to the spring and maintain the same position.
6. Deflection shall be indicated by a pointer and scale.
7. Manufacturer:
 - a. Mason "30N"
 - b. Kinetics "SFH"
 - c. Amber/Booth "BSW"
 - d. Vibration Eliminator Co. "SNRC"
 - e. Vibro Acoustics "SHR"

2.5 BASES

A. Type B1:

1. Rectangular structural steel bases.
2. All perimeter members shall be beams or channels with minimum depth of 10% of the longest base dimension or 14" maximum if rigidity is acceptable to the equipment manufacturer.
3. Use height saving brackets, unless noted otherwise.
4. Manufacturers:
 - a. Mason "WF"
 - b. Kinetics "SBB"
 - c. Aeroflex
 - d. Vibration Eliminator Co. "AF"

B. Type B2:

1. Steel members welded to height-saving brackets to cradle machines having legs or bases that do not require complete supplementary bases.
2. Members shall be sufficiently rigid to prevent strains in the equipment.
3. Manufacturers:
 - a. Mason "ICS"
 - b. Kinetics "SFB"
 - c. Aeroflex

C. Type B3:

1. Rectangular structural channel concrete forms for floating foundations.
2. Where applicable, bases shall be large enough to support suction elbows, discharge elbows, and suction diffusers.
3. Channel depth shall be at least 1/12 the longest dimension of the base but not less than 6". Depth need not exceed 12" if rigidity is acceptable to equipment manufacturer.
4. Forms shall include 1/2" rebars welded on 6" centers running both ways in a layer 1-1/2" above the bottom, and drilled steel members with sleeves welded below the holes to receive the equipment anchor bolts.
5. Contractor shall pour 3,300 PSI concrete inside entire base. Concrete to be same thickness as sides of base. Trowel concrete smooth on top of base.
6. Use height saving brackets, unless noted otherwise.
7. Manufacturers:
 - a. Mason "K"
 - b. Kinetics "CIB-H"
 - c. Aeroflex "MPF"
 - d. Amber Booth "CPF"
 - e. Bulldog, Inc.
 - f. Vibration Eliminator Co. "SN".

2.6 FLEXIBLE CONNECTORS (NOISE AND VIBRATION ELIMINATORS)

A. Type FC1:

1. Spherical flexible connectors with multiple plies of nylon tire cord fabric and either EPDM or molded and cured neoprene. Outdoor units shall be EPDM.
2. Steel aircraft cables or threaded steel rods shall be used to prevent excess elongation.
3. All straight through connections shall be made with twin-spheres properly pre-extended as recommended by the manufacturer.
4. Connectors up to 2" size may have threaded ends.
5. Connectors 2-1/2" and over shall have floating steel flanges recessed to lock raised face neoprene flanges.
6. All connectors shall be rated for a minimum working pressure of 150 psi at 200°F.
7. Manufacturer:
 - a. Metraflex "Double Cable-Sphere"
 - b. Minnesota Flex Corp.
 - c. Mercer "200 Series"
 - d. Twin City Hose "MS2".

B. Type FC2:

1. Stainless steel flexible connectors with corrugated stainless steel hose body and stainless steel braided casing.
2. Rated for minimum working pressures of 150 psi at 70°F and 100 psi at 800°F .
3. Sizes 2" and under shall have steel threaded connections.
4. Sizes 2-1/2" and over shall have 150 lb. steel flanges.
5. Suitable for 1/2" permanent misalignment.
6. Manufacturers:
 - a. Mason or Mercer "BSS-GU"
 - b. Metraflex "ML"
 - c. Twin City Hose "TCHS"
 - d. American "BOA B4-1"
 - e. Flexible Metal Hose Company "FM-21"
 - f. or Wheatley.

PART 3 - EXECUTION

3.1 GENERAL INSTALLATION

- A. Install all products per manufacturer's recommendations.
- B. Provide vibration isolation as indicated on the drawings and as described herein.
- C. Clean the surface below all mountings that are not bolted down and apply adhesive cement equal to Mason Type WG between mounting and floor. If movement occurs, bolt mountings down. Isolate bolts from baseplates with neoprene washers and bushings.

- D. All static deflections listed in the drawings and specifications are the minimum acceptable actual deflection of the isolator under the weight of the installed equipment - not the maximum rated deflection of the isolator.
- E. Support equipment to be mounted on structural steel frames with isolators under the frames or under brackets welded to the frames. Where frames are not needed, fasten isolators directly to the equipment.
- F. Where a specific quantity of hangers is noted in these specifications, it shall mean hanger pairs for support points that require multiple hangers, such as rectangular ducts or pipes supported on a strut rack.

3.2 PIPE ISOLATION

- A. The first three hangers from vibration-isolated equipment shall be type H1.
- B. The first five hangers from vibration-isolated equipment shall have spring isolators with the same static deflection as the equipment. Use type H1 or H2 as required for the specified deflection. The next five hangers shall be type H1.
- C. For base mounted pumps without resilient mountings, the first five hangers shall be Type H1.
- D. Where piping is floor-supported, use M2 instead of H1 and M3 instead of H2.
- E. Install flexible connectors in all piping connected to vibration producing equipment. This includes all fans, base-mounted pumps, compressors, etc. Absence of flexible connectors on piping diagrams does not imply that they are not required.
- F. Use Type FC1 where pressures are lower than 150 psi, temperatures are below 220°F , and the fluid handled is compatible with neoprene and EPDM.
- G. Use Type FC2 for all other services. FC2 shall be installed parallel with equipment shafts.
- H. Provide sufficient piping flexibility for vibrating refrigerant equipment, or furnish flexible connectors with appropriate temperature and pressure ratings.
- I. Vibration isolators shall not cause any change in position of piping that will result in stresses in connections or misalignment of shafts or bearings. Equipment and piping shall be maintained in a rigid position during installation. Do not transfer load to the isolators until the installation is complete and under full operational load. Hanger H3 and Mounting M4 may be used instead of other products for this purpose.
- J. Support piping to prevent extension of flexible connectors.

3.3 VIBRATION ISOLATION SCHEDULE

A. 0.75" (Less than 3 HP) or 1.5" (3 HP and Above)

EQUIPMENT DESIGNATION	BASE TYPE	ISOLATOR TYPE	STATIC DEFLECTION	FLEXIBLE CONNECTIONS
Inline Pump(s)	NA	M3 or H2 or H3	0.75" (Less than 3HP) or 1.5" (3HP and above)	NA
Base Mounted Pump(s)	B3	M3	0.75"	FC-2

END OF SECTION 23 05 48

SECTION 23 05 53 - HVAC IDENTIFICATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Identification of products installed under Division 23.

1.2 REFERENCES

- A. ANSI/ASME A13.1 - Scheme for the Identification of Piping Systems.
- B. ASTM B-1, B-3, and B-8 for copper conductors.
- C. ASTM D-1248 for Polyethylene Extrusion Materials, ICEA S-70-547 Weatherproof Resistant Polyethylene Conductors, ICEA S-61-402/NEMA WC5 Thermoplastic Insulated Wire & Cable, ICEA S-95-658/NEMA WC70 Non-Shielded 0 - 2kV Cables.
- D. CGA Pamphlet C-9, Standard Color-Marking of Compressed Gas Cylinders for Medical Use.
- E. NFPA-99 - Health Care Facilities.
- F. UL 1581 Standard for Electrical Wires, Cables, and Flexible Cords.

1.3 SUBMITTALS

- A. Submit shop drawings under provisions of Section 23 05 00. Include list of items identified, wording, letter sizes, and color coding.
- B. Include valve chart and schedule listing valve tag number, location, function, and valve manufacturer's name and model number.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. 3M
- B. Bunting
- C. Calpico
- D. Craftmark
- E. Emedco
- F. Kolbi Industries
- G. Seton

H. W.H. Brady

I. Marking Services.

2.2 MATERIALS

A. All pipe markers (purchased or stenciled) shall conform to ANSI A13.1. Marker lengths and letter sizes shall be at least the following:

OD of Pipe or Insulation	Marker Length	Size of Letters
Up to and including 1-1/4" (32mm)	8" (200 mm)	1/2" (12 mm)
1-1/2" (40 mm) to 2" (50 mm)	8" (200 mm)	3/4" (20 mm)
2-1/2" (65 mm) to 6" (150 mm)	12" (300 mm)	1-1/4" (32 mm)
8" (200 mm) to 10" (250 mm)	24" (600 mm)	2-1/2" (65 mm)
Over 10" (250 mm)	32" (800 mm)	3-1/2" (90 mm)

Plastic tags may be used for outside diameters under 3/4" (20 mm)

B. Plastic Nameplates: Laminated three-layer phenolic with engraved black, 1/4" minimum letters on light contrasting background.

C. Aluminum Nameplates: Black enamel background with natural aluminum border and engraved letters furnished with two mounting holes and screws.

D. Plastic Tags: Minimum 1-1/2" square or round laminated three-layer phenolic with engraved, 1/4" minimum black letters on light contrasting background.

E. Brass Tags: Brass background with engraved black letters. Tag size minimum 1-1/2" square or 1-1/2" round.

F. Vinyl Pipe Markers: Colored vinyl with permanent pressure sensitive adhesive backing.

G. Stencil Painted Pipe Markers: Use industrial enamel spray paint per ANSI Standard A13.1. Indicate fluid conveyed and flow direction.

H. Underground Pipe Markers: Bright colored continuously printed plastic ribbon tape 6" wide by 3.5 mils thick, manufactured for direct burial, with aluminum foil core for location by non-ferric metal detectors and bold lettering identifying buried item.

I. Tracer Wire:

1. Single copper conductors shall be solid or stranded annealed or hard uncoated copper per UL83 and ASTM requirements. Tracer tape or copper-coated steel wire is not acceptable.
2. Conductor shall be insulated with HMWPE as specified and applied in a concentric manner. The minimum at any point shall not be less than 90% of the specified average thickness in compliance with UL 83.
3. Tracer wire shall be continuously spark tested at 7500 Volts DC. Other electrical and mechanical tests shall be in accordance with UL 1581.

J. Ductwork Markers:

1. Ductwork systems containing hazardous materials shall be provided with minimum 2" x 4" ANSI Z535.2 biohazard warning labels with custom labeling describing hazard. Refer to Part 3 for system and label description.
2. Vinyl Markers: Colored vinyl with permanent pressure sensitive adhesive backing suitable for indoor and outdoor application.

K. Maintenance Access Doors:

1. Doors and roof hatches used to access equipment serving hazardous ductwork systems shall be provided with a minimum 4" x 6" ANSI Z535.2 biohazard warning label. Label shall read "WARNING - BIOHAZARD. ONLY AUTHORIZED PERSONNEL BEYOND THIS POINT".
2. Coordinate location of warning label with Owner.

L. Ceiling Markers:

1. Label Style:

- a. The intent is for the ceiling labels to be inconspicuous but easy to find and read while standing underneath. The labels shall be located on the grid T-bar nearest the ceiling tile that can be removed to provide the best access to the serviceable side of equipment or to valves. An arrow can be used to point to the tile needing removal.
- b. The label tape shall be approximately 1/2" wide with all capitalized letters approximately 3/16" tall.
- c. Ceiling grid labels shall be made with a label maker with durable adhesive labels having a clear background and black letters.
- d. Equipment labels shall be as designated on the drawings (e.g., FCU-606B, etc.).
- e. Valve labels shall be designated by the size, service, and the valve tag number (e.g., 1-1/4" CW #123, 2" HWS #234, etc.). A single longer label can be used to identify multiple valves using spaces between the descriptors if the valves are located close together and have the same service (e.g., HWS and HWR valves serving the same equipment or CW, HW, and HWC lines serving the same restroom, etc.).
- f. Fire, fire/smoke and smoke dampers shall be labeled consistent with the type (e.g., Fire Damper, Fire/Smoke Damper, etc.),

2. "Dot" Style:

- a. The intent is for the ceiling labels to be inconspicuous but easy to find and read while standing underneath. The labels shall be located on the grid T-bar nearest the ceiling tile that can be removed to provide the best access to the serviceable side of equipment or to valves.
- b. The marker shall be a self-adhesive color dot approximately 1/2" in diameter.
- c. The equipment and accessories to be marked and dot color shall be coordinated with the Architect/Engineer and Owner.

1) Equipment and accessories to be marked:

- a) Hydronic Valves

- b) Fire Dampers
- c) Fire/Smoke and Smoke Dampers
- d) Fan Coil Units
- e) Project Specific Item

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install all products per manufacturer's recommendations.
- B. Degrease and clean surfaces to receive adhesive for identification materials.
- C. Valves:
 - 1. All valves (except shutoff valves at equipment) shall have numbered tags.
 - 2. Provide or replace numbered tags on all existing valves that are connected to new systems or that have been revised.
 - 3. Provide all existing valves used to extend utilities to this project with numbered tags. Review tag numbering sequence with the Owner prior to ordering tags.
 - 4. Secure tags with heavy duty key chain and brass "S" link or with mechanically fastened plastic straps.
 - 5. Attach to handwheel or around valve stem. On lever operated valves, drill the lever to attach tags.
 - 6. Number all tags and show the service of the pipe.
 - 7. Provide one Plexiglas framed valve directory listing all valves, with respective tag numbers, uses and locations. Mount directory in location chosen by the Architect/Engineer.
 - 8. Provide one 36" x 24" minimum Plexiglas framed piping schematic showing valve locations with respective tag numbers. Mount directory in location chosen by the Architect/Engineer.
 - 9. Provide two sets of laminated 8-1/2" x 11" (letter size) copies of a valve directory listing all valves, with respective tag numbers, uses, and locations. The directory shall be reviewed by the Owner and Architect/Engineer prior to laminating final copies. Laminated copies shall have brass eyelet in at least one corner for easy hanging.
- D. Pipe Markers:
 - 1. Adhesive Backed Markers: Use Brady Style 1, 2, or 3 on pipes 3" diameter and larger. Use Brady Style 4, 6, or 8 on pipes under 3" diameter. Similar styles by other listed manufacturers are acceptable. Secure all markers at both ends with a wrap of pressure sensitive tape completely around the pipe.
 - 2. Snap-on Markers: Use Seton "Setmark" on pipes up to 5-7/8" OD. Use Seton "Setmark" with nylon or Velcro ties for pipes 6" OD and over. Similar styles by other listed manufacturers are acceptable.
 - 3. Stencil Painted Pipe Markers:
 - a. Remove rust, grease, dirt, and all foreign substances from the pipe surface.
 - b. Apply primer on non-insulated pipes before painting.
 - c. Use background and letter colors as scheduled later in this section.

4. Apply markers and arrows in the following locations where clearly visible:
 - a. At each valve.
 - b. On both sides of walls that pipes penetrate.
 - c. At least every 20 feet along all pipes.
 - d. On each riser and each leg of each "T" joint.
 - e. At least once in every room and each story traversed.
 5. Underground Pipe Markers: Install 8" to 10" below grade, directly above buried pipes.
- E. Ductwork Markers:
1. Apply ductwork markers on ductwork systems containing hazardous materials in the following locations where clearly visible:
 - a. On both sides of walls that ducts penetrate.
 - b. At least every 20 feet along all ducts.
 - c. On each riser and each leg of each branch connection.
 - d. At least once in every room and each story traversed.
 - e. At all ductwork access doors.
 - f. At all fans and equipment serving ductwork system. Markers shall be clearly visible from the normal maintenance access path to the equipment. Coordinate placement location with Owner.
- F. Equipment:
1. All equipment not easily identifiable such as controls, relays, gauges, etc.; and all equipment in an area remote from its function such as air handling units, exhaust fans, filters, reheat coils, dampers, etc.; shall have nameplates or plastic tags listing name, function, and drawing symbol. Do not label exposed equipment in public areas.
 2. Fasten nameplates or plastic tags with stainless steel self-tapping screws or permanently bonding cement.
 3. Mechanical equipment that is not covered by the U.S. National Appliance Energy Conservation Act (NAECA) of 1987 shall carry a permanent label installed by the manufacturer stating that the equipment complies with the requirements of ASHRAE 90.1.
- G. Miscellaneous:
1. Attach self-adhesive vinyl labels at all duct access doors used to reset fusible links or actuators on fire, fire/smoke, or smoke dampers. Lettering shall be a minimum of 1/2" high. Labels shall indicate damper type.
 2. Provide engraved plastic tags at all hydronic or steam system make-up water meters.
- H. Tracer Wire:
1. Tracer wire shall be installed on top of all non-metallic buried utilities.
 2. Tracer wire shall be taped directly to plastic water or drain pipe.
 3. Tracer wire shall not be fastened directly or indirectly to gas piping.
 4. Tracer wire when attached shall be secured to the pipe a minimum of every 10 feet and at all changes of direction.

5. Tape shall be Polyken "930-35", Protecto-Wrap "310", or approved equal.
6. Tracer wire shall be continuous between boxes and shall be tested for continuity.
7. Splices in tracer wire shall be made with a water proof splice kit to prevent corrosion. Wire nuts shall not be used.
8. The tracer wire shall daylight to grade through a 2" PVC conduit, at the point of the utility entrance to building. PVC conduit shall be capped and labeled as future contact point to locate the utility.

3.2 SCHEDULE

- A. Pipes to be marked shall be labeled with text as follows, regardless of which method or material is used:
 1. HEATING WATER SUPPLY: White lettering; green background
 2. HEATING WATER RETURN: White lettering; green background
 3. Underground Piping: Varies
 4. Tracer Wire - Natural Gas Pipe Lines: Black lettering; yellow background
 5. Tracer Wire - All other buried types: White lettering; green background

END OF SECTION 23 05 53

SECTION 23 05 93 - TESTING, ADJUSTING, AND BALANCING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Testing, adjusting, and balancing of heating systems.
- B. Measurement of final operating condition of HVAC systems.

1.2 QUALITY ASSURANCE

- A. Agency shall be a company specializing in the adjusting and balancing of systems specified in this section with minimum three years' experience. Perform work under supervision of AABC Certified Test and Balance Engineer, NEBB Certified Testing, Balancing and Adjusting Supervisor, SMARTA Certified Air and Hydronic Balancer, or TABB Certified Supervisor.
- B. Work shall be performed in accordance with the requirements of the references listed at the start of this section.

1.3 REFERENCES

- A. AABC - National Standards for Total System Balance, Seventh Edition.
- B. ADC - Test Code for Grilles, Registers, and Diffusers.
- C. AMCA - Publication 203-90; Field Performance Measurement of Fan Systems.
- D. ASHRAE - 2019 HVAC Applications Handbook; Chapter 39, Testing, Adjusting and Balancing.
- E. ASHRAE/ANSI - Standard 111-2008; Practices for Measurement, Testing, Adjusting and Balancing of Building HVAC&R Systems.
- F. NEBB - Procedural Standards for Testing, Adjusting and Balancing of Environmental Systems, Ninth Edition, 2019.
- G. SMACNA - HVAC Systems; Testing, Adjusting and Balancing, Third Edition, 2002.
- H. TABB - International Standards for Environmental Systems Balance.

1.4 SUBMITTALS

- A. Submit copies of report forms, balancing procedures, and the name and qualifications of testing and balancing agency for approval within 30 days after award of Contract.

B. Electronic Copies:

1. Submit a certified copy of test reports to the Architect/Engineer for approval. Electronic copies shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Copies that are not legible will be returned to the Contractor for resubmittal. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
2. Electronic file size shall be limited to a maximum of 10MB. Larger files shall be divided into files that are clearly labeled as "1 of 2", "2 of 2", etc.
3. All text shall be searchable.
4. Bookmarks shall be used. All bookmark titles shall be an active link to the index page and index tabs.

1.5 REPORT FORMS

- A. Submit reports on AABC, SMACNA or NEBB forms. Use custom forms approved by the Architect/Engineer when needed to supply specified information.
- B. Include in the final report a schematic drawing showing each system component, including balancing devices, for each system. Each drawing shall be included with the test reports required for that system. The schematic drawings shall identify all testing points and cross-reference these points to the report forms and procedures.
- C. Refer to PART 4 for required reports.

1.6 WARRANTY/GUARANTEE

- A. The TAB Contractor shall include an extended warranty of 90 days after owner receipt of a completed balancing report, during which time the Owner may request a recheck of terminals, or resetting of any outlet, coil, or device listed in the test report. This warranty shall provide a minimum of 6 manhours of onsite service time. If it is determined that the new test results are not within the design criteria, the balancer shall rebalance the system according to design criteria.
- B. Warranty/Guarantee must meet one of the following programs: TABB International Quality Assurance Program, AABC National Project Performance Guarantee, NEBB's Conformance Certification.

1.7 SCHEDULING

- A. Coordinate schedule with other trades. Provide a minimum of seven days' notice to all trades and the Architect/Engineer prior to performing each test.
- B. Project will be constructed in phases. Provide balancing report after each phase is complete.

PART 2 - PRODUCTS (Not Used)

2.1 Manufacturers

- A. Griffith Engineer Service

- B. Fort Collins/Midwest
- C. TAB Services
- D. Lawerance Finn & Associates
- E. JPG Engineering
- F. Air-Right

PART 3 - EXECUTION

3.1 GENERAL REQUIREMENTS

- A. All procedures must conform to a published standard listed in the References article of this section. All equipment shall be adjusted in accordance with the manufacturer's recommendations. Any system not listed in this specification but installed under the contract documents shall be balanced using a procedure from a published standard listed in the References article.
- B. The Balancing Contractor shall incorporate all pertinent documented construction changes (e.g. submittals/shop drawings, change orders, RFIs, ASIs, etc.) and include in the balancing report.
- C. Recorded data shall represent actual measured or observed conditions.
- D. Cut insulation, ducts, pipes, and equipment cabinets for installation of test probes to the minimum extent necessary to allow adequate performance of procedures. After testing and balancing is complete, close probe holes and patch insulation with new materials as specified. Restore vapor barrier and finish as specified.
- E. Permanently mark setting of valves, dampers, and other adjustment devices allowing for settings to be restored. Set and lock memory stops.
- F. Leave systems in proper working order, replacing belt guards, closing access doors, closing doors to electrical switch boxes, plugging test holes, and restoring thermostats to specified settings.
- G. The Balancing Contractor shall measure terminal air box air flow, and the TCC shall adjust DDC readout to match. Refer to Section 23 09 00 for additional information.
- H. Installations with systems consisting of multiple components shall be balanced with all system components operating.

3.2 EXAMINATION

- A. Before beginning work, verify that systems are complete and operable. Ensure the following:
 - 1. General Equipment Requirements:

- a. Equipment is safe to operate and in normal condition.
- b. Equipment with moving parts is properly lubricated.
- c. Temperature control systems are complete and operable.
- d. Proper thermal overload protection is in place for electrical equipment.
- e. Direction of rotation of all fans and pumps is correct.
- f. Access doors are closed and end caps are in place.

2. Duct System Requirements:

- a. All filters are clean and in place. If required, install temporary media.
- b. Duct systems are clean and free of debris.
- c. Fire/smoke and manual volume dampers are in place, functional and open.
- d. Air outlets are installed and connected.
- e. Duct system leakage has been minimized.

3. Pipe System Requirements:

- a. Coil fins have been cleaned and combed.
- b. Hydronic systems have been cleaned, filled, and vented.
- c. Strainer screens are clean and in place.
- d. Shutoff, throttling and balancing valves are open.

- B. Report any defects or deficiencies to Architect/Engineer.
- C. Promptly report items that are abnormal or prevent proper balancing.
- D. If, for design reasons, system cannot be properly balanced, report as soon as observed.
- E. Beginning of work means acceptance of existing conditions.

3.3 PREPARATION

- A. Provide instruments required for testing, adjusting, and balancing operations. Make instruments available to the Architect/Engineer for spot checks during testing.
- B. Instruments shall be calibrated within six months of testing performed for project, or more recently if recommended by the instrument manufacturer.

3.4 INSTALLATION TOLERANCES

- A. $\pm 10\%$ of scheduled values:
 1. Adjust air inlets and outlets to $\pm 10\%$ of scheduled values.
 2. Adjust piping systems to $\pm 10\%$ of design values.
- B. $\pm 5\%$ of scheduled values:
 1. Adjust fume exhaust systems to $\pm 5\%$ of scheduled values.
 2. Adjust supply and exhaust air-handling systems for space pressurization to $\pm 5\%$ of scheduled values, and to provide proper pressurization.

- C. + 5% of scheduled values
 - 1. Adjust outdoor air intakes to within + 5% of scheduled values.
 - 2. Adjust exhaust air through energy recovery equipment to within +5% of scheduled values.
- D. Adjust supply, return, and exhaust air-handling systems to +10% / -5% of scheduled values.

3.5 ADJUSTING

- A. After adjustment, take measurements to verify balance has not been disrupted or that disruption has been rectified.
- B. Once balancing of systems is complete, at least one damper or valve must be 100% open.
- C. After testing, adjusting and balancing are complete, operate each system and randomly check measurements to verify system is operating as reported in the report. Document any discrepancies.
- D. Contractor responsible for each motor shall also be responsible for replacement sheaves. Coordinate with contractor.
- E. Contractor responsible for pump shall trim impeller to final duty point as instructed by this contractor on all pumps not driven by a VFD. Coordinate with contractor.

3.6 SYSTEM PERFORMANCE REPORT

- A. After the conclusion of balancing operations, utilize the building DDC system or install portable data loggers to simultaneously record temperatures and humidity during summer and winter conditions for a seven-day period, continuous over a weekend, and including at least one period of operation at outside conditions within 5°F wet bulb temperature of maximum summer design condition and within 10°F dry bulb temperature of minimum winter design condition.
- B. Design Conditions:
 - 1. Summer: 95 °F DB 62 °F WB
 - 2. Winter: -5 °F DB
- C. Architect/Engineer will direct all test locations.
- D. Report of test results shall include original recording and three reproductions.

3.7 SUBMISSION OF REPORTS

- A. Fill in test results on appropriate forms.
- B. Complete all applicable tests, certifications, forms, and matrices listed in the Illinois Department of Public Health (IDPH) Final Occupancy Checklist Certifications for Request of Inspection.

PART 4 - SYSTEMS TO BE TESTED, ADJUSTED AND BALANCED

4.1 GENERAL REQUIREMENTS

A. Title Page:

1. Project name.
2. Project location.
3. Project Architect.
4. Project Engineer (IMEG Corp.).
5. Project General Contractor.
6. TAB Company name, address, phone number.
7. TAB Supervisor's name and certification number.
8. TAB Supervisor's signature and date.
9. Report date.

B. Report Index

C. General Information:

1. Test conditions.
2. Nomenclature used throughout report.
3. Notable system characteristics/discrepancies from design.
4. Test standards followed.
5. Any deficiencies noted.
6. Quality assurance statement.

D. Instrument List:

1. Instrument.
2. Manufacturer, model, and serial number.
3. Range.
4. Calibration date.

4.2 HEATING SYSTEMS

A. Pump Data (Primary and Secondary Heating Water Loop Pumps):

1. Existing drawing symbol or equipment TAG
2. Service.
3. Manufacturer, size, and model.
4. Impeller size: specified, actual, and final (if trimmed).
5. Flow Rate (gpm): specified and actual.
6. Pump Head: specified, operating and shutoff.
7. Suction Pressure: Operating and shutoff.
8. Discharge Pressure: Operating and shutoff.
9. Final frequency of motor at maximum flow rate (on pumps driven by VFD).

B. Hot Water Boiler:

1. General Requirements:
 - a. Drawing symbol.
 - b. Service.
 - c. Location.
 - d. Manufacturer, model, and identification number.
 - e. Control setting: specified and actual.
2. Temperature:
 - a. Entering water temperature: specified and actual.
 - b. Leaving water temperature: specified and actual.
3. Flow Rate:
 - a. Flow rate (gpm): specified and actual.
4. Pressure Drop and Pressure:
 - a. Pressure Drop: specified and actual.
5. Energy:
 - a. Rating (Btuh).
 - b. Measured output (Btuh).

END OF SECTION 23 05 93

SECTION 23 07 19 - HVAC PIPING INSULATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Piping Insulation.
- B. Insulation Jackets.

1.2 QUALITY ASSURANCE

- A. Applicator: Company specializing in piping insulation application with five years minimum experience.
- B. Materials: Flame spread/smoke developed rating of 25/50 in accordance with ASTM E84, NFPA 255, or UL 723 (where required). Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers with appropriate markings of applicable testing agency.
- C. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- D. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.

1.3 REFERENCES

- A. ANSI/ASHRAE/IES Standard 90.1 (latest published edition) - Energy Standard for Buildings Except Low-Rise Residential Buildings.
- B. ANSI/ASTM C195 - Mineral Fiber Thermal Insulation Cement.
- C. ANSI/ASTM C533 - Calcium Silicate Block and Pipe Thermal Insulation.
- D. ANSI/ASTM C534 - Elastomeric Foam Insulation.
- E. ANSI/ASTM C547 - Mineral Fiber Preformed Pipe Insulation.
- F. ANSI/ASTM C552 - Cellular Glass Block and Pipe Thermal Insulation.
- G. ASTM C449 - Mineral Fiber Hydraulic-setting Thermal Insulating and Finishing Cement.
- H. ASTM C591 - Unfaced Preformed Rigid Cellular Polyisocyanurate Insulation.
- I. ASTM C578 - Preformed Cellular Polystyrene Thermal Insulation.

- J. ASTM C1126 - Standard Specification for Faced or Unfaced Rigid Cellular Phenolic Thermal Insulation.
- K. ASTM C1729 - Standard Specification for Aluminum Jacketing for Insulation.
- L. ASTM C1767 - Standard Specification for Stainless Steel Jacketing for Insulation.
- M. ASTM E84 - Surface Burning Characteristics of Building Materials.
- N. NFPA 255 - Surface Burning Characteristics of Building Materials.
- O. UL 723 - Surface Burning Characteristics of Building Materials.
- P. National Commercial & Industrial Insulation Standards - 1999 Edition - as published by Midwest Insulation Contractors Association and endorsed by National Insulation Contractors Association.

1.4 SUBMITTALS

- A. Submit shop drawings per Section 23 05 00. Include product description, list of materials and thickness for each service, and locations.

PART 2 - PRODUCTS

2.1 INSULATION

- A. Type A: Glass fiber; ANSI/ASTM C547; 0.24 maximum 'K' value at 75°F; non-combustible. All-purpose polymer or polypropylene service jacket, 25/50 flame spread/smoke developed rating when tested in accordance with ASTM E84 (UL 723).

2.2 VAPOR BARRIER JACKETS

- A. All-purpose polymer or polypropylene service jacket vapor barrier with self-sealing adhesive joints. Beach puncture resistance ratio of at least 50 units. Tensile strength: 35 psi minimum. Single, self-seal acrylic adhesive on longitudinal jacket laps and butt strips.
- B. Polyvinylidene Chloride (PVDC or Saran) film and tape: Durable and highly moisture and moisture vapor resistant. Please refer to manufacturer's recommended installation guidelines.

2.3 JACKET COVERINGS

- A. Plastic Jackets and Fitting Covers: High impact, glossy white, 0.020" thick, self-extinguishing plastic. Suitable for use indoors or outdoors with ultraviolet inhibitors. Suitable for -40°F to 150°F. 25/50 maximum flame spread/smoke developed.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Install insulation after piping has been tested. Pipe shall be clean, dry and free of rust before applying insulation.
- B. Patch and repair torn insulation. Paint to match adjacent insulation surface.

3.2 INSTALLATION

A. General Installation Requirements:

- 1. Install materials per manufacturer's instructions, building codes and industry standards.
- 2. Continue insulation with vapor barrier through penetrations. This applies to all insulated piping. Maintain fire rating of all penetrations.
- 3. All piping and insulation that does not meet 25/50 that is in an air plenum shall have written approval from the Authority Having Jurisdiction and the local fire department for authorization and materials approval. If approval has been allowed, the non-rated material shall be wrapped with a product that has been listed and labeled having a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested as a composite in accordance with ASTM E84 or UL 723.
- 4. On 1" and smaller piping routed through metal wall studs, provide a plastic grommet to protect the piping. The piping shall be insulated between the wall studs, and the insulation shall butt up to each stud.

B. Insulated Piping Operating Below 60°F:

- 1. Insulate fittings, valves, unions, flanges, flexible connections, flexible hoses, and expansion joints. Seal all penetrations of vapor barrier.
- 2. All balance valves and strainers with fluid operating below 60°F shall be insulated with a removable plug wrapped with vapor barrier tape to allow access for reading and adjusting of the balancing valve and cleaning and servicing of the balancing valve.

C. Insulated Piping Operating Between 60°F and 140°F:

- 1. Do not insulate flanges and unions, but bevel and seal ends of insulation at such locations. Insulate all fittings, valves and strainers.

D. Insulated Piping Operating Above 140°F:

- 1. Insulate fittings, valves, flanges, float & thermostatic steam traps, and strainers. On gate valves, the insulation shall be extended to cover the entire valve bonnet, leaving only the portion of the stem that is above the bonnet and valve operator exposed.
- 2. All balance valves with fluid operating above 140°F shall be insulated and an opening shall be left in the insulation to allow for reading and adjusting the valve.
- 3. The use of removable insulation jackets is acceptable for insulating large and non-cylindrical shaped piping components (e.g., check valves, pressure regulating valves, calibrated balance valves, gate valve bonnets, F&T traps, strainers, line sets, and the like).

E. Refrigerant Piping:

1. On refrigerant piping (25°F and above) and not required to meet the 25/50 flame/smoke, provide at each strut or clevis support an insulation coupling to support pipe and to accept insulation thickness of adjoining insulation, to prevent insulation from sagging and crushing. The coupling shall be suitable for planned temperatures, use with specified pipe material, and shall be a 360°, one-piece cylindrical segment. Use mechanical fasteners where coupling cannot be installed on pipe during installation. Contractor shall apply adhesive to ends of insulation entering insulation coupling to maintain vapor barrier.

F. Exposed Piping:

1. Locate and cover seams in least visible locations.
2. Where exposed insulated piping extends above the floor, provide a sheet metal guard around the insulation extending 12" above the floor. Guard shall be 0.016" cylindrical smooth or stucco aluminum and shall fit tightly to the insulation.

3.3 SUPPORT PROTECTION

A. Provide a shield on all insulated piping at each support between the insulation jacket and the support.

B. On all insulated piping greater than 1-1/2", provide shield with insulation insert of same thickness and contour as adjoining insulation at each support, between the pipe and insulation jacket, to prevent insulation from sagging and crushing. Inserts shall be as follows:

1. The insert shall be suitable for planned temperatures, be suitable for use with specific pipe material, and shall be a minimum 180° cylindrical segment the same length as metal shields. Inserts shall be:
 - a. Molded hydrous calcium silicate (only use for pipes with operating temperatures above 90°F, with a minimum compressive strength of 100 psi is acceptable for pipe sizes 14" and below. For pipe sizes larger than 14", provide rolled steel plate in addition to the shield.
 - b. As an alternative to separate pipe insulation insert and saddle, properly sized manufactured integral rigid insulation insert and shield assemblies may be used.
 - 1) Products:
 - a) Buckaroo CoolDry
 - b) Cooper/B-Line Fig. B3380 through B3384
 - c) Pipe Shields A1000, A2000
 - c. Insulation Couplings:
 - 1) Molded thermoplastic slip coupling, -65°F to 275°F, sizes up to 4-1/8" OD, and receive insulation thickness up to 1". Suitable for use indoors or outdoors with UV stabilizers. Vertical insulation riser clamps shall have a 1,000lb vertical load rating. On cold pipes operating below 60°F, cover joint and coupling with vapor barrier mastic to ensure continuous vapor barrier.

- 2) Horizontal Strut Mounted Insulated Pipe Manufacturers:
 - a) Klo-Shure or equal
- 3) Vertical Manufacturers:
 - a) Manufacturers: Klo-Shure Titan or equal
- d. Rectangular blocks, plugs, or wood material are not acceptable.
- e. Temporary wood blocking may be used by the Piping Contractor for proper height; however, these must be removed and replaced with proper inserts by the Insulation Contractor. Refer to Supports and Anchors specification section for additional information.

- C. Neatly finish insulation at supports, protrusions, and interruptions.
- D. Install metal shields between all hangers or supports and the pipe insulation. Shields shall be galvanized sheet metal, half-round with flared edges. Adhere shields to insulation. On cold piping, seal the shields vapor-tight to the insulation as required to maintain the vapor barrier, or add separate vapor barrier jacket.
- E. Shields shall be at least the following lengths and gauges:

<u>Pipe Size</u>	<u>Shield Size</u>
1/2" to 3-1/2"	12" long x 18 gauge
4"	12" long x 16 gauge
5" to 6"	18" long x 16 gauge
8" to 14"	24" long x 14 gauge
16" to 24"	24" long x 12 gauge

- F. Ferrous hot piping 4 inches and larger, provide steel saddle at rollers as described in Section 23 05 29 "HVAC Supports and Anchors".
- G. Minimum 1/4" rolled galvanized steel plates shall be provided in addition to the sleeves as reinforcement on large pipes to reduce point loading on roller, trapeze hanger and strut support locations depending on insulation compressive strength. Refer to section above for exact locations.

3.4 INSULATION

- A. Type A Insulation:
 - 1. All Service Jackets: Seal all longitudinal joints with self-seal laps using a single pressure sensitive adhesive system. Do not staple.
 - 2. Insulation without self-seal lap may be used if installed with Benjamin Foster 85-20 or equivalent Chicago Mastic, 3M or Childers lap adhesive.
 - 3. Apply insulation with laps on top of pipe.

4. Fittings, Valve Bodies and Flanges: For 4" and smaller pipes, insulate with 1 lb. density insulation wrapped under compression to a thickness equal to the adjacent pipe insulation. For pipes over 4", use mitered segments of pipe insulation. Finish with preformed plastic fitting covers. Secure fitting covers with pressure sensitive tape at each end. Overlap tape at least 2" on itself. For pipes operating below 60°F, seal fitting covers with vapor retarder mastic in addition to tape.

3.5 JACKET COVER INSTALLATION

A. Metal Covering:

1. Provide vapor barrier as specified for insulation type. Cover with jacket covering with seams located on the bottom of horizontal piping. Include fittings, joints and valves.
2. Seal all interior and exterior butt joints with metal draw bands and sealant. Seal all exterior joints watertight.
3. Interior joints do not need to be sealed.
4. Use metal covering on the following pipes:
 - a. All exterior piping.
 - b. Engine exhaust piping (interior).
 - c. All exposed piping in finished spaces.
 - d. All exposed piping in areas noted on drawings.
5. Use colored aluminum jacket covers on the following pipes:
 - a. All exterior piping.

B. . Plastic Covering:

1. Provide vapor barrier as specified for insulation type. Cover with plastic jacket covering. Position seams to shed water.
2. Solvent weld all joints with manufacturer recommended cement.
3. Overlap all laps and butt joints 1-1/2" minimum. Repair any loose ends that do not seal securely. Solvent weld all fitting covers in the same manner. Final installation shall be watertight.
4. All joints in areas noted shall meet USDA standards for Totally Sealed Systems, including overlaps of 1" on circumferential and 1.5" to 2" on longitudinal seams.
5. Use plastic insulation covering on all exposed pipes including, but not limited to:
 - a. All exposed piping in finished spaces.
 - b. All exposed piping in areas noted on drawings.
 - c. All exposed piping in locker rooms.
 - d. All exposed piping below 8'-0" above floor.
 - e. All piping in mechanical rooms and/or tunnels that is subject to damage from normal operations. (Example: Piping that must be stepped over routinely.)
 - f. All kitchen areas.
6. Elastomeric piping insulation may have two coats of latex paint instead of plastic jacket.
7. Use colored plastic covering on the following pipes:
 - a. All exterior piping.

3.6 SCHEDULE

- A. Refer to drawings for insulation schedule.

END OF SECTION 23 07 19

SECTION 23 09 00 - CONTROLS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Complete System of Automatic Controls.
- B. Control Devices, Components, Wiring and Material.
- C. Instructions for Owners.
- D. Remodeling.

1.2 QUALITY ASSURANCE

- A. Manufacturer: Company specializing in manufacturing the products specified in this Section with minimum five years' experience.
- B. TCC: Company specializing in the work of this section with minimum five years temperature control experience.
- C. Technician: Minimum five years' experience installing commercial temperature control systems.
- D. TCCs are limited to firms regularly employing a minimum of five full-time temperature control technicians within 100 miles of the job site.

1.3 REFERENCES

- A. AMCA 500 - Test Methods for Louvers, Dampers and Shutters.
- B. ANSI/ASHRAE/IES Standard 90.1 (latest published edition) - Energy Standard for Buildings Except Low-Rise Residential Buildings.
- C. ANSI/ASHRAE Standard 135-2001: BACnet® - A Data Communication Protocol for Building Automation and Control Networks, including all amendments.
- D. ANSI/NEMA 250 - Enclosures for Electrical Equipment (1000 volts Maximum).
- E. ANSI/NFPA 70 - National Electrical Code.
- F. ANSI/NFPA 90A - Installation of Air-Conditioning and Ventilation Systems.
- G. ASHRAE 62.1 - Ventilation for Acceptable Indoor Air Quality.
- H. ASHRAE 85 - Automatic Control Terminology for Heating, Ventilating, Air Conditioning.
- I. ANSI/ASME B16.22 - Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
- J. ANSI/ASTM B32 - Solder Metal.

- K. ASTM B280 - Seamless Copper Tube for Air Conditioning & Refrigeration Field Service.
- L. ASTM D1693 - Environmental Stress - Cracking of Ethylene Plastics.

1.4 SUBMITTALS

A. Equipment Coordination:

1. The Controls Contractor shall obtain approved equipment submittals from other contractors to determine equipment wiring connections, to choose appropriate controllers, and to provide programming.
2. Control valve selections shall be based on flow rates shown in approved shop drawings.
3. Coordinate the control interface of all equipment with the equipment manufacturers prior to submittal submission.

B. Shop Drawings:

1. Submit shop drawings per Section 23 05 00. In addition, submit an electronic copy of the shop drawings in Adobe Acrobat (.pdf) format to the Owner for review.
2. Cross-reference all control components and point names in a single table located at the beginning of the submittal with the identical nomenclature used in this section.
3. Submittal shall also include a trunk cable schematic diagram depicting operator workstations, control panel locations and a description of the communication type, media and protocol.
4. System Architecture: Provide riser diagrams of wiring between central control unit and all control panels. This shall include specific protocols associated with each level within the architecture. Identify all interface equipment between CPU and control panels. The architecture shall include interface requirements with other systems including, but not limited to, security systems, lighting control, fire alarm, elevator status, and power monitoring system.
5. Diagrams shall include:
 - a. Wiring diagrams and layouts for each control panel showing all termination numbers.
 - b. Schematic diagrams for all control, communication, and power wiring. Provide a schematic drawing of the central system installation. Label all cables and ports with computer manufacturers' model numbers and functions. Show all interface wiring to the control system.
 - c. Identification of all control components connected to emergency power.
 - d. Schematic diagrams for all field sensors and controllers.
 - e. A schematic diagram of each controlled system. The schematics shall have all control points labeled. The schematics shall graphically show the location of all control elements in the system.
 - f. A schematic wiring diagram for each controlled system. Each schematic shall have all elements labeled. Where a control element is the same as that shown on the control system schematic, label it with the same name. Label all terminals.
 - g. A tabular instrumentation list for each controlled system. The table shall show element name, type of device, manufacturer, model number and product data sheet number.

- h. All installation details and any other details required to demonstrate that the system will function properly.
 - i. All interface requirements with other systems.
6. The network infrastructure shall conform to the published guidelines for wire type, length, number of nodes per channel, termination, and other relevant wiring and infrastructure criteria as published. The number of nodes per channel shall be no more than 80% of the defined segment (logical or physical) limit in order to provide future system enhancement with minimal infrastructure modifications.
7. Sequences: Submit a complete description of the operation of the control system, including sequences of operation. The description shall include and reference a schematic diagram of the controlled system. The wording of the control sequences in the submittal shall match verbatim that included in the construction documents to ensure there are no sequence deviations from that intended by the Architect/Engineer. Clearly highlight any deviations from the specified sequences on the submittals.
8. Points List Schedule: Submit a complete points list of all points to be connected to the TCS and FMCS. The points list for each system controller shall include both inputs and outputs (I/O), point number, the controlled device associated with the I/O point, the location of the I/O device, and reference drawings. Where a control point is the same as that shown on the control system schematic, label it with the same name. Points list shall specifically identify alarms, trends, event history, archive, totalization, graphic points, and all mapped points from other systems (security systems, lighting control, fire alarm, etc.). Provide points lists, point naming convention, and factory support information for systems provided and integrated into the FMCS.
9. Damper Schedule: Schedule shall include a separate line for each damper and a column for each of the damper attributes:
 - a. Damper Identification Tag.
 - b. Location.
 - c. Damper Type.
 - d. Damper Size.
 - e. Duct Size.
 - f. Arrangement.
 - g. Blade Type.
 - h. Velocity.
 - i. Pressure Drop.
 - j. Fail Position.
 - k. Actuator Identification Tag.
 - l. Actuator Type.
 - m. Mounting.
10. Valve Schedule: Valve manufacturer shall size valves and create a valve schedule. Schedule shall include a separate line for each valve and a column for each of the valve attributes:
 - a. Valve Identification Tag.
 - b. Location.
 - c. Valve Type.
 - d. Valve Size.
 - e. Pipe Size.
 - f. Configuration.

- g. Flow Characteristics.
 - h. Capacity.
 - i. Valve CV.
 - j. Design Pressure Drop.
 - k. Pressure Drop at Design Flow.
 - l. Fail Position.
 - m. Close-off Pressure.
 - n. Valve and Actuator Model Number and Type.
11. Product Data Sheets: Required for each component that includes: unique identification tag that is consistent throughout the submittal, manufacturer's description, technical data, performance curves, installation/maintenance instructions, and other relevant items. When manufacturer's literature applies to a product series rather than a specific product, the data specifically applicable to the project shall be highlighted or clearly indicated by other means. Each submitted piece of literature and drawings shall clearly reference the specification and/or drawing that the submittal is to cover. General catalogs shall not be accepted as cutsheets to fulfill submittal requirements.
 12. Provide PICS files indicating the BACnet functionality and configuration of each device.
 13. Provide documentation of submitted products that have been tested and listed by the BACnet Testing Laboratory (BTL), or provide a letter on the manufacturer's company letterhead indicating the anticipated date by which testing is expected to be completed. If, for any reason, BTL testing and listing has not been completed, a written commitment to upgrade installed controls to a version that meets BTL testing and listing requirements if problems are found during BTL testing is required.
 14. Graphic Display: Include a sample graphic of each system and component identified in the points list with a flowchart (site map) indicating how the graphics are to be linked to each other for system navigation.
 15. Software: A list of operating system software, operator interface software, color graphic software, and third-party software.
 16. Control System Demonstration and Acceptance: Provide a description of the proposed process, along with all reports and checklists to be used.
 17. Clearly identify work by others in the submittal.
 18. Quantities of items submitted may be reviewed but are the responsibility of the Contractor to verify.

C. Operation and Maintenance Manual:

1. In addition to the requirements of Section 23 05 00, submit an electronic copy of the O&M manuals in PDF format.
2. Provide three complete sets of manuals.
3. Each O&M manual shall include:
 - a. Table of contents with indexed tabs dividing information as outlined below.
 - b. Definitions: List of all abbreviations and technical terms with definitions.
 - c. Warranty Contacts: Names, addresses, and 24-hour telephone numbers of contractors installing equipment and controls and service representatives of each.
 - d. Licenses, Guarantees, and Warranties: Provide documentation for all equipment and systems.
 - e. System Components: Alphabetical list of all system components, with the name, address, and telephone number of the vendor.

- f. Operating Procedures: Include procedures for operating the control systems; logging on/off; enabling, assigning, and reporting alarms; generating reports; collection, displaying, and archiving of trended data; overriding computer control; event scheduling; backing up software and data files; and changing setpoints and other variables.
- g. Programming: Description of the programming language (including syntax), statement descriptions (including algorithms and calculations used), point database creation and modification, program creation and modification, and use of the editor.
- h. Engineering, Installation, and Maintenance: Explain how to design and install new points, panels, and other hardware; recommended preventive maintenance procedures for all system components, including a schedule of tasks (inspection, cleaning, calibration, etc.), time between tasks, and task descriptions; how to debug hardware problems; and how to repair or replace hardware. A list of recommended spare parts.
- i. Original Software: Complete original issue CDs for all software provided, including operating systems, programming language, operator workstation software, and graphics software.
- j. Software: One set of CDs containing an executable copy of all custom software created using the programming language, including the setpoints, tuning parameters, and object database.
- k. Graphics: A glossary or icon symbol library detailing the function of each graphic icon and graphics creation and modification. One set of CDs containing files of all color graphic screens created for the project.

D. Training Manual:

- 1. Provide a course outline and training manuals for each training class.

E. Record Documents:

- 1. Submit record documentation per Section 23 05 00.
- 2. Provide a complete set of "as-built" drawings and application software on CDs. Provide drawings as AutoCAD or Visio compatible files. Provide two copies of the "as-built" drawings with revisions clearly indicated in addition to the documents on compact disk. All as-built drawings shall also be installed on the FMCS server in a dedicated directory. Provide all product data sheets in PDF format.
- 3. Submit two hard copies and one electronic copy of as-built versions of the shop drawings, including product data and record drawings with revisions clearly indicated. Provide floor plans showing actual locations of control components including panels, thermostats, sensors, and hardware.
- 4. Provide all completed testing and commissioning reports and checklists, along with all trend logs for each system identified in the points lists.
- 5. Submit printouts of all graphic screens with current values (temperatures, pressures, etc.) to the A/E verifying completion and proper operation of all points.

1.5 DELIVERY, STORAGE AND HANDLING

- A. Provide factory-shipping cartons for each piece of equipment and control device. Maintain cartons through shipping, storage, and handling as required to prevent equipment damage. Store equipment and materials inside and protected from weather.

- B. Factory-Mounted Components: Where control devices specified in this section are indicated to be factory mounted on equipment, arrange for shipping control devices to unit manufacturer.

1.6 PRODUCTS FURNISHED BUT NOT INSTALLED UNDER THIS SECTION

- A. Control Valves.
- B. Flow Switches.
- C. Temperature Sensor Sockets.
- D. Gauge Taps.
- E. Automatic Dampers.
- F. Flow Meters.

1.7 AGENCY AND CODE APPROVALS

- A. All products shall have the following agency approvals. Provide verification that the approvals exist for all submitted products with the submittal package.
 - 1. UL-916; Energy Management Systems.
 - 2. C-UL listed to Canadian Standards Association C22.2 No. 205-M1983 "Signal Equipment."
 - 3. EMC Directive 89/336/EEC (European CE Mark).
 - 4. FCC, Part 15, Subpart J, Class A Computing Devices.

1.8 ACRONYMS

- A. Acronyms used in this specification are as follows:
 - 1. B-AAC BACnet Advanced Application Controller
 - 2. B-ASC BACnet Application Specific Controller
 - 3. BTL BACnet Testing Laboratories
 - 4. DDC Direct Digital Controls
 - 5. FMCS Facility Management and Control System
 - 6. GUI Graphic User Interface
 - 7. IBC Interoperable BACnet Controller
 - 8. IDC Interoperable Digital Controller
 - 9. LAN Local Area Network
 - 10. NAC Network Area Controller
 - 11. ODBC Open DataBase Connectivity
 - 12. OOT Object Oriented Technology
 - 13. OPC Open Connectivity via Open Standards
 - 14. PICS Product Interoperability Compliance Statement
 - 15. PMI Power Measurement Interface
 - 16. POT Portable Operator's Terminal
 - 17. TCC Temperature Control Contractor
 - 18. TCS Temperature Control System

19. WAN Wide Area Network
20. WBI Web Browser Interface

1.9 SUMMARY

- A. Provide new standalone FMCS for this project.
- B. Extend Existing System:
 1. Extend the existing FMCS for this project.
 2. All controllers and accessories shall interface with the existing FMCS.
- C. Owner Furnished System:
 1. Owner will furnish FMCS panels, sensors, etc. installed under this contract. Reference control diagrams issued with these documents for required monitoring by this system.
 2. The Temperature Control Contractor (TCC) shall receive, store, protect and install the FMCS products supplied by the Owner. These will consist of FMCS panels and subassemblies, prewired outboard gear cabinets (prewired to terminal strips), and those input sensors identified in the project points lists. All work to install this equipment, as well as the necessary piping and wiring, are the responsibility of the TCC. The TCC shall also receive control system drawings provided by the FMCS system manufacturer. The TCC shall create integrated system drawings showing all work provided by the TCC and by the Owner. The Owner will provide a completely functioning operating software package for each FMCS Panel. The Owner will employ the manufacturer to commission the FMCS system hardware. The TCC shall provide manpower at the jobsite whenever the Owner's FMCS supplier is commissioning the system.
- D. TCC shall furnish all labor, materials, equipment, and service necessary for a complete and operating Temperature Control System (TCS) and Facility Management and Control System (FMCS) using Direct Digital Controls as shown on the drawings and as described herein.
- E. All labor, material, equipment and software not specifically referred to herein or on the plans that is required to meet the intent of this specification shall be provided without additional cost to the Owner.
- F. The Owner shall be the named license holder of all software associated with any and all incremental work on the project.
- G. Provide Critical Environment Control System (refer to Section 23 09 20)

1.10 SYSTEM DESCRIPTION

- A. The entire TCS shall be comprised of a network of interoperable, standalone digital controllers communicating via the following protocol to an NAC. Temperature Control System products shall be as specified below.
- B. The FMCS shall include Network Area Controller or Controllers (NAC) within each facility. The NAC shall connect to the Owner's local or wide area network, depending on configuration. Provide access to the system, either locally in each building or remotely from a central site or sites, through standard Web browsers, via the Internet, and/or via local area network.

- C. Provide materials and labor necessary to connect factory supplied control components.
- D. Provide central and remote hardware, software, and interconnecting wire and conduit.
- E. The FMCS shall include automated alarming software capable of calling e-mail compatible cellular telephones and pagers. The e-mail alarm paging system shall be able to segregate users, time schedules, and equipment and be capable of being programmed by the Owner.
- F. For the dedicated configuration tool provided, it is preferable that it be launched from within the applicable Network Management Software. If not, include any software required for controller configuration as a leave-behind tool with enough license capability to support the installation.
- G. For each operator workstation provided, furnish one legal copy of all software tools, configuration tools, management tools, and utilities used during system commissioning and installation. All tools shall be readily available in the market. Contractor shall convey to the Owner all software tools and their legal licenses at project closeout.

1.11 SOFTWARE LICENSE AGREEMENT

- A. The Owner shall be the named license holder of all software associated with any and all incremental work on the project(s). In addition, the Owner shall receive ownership of all job-specific configuration documentation, data files, configuration tools, and application-level software developed for the project. This shall include, but is not limited to, all custom, job-specific software code and documentation for all configuration and programming that is generated for a given project and/or configured for use with the NAC, FMCS Server(s), and any related LAN/WAN/intranet and/or Internet connected routers and devices. Provide the Owner with all required IDs and passwords for access to any component or software program. The Owner shall determine which organizations shall be named in the SI organization ID ("orgid") of all software licenses. Owner shall be free to direct the modification of the "orgid" in any software license, regardless of supplier.

1.12 JOB CONDITIONS

- A. Cooperation with Other Trades: Coordinate the Work of this section with that of other sections to ensure that the Work will be carried out in an orderly fashion. It is this Contractor's responsibility to check the Contract Documents for possible conflicts between the Work of this section and that of other crafts in equipment location; pipe, duct and conduit runs; electrical outlets and fixtures; air diffusers; and structural and architectural features.

1.13 WARRANTY

- A. Refer to Section 23 05 00 for warranty requirements.
- B. Within the warranty period, any defects in the work provided under this section due to faulty materials, methods of installation or workmanship shall be promptly (within 48 hours after receipt of notice) repaired or replaced by this Contractor at no expense to the Owner.
- C. Warranty requirements include furnishing and installing all FMCS software upgrades issued by the manufacturer during the one-year warranty period.

- D. Update all software and back-ups during warranty period and all user documentation on the Owner's archived software disks.

1.14 WARRANTY ACCESS

- A. The Owner shall grant to this Contractor reasonable access to the TCS and FMCS during the warranty period.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. BACnet Protocol:
 - 1. Honeywell - Bacon Elementary School - Building Technology Systems (BTS)
 - 2. Schneider Controls - Webber Middle School - Shepardson Elementary School - Long Building Technologies.

2.2 SYSTEM ARCHITECTURE

- A. General:
 - 1. The Temperature Control System (TCS) and Facility Management Control System (FMCS) shall consist of a network of interoperable, standalone digital controllers, a computer system, graphic user interface software, printers, network devices, valves, dampers, sensors, and other devices as specified herein.
 - 2. The installed system shall provide secure password access to all features, functions and data contained in the overall FMCS.
- B. Open, Interoperable, Integrated Architectures:
 - 1. All components and controllers supplied under this Division shall be true "peer-to-peer" communicating devices. Components or controllers requiring "polling" by a host to pass data are not acceptable.
 - 2. The supplied system must be able to access all data using standard Web browsers without requiring proprietary operator interface and configuration programs. An Open DataBase Connectivity (ODBC) or Structured Query Language (SQL) compliant server database is required for all system database parameter storage. This data shall reside on a supplier-installed server for all database access. Systems requiring proprietary database and user interface programs are not acceptable.
 - 3. Hierarchical or "flat" topologies are required to have system response times as indicated below and to manage the flow and sharing of data without unduly burdening the customer's internal intranet network.
 - a. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 5 seconds for network connected user interfaces.
 - b. Maximum acceptable response time from any alarm occurrence (at the point of origin) to the point of annunciation shall not exceed 60 seconds for remote or dial-up connected user interfaces.

2.3 NETWORKS

- A. The Local Area Network (LAN) shall be a 100 megabits/sec Ethernet network supporting BACnet, Java, XML, HTTP, and SOAP. Provide support for multiple Network Area Controllers (NACs), user workstations and, if specified, a local server.
- B. Local area network minimum physical and media access requirements:
 - 1. Ethernet; IEEE Standard 802.3.
 - 2. Cable; 100 Base-T, UTP-8 wire, Category 6.
 - 3. Minimum throughput; 100 Mbps.
- C. Communication conduits shall not be installed closer than six feet from 110VAC or higher transformers or run parallel within six feet of electrical high-power cables. Route the cable as far from interference generating devices as possible. Where communication wire must cross 110VAC or higher wire, it must do so at right angles.
- D. Ground all shields (earth ground) at one point only to eliminate ground loops. Provide all shield grounding at the controller location, with the shield at the sensor/device end of the applicable wire being left long and "safed" off in an appropriate manner.
- E. There shall be no power wiring more than 30 VAC rms run in conduit with communications wiring. In cases where signal wiring is run in conduit with communication wiring, run all communication wiring and signal wiring using separate twisted pairs (24awg) in accordance with the manufacturer's wiring practices.

2.4 REMOTE NETWORK ACCESS

- A. For Local Area Network installations, provide access to the LAN from a remote location via the Internet. The Owner shall provide a connection to the Internet to enable this access via high speed cable modem, asynchronous digital subscriber line (ADSL) modem, ISDN line, T1 Line or via the customer's intranet to a corporate server providing access to an Internet Service Provider (ISP). Customer agrees to pay monthly access charges for connection and ISP.

2.5 NETWORK AREA CONTROLLER (NAC)

- A. The TCC shall supply one or more Network Area Controllers (NAC) as part of this contract. Number of NACs required depends on the type and quantity of devices provided under Divisions 23 and 26. The TCC shall determine the quantity and type of devices.
- B. Each NAC shall provide the interface between the LAN or WAN and the field control devices and shall provide global supervisory control functions over the control devices connected to the NAC. It shall execute application control programs to provide:
 - 1. Calendar functions.
 - 2. Scheduling.
 - 3. Trending.
 - 4. Alarm monitoring and routing.
 - 5. Time synchronization.
 - 6. Integration of all controller data.
 - 7. Network Management functions.

- C. The Network Area Controller shall provide the following hardware features as a minimum:
1. One Ethernet Port - 10/100 Mbps.
 2. One RS-232 port.
 3. One RS-485 port.
 4. Battery backup.
 5. Flash memory for long-term data backup. (If battery backup or flash memory is not supplied, the controller shall contain a hard disk with at least 1 gigabyte storage capacity.)
 6. The NAC must be capable of operation over a temperature range of 32°F to 122°F.
 7. The NAC must be capable of withstanding storage temperatures of between 0°F and 158°F.
 8. The NAC must be capable of operation over a humidity range of 5% RH to 95% RH, non-condensing.
- D. The NAC shall provide multiple user access to the system and support for ODBC or SQL. Databases resident on the NAC shall be ODBC-compliant or must provide an ODBC data access mechanism to read and write data stored within it.
- E. The NAC shall support standard Web browser access via the Internet or an intranet and a minimum of five (5) simultaneous users.
- F. Event Alarm Notification and Actions:
1. The NAC shall provide alarm recognition, storage; routing, management, and analysis to supplement distributed capabilities of equipment or application specific controllers.
 2. The NAC shall be able to route any alarm condition to any defined user location whether connected to a LAN, remote via dial-up telephone connection, or WAN.
 3. Alarm generation shall be selectable for annunciation type and acknowledgement requirements including, but not limited to:
 - a. Alarm
 - b. Normal
 4. Provide for the creation of a minimum of eight alarm classes with different routing and acknowledgement properties, e.g. security, HVAC, Fire, etc.
 5. Provide timed (scheduled) routing of alarms by class, object, group, or node.
 6. Provide alarm generation from binary object "runtime" and/or event counts for equipment maintenance. The user shall be able to reset runtime or event count values with appropriate password control.
- G. Treat control equipment and network failures as alarms and annunciated.
- H. Annunciate alarms in any of the following manners as defined by the user:
1. Screen message text.
 2. E-mail of the complete alarm message to multiple recipients. Provide the ability to route and e-mail alarms based on:
 - a. Day of week.
 - b. Time of day.

- c. Recipient.
 - 3. Pagers via paging services that initiate a page on receipt of e-mail message.
 - 4. Graphic with flashing alarm object(s).
 - 5. Printed message, routed directly to a dedicated alarm printer.
 - I. The FMCS shall record the following for each alarm:
 - 1. Time and date.
 - 2. Location (building, floor, zone, office number, etc.).
 - 3. Equipment tag.
 - 4. Acknowledge time, date, and user who issued acknowledgement.
 - 5. Number of occurrences since last acknowledgement.
 - J. Give defined users proper access to acknowledge any alarm.
 - K. A log of all alarms shall be maintained by the NAC and/or a server (if configured in the system) and shall be available for review by the user.
 - L. Provide a "query" feature to allow review of specific alarms by user-defined parameters.
 - M. A separate log for system alerts (controller failures, network failures, etc.) shall be provided and available for review by the user.
 - N. An error log to record invalid property changes or commands shall be provided and available for review by the user.
- 2.6 BACNET FMCS
- A. The intent of this specification is to provide a peer-to-peer networked, standalone, distributed control system with the capability to integrate ANSI/ASHRAE Standard 135-2001 BACnet, MODBUS, OPC, and other open and proprietary communication protocols in one open, interoperable system.
 - B. The supplied computer software shall employ object-oriented technology (OOT) for representation of all data and control devices in the system. Adherence to industry standards including the latest ANSI/ASHRAE Standard 135 (BACnet) to assure interoperability between all system components is required. For each BACnet device, the device supplier must provide a PICS document showing the installed device's compliance level. Minimum compliance is Level 3; with the ability to support data read and write functionality. Physical connection of BACnet devices shall be via Ethernet (BACnet Ethernet/IP) and/or RS-485 (BACnet MSTP).
 - C. Interoperable BACnet Controller (IBC):
 - 1. Controls shall be microprocessor based Interoperable BACnet Controllers (IBC) in accordance with the latest ANSI/ASHRAE Standard 135. Provide IBCs for unit ventilators, fan coils, heat pumps, terminal air boxes (TAB) and other applications. The application control program shall reside in the same enclosure as the input/output circuitry that translates the sensor signals. Provide a PICS document showing the installed system's compliance level to ANSI/ASHRAE Standard 135. Minimum compliance is Level 3.

2. The IBCs shall be listed by the BACnet Testing Laboratory (BTL) as follows:
 - a. BACnet Building Controller(s) (B-BC).
 - b. BACnet Advanced Application Controller(s) (B-ACC).
 - c. BACnet Application Specific Controller(s) (B-ASC).
3. The IBCs shall communicate with the NAC via an Ethernet connection at a baud rate of not less than 10 Mbps.
4. Each IBC sensor shall connect directly to the IBC and shall not use any of the I/O points of the controller. The IBC Sensor shall provide a two-wire connection to the controller that is polarity and wire type insensitive. The IBC sensor shall provide a communications jack for connection to the BACnet communication trunk to which the IBC controller is connected. The IBC sensor, the connected controller, and all other devices on the BACnet bus shall be accessible by the POT.
5. All IBCs shall be fully application programmable and shall at all times maintain their BACnet Level 3 compliance. Controllers offering application selection only (non-programmable) require a 10% spare point capacity to be provided for all applications. Store all control sequences within or programmed into the IBC in non-volatile memory that does not depend on a battery to be retained.
6. The Contractor supplying the IBCs shall provide documentation for each device, with the following information at a minimum:
 - a. BACnet Device; MAC address, name, type and instance number.
 - b. BACnet Objects; name, type and instance number.
7. It is the responsibility of the Contractor to ensure that the proper BACnet objects are provided in each IBC.

D. Object Libraries:

1. A standard library of objects shall be included for development and setup of application logic, user interface displays, system services, and communication networks.
2. The objects in this library shall be capable of being copied and pasted into the user's database and shall be organized according to their function. In addition, the user shall have the capability to group objects created in their application and store the new instances of these objects in a user-defined library.
3. In addition to the standard libraries specified here, the system supplier shall maintain an on-line accessible (over the Internet) library, available to all registered users, to provide new or updated objects and applications as they are developed.
4. All control objects shall conform to the control objects specified in the BACnet specification.
5. The library shall include applications or objects for the following functions, at a minimum:
 - a. Scheduling Object: The schedule must conform to the schedule object as defined in the BACnet specification, providing seven-day plus holiday and temporary scheduling features and a minimum of 10 on/off events per day. Data entry to be by graphic sliders to speed creation and selection of on-off events.

- b. Calendar Object: The calendar must conform to the calendar object as defined in the BACnet specification, providing 12-month calendar features to allow for holiday or special event data entry. Data entry to be by graphic "point-and-click" selection. This object must be "linkable" to any or all scheduling objects for effective event control.
 - c. Override Object: Provide override object that is capable of restarting equipment turned off by other energy saving programs to maintain occupant comfort or for equipment protection.
 - d. Start-Stop Time Optimization Object: Provide a start-stop time optimization object to start equipment just early enough to bring space conditions to desired conditions by the scheduled occupancy time. Also, allow equipment to be stopped before the scheduled unoccupied time just far enough ahead to take advantage of the building's "flywheel" effect for energy savings. Provide automatic tuning of all start-stop time object properties based on historical performance.
 - e. Demand Limiting Object: Provide a demand-limiting object that is capable of controlling demand for any selected energy utility (electric, oil, gas, etc.). The object shall be able to monitor a demand value and predict (using a sliding window prediction algorithm) the demand at the end of the user-defined interval period (1 to 60 minutes). This object shall also accommodate a utility meter time sync pulse for fixed interval demand control. Upon a prediction that will exceed the user-defined demand limit (supply a minimum of 6 per day), the demand limiting object shall issue shed commands to either turn off user specified loads or modify equipment setpoints to provide the desired energy reduction. If the list of sheddable equipment is not enough to reduce the demand to below the setpoint, display a message on the user's screen (as an alarm) instructing the user to take manual actions to maintain the desired demand. The shed lists are specified by the user and shall be selectable to be shed in either a fixed or rotating order to control which equipment is shed the most often. Upon suitable reductions in demand, the demand-limiting object shall restore the equipment that was shed in the reverse order in which it was shed. Each sheddable object shall have a minimum and maximum shed time property to provide both equipment protection and occupant comfort.
6. The library shall include control objects for the following functions:
- a. Analog Input Object: Minimum requirement is to comply with the BACnet standard for data sharing. Allow high, low and failure limits to be assigned for alarming. Also, provide a time delay filter property to prevent nuisance alarms caused by temporary excursions above or below the user defined alarm limits.
 - b. Analog Output Object: Minimum requirement is to comply with the BACnet standard for data sharing.
 - c. Binary Input Object: Minimum requirement is to comply with the BACnet standard for data sharing. The user must be able to specify either input condition for alarming. This object must also include the capability to record equipment runtime by counting the amount of time the hardware input is in an "on" condition. The user must be able to specify either input condition as the "on" condition.

- d. Binary Output Object: Minimum requirement is to comply with the BACnet standard for data sharing. Properties to enable minimum on and off times for equipment protection as well as start-to-start delay must be provided. Incorporate the BACnet Command Prioritization priority scheme to allow multiple control applications to execute commands on this object with the highest priority command being invoked. Provide 16 levels of priority as a minimum. Systems not employing the BACnet method of contention resolution are not acceptable.
 - e. PID Control Loop Object: Minimum requirement is to comply with the BACnet standard for data sharing. Each individual property must be adjustable to allow proportional control only, or proportional with integral control, or proportional, integral and derivative control.
 - f. Comparison Object: Allow a minimum of two analog objects to be compared to select either the highest, lowest, or equality between the two linked inputs. Also, allow limits to be applied to the output value for alarm generation.
 - g. Math Object: Allow a minimum of four analog objects to be tested for the minimum or maximum, or the sum, difference, or average of linked objects. Also, allow limits to be applied to the output value for alarm generation.
 - h. Custom Programming Objects: Provide a blank object template for the creation of new custom objects to meet specific user application requirements. This object must provide a simple BASIC-like programming language that is used to define object behavior. Provide a library of functions including, but not limited to, math and logic functions and string manipulation. Also, provide a comprehensive on-line debug tool to allow complete testing of the new object. Allow new objects to be stored in the library for reuse.
 - i. Interlock Object: Provide an interlock object that provides a means of coordination of objects within a piece of equipment, such as an air handler or other similar types of equipment. An example is to link the return fan to the supply fan such that, when the supply fan is started, the return fan object is also started automatically without the user having to issue separate commands or to link each object to a schedule object. In addition, the control loops, damper objects, and alarm monitoring (such as return air, supply air, and mixed air temperature objects) will be inhibited from alarming during a user-defined period after startup to allow for stabilization. When the air handler is stopped, the interlocked return fan is also stopped, the outside air damper is closed, and other related objects within the air handler unit are inhibited from alarming, thereby eliminating nuisance alarms during the off period.
 - j. Temperature Override Object: Provide an object whose purpose is to override a binary output to an "on" state in the event a user-specified high or low limit value is exceeded. Link this object to the desired binary output object as well as to an analog object for temperature monitoring to cause the override to be enabled. This object will execute a start command at the Temperature Override level of start/stop command priority, unless changed by the user.
 - k. Composite Object: Provide a container object that allows a collection of objects representing an application to be encapsulated to protect the application from tampering or to more easily represent large applications. This object must have the ability to allow the user to select the appropriate parameters of the "contained" application that are represented on the graphic shell of this container.
7. The object library shall include objects to support the integration of devices connected to the Network Area Controller (NAC). Provide the following as part of the standard library included with the programming software:

- a. LonMark/LonWorks Devices: These devices shall include, but not be limited to, devices for control of HVAC, lighting, access, and metering. Provide LonMark manufacturer-specific objects to facilitate simple integration of these devices. Support all network variables defined in the LonMark profile. The device manufacturer shall provide information (type and function) regarding network variables not defined in the LonMark profile.
- b. For devices not conforming to the LonMark standard, provide a dynamic object that can be assigned to the device based on network variable information provided by the device manufacturer. Device manufacturer shall provide an XIF file, resource file, and documentation for the device to facilitate device integration.
- c. For BACnet devices, provide the following objects:
 - 1) Analog In.
 - 2) Analog Out.
 - 3) Analog Value.
 - 4) Binary.
 - 5) Binary In.
 - 6) Binary Out.
 - 7) Binary Value.
 - 8) Multi-State In.
 - 9) Multi-State Out.
 - 10) Multi-State Value.
 - 11) Schedule Export.
 - 12) Calendar Export.
 - 13) Trend Export.
 - 14) Device.
- d. For each BACnet object, provide the ability to assign the object a BACnet device and object instance number.
- e. For BACnet devices, provide the following support at a minimum:
 - 1) Segmentation.
 - 2) Segmented Request.
 - 3) Segmented Response.
 - 4) Application Services.
 - 5) Read Property.
 - 6) Read Property Multiple.
 - 7) Write Property.
 - 8) Write Property Multiple.
 - 9) Confirmed Event Notification.
 - 10) Unconfirmed Event Notification.
 - 11) Acknowledge Alarm.
 - 12) Get Alarm Summary.
 - 13) Who-has.
 - 14) I-have.
 - 15) Who-is.
 - 16) I-am.
 - 17) Subscribe COV.
 - 18) Confirmed COV notification.
 - 19) Unconfirmed COV notification.
 - 20) Media Types.

- 21) Ethernet.
- 22) BACnet IP Annex J.
- 23) MSTP.
- 24) BACnet Broadcast Management Device (BBMD) function.
- 25) Routing.

2.7 DATA COLLECTION AND STORAGE (TRENDING REQUIREMENTS)

- A. The NAC shall be able to collect data for any property of any object and store resident in the NAC that shall have, at a minimum, the following configurable properties:
 1. Designating the log as interval or deviation.
 2. For interval logs, configure the object for time of day, day of week and the sample collection interval.
 3. For deviation logs, configure the object for the deviation of a variable to a fixed value. This value, when reached, will initiate logging of the object.
 4. For all logs, provide the ability to set the maximum number of data stores for the log and to set whether the log will stop collecting when full or rollover the data on a first-in, first-out basis.
 5. Each log shall have the ability to have its data cleared on a time-based event or by a user-defined event or action.
- B. Store all log data in a relational database in the NAC that is accessible from a server (if the system is so configured) or a standard Web browser.
- C. All log data, when accessed from a server, shall be capable of being manipulated using standard SQL statements.
- D. All log data shall be available to the user in ALL the following data formats:
 1. HTML.
 2. XML.
 3. Plain text.
 4. Comma or tab separated values.
- E. The NAC shall archive its log data either locally (to itself) or remotely to a server or other NAC on the network. Provide the ability to configure the following archiving properties:
 1. Archive on time of day.
 2. Archive on user-defined number of data stores in the log (buffer size).
 3. Archive when log has reached its user-defined capacity of data stores.
 4. Provide ability to clear logs once archived.

2.8 WEB BROWSER CLIENTS

- A. The system shall be capable of supporting an unlimited number of clients using a standard Web browser such as Internet Explorer, Firefox, or Chrome. Systems requiring additional software to enable a standard Web browser to reside on the client machine, or manufacturer-specific browsers, are not acceptable.

- B. The Web browser shall provide the same view of the system, in terms of graphics, schedules, calendars, logs, etc., and provide the same interface methodology as is provided by the Graphic User Interface. Systems that require different views or that require different means of interacting with objects, such as schedules or logs, are not permitted.

- C. The Web browser client shall provide:
 - 1. User log-on identification and password shall be required. If an unauthorized user attempts access, display a blank web page. Implement security using Java authentication and encryption techniques to prevent unauthorized access.
 - 2. Graphic screens developed for the GUI shall be the same screens used for the Web browser client. The web browser interface shall support all animated graphic objects supported by the GUI.
 - 3. HTML programming shall not be required to display system graphics or data on a Web page. HTML editing of the Web page shall be allowed if the user desires a specific look or format.
 - 4. Store all graphic screens in the Network Area Controller (NAC) without requiring any graphics storage on the client machine.
 - 5. Real-time values displayed on a Web page shall update automatically without requiring a manual "refresh" of the Web page.
 - 6. Users shall have administrator-defined access privileges. Depending on the access privileges assigned, the user shall be able to perform the following:
 - a. Modify common application objects, such as schedules, calendars, and setpoints, graphically.
 - 1) Schedule times shall be adjustable using a graphic slider, without requiring any keyboard entry from the operator.
 - 2) Holidays shall be set using a graphic calendar, without requiring any keyboard entry from the operator.
 - b. Commands to start and stop binary objects shall be made by right-clicking the selected object and selecting the appropriate command from a pop-up menu. No text entry shall be required.
 - c. View logs and charts.
 - d. View and acknowledge alarms.
 - e. Setup and execute SQL queries on log and archive information
 - 7. The system shall be able to specify a user's (as determined by the log-on user identification) home page. Provide the ability to limit a specific user to just his/her defined home page. From the home page, links to other views or pages in the system shall be possible, if allowed by the system administrator.
 - 8. Graphic screens on the Web Browser client shall support hypertext links to other locations on the Internet or on intranet sites by specifying the Uniform Resource Locator (URL) for the desired link.

2.9 CONTROL INSTRUMENTATION

- A. Temperature Sensors:
 - 1. Water Temperature Sensor:

- a. Install in immersion wells. Separate thermometers as specified elsewhere, also of the immersion well type, shall be installed within 2 feet of each temperature sensor.

B. Pressure Measuring Devices

1. Pressure Transmitters/Transducer:

- a. Wet-to-Wet (uses include measuring hydronic system differential pressure for VFD control):

- 1) Unidirectional pressure range selected for appropriate range based on the application.
- 2) Provide transducer with minimum 250 psi high side proof pressure and minimum 60 psi low side proof pressure.
- 3) Case shall be constructed of stainless steel/aluminum and shall be equipped with 1/4" threaded connections. Wetted parts shall be constructed of 300 series stainless steel. Provide transducer with Viton and silicone O-rings for solutions containing water and/or glycol. Provide transducer with Buna-N O-rings for hydrocarbon solutions.
- 4) Provide transducer with factory assembled 3-valve manifold assembly to allow for field calibration of transducer.
- 5) Performance shall be as follows:
 - a) Accuracy: $\pm\pm 0.25\%$ F.S.
 - b) Non-Linearity: $\pm\pm 0.20\%$ F.S.
 - c) Hysteresis: 0.10% F.S.
 - d) Non-Repeatability: 0.05% F.S.
 - e) Compensated Temp Range: +30°F to +150°F
 - f) Long Term Stability: 0.5% F.S./year

Area (sq.ft.)	Total # of Sensors Required
Less than 2	4
2 to less than 4	6
4 to less than 8	8
8 to less than 16	12
≥ 16	16

C. Current Measuring Devices:

1. Current Switches for Constant Speed Motors:

- a. Digital device rated for amperage load of motor or device with split core design, adjustable high and low trip points, 600 VAC rms isolation, induced power from the monitored load, LED indicator lamps for output status and sensor power. The device shall sense overloading, belt-loss, and power failure with a single signal.

2. Current Switches for Motors Controlled by VFD:

- a. Digital device rated for amperage load of motor or device with split core design, factory programmed to detect motor undercurrent conditions on variable or constant volume loads, self-calibrating, positive status indication, LED indicator lamps, 600 VAC rms isolation, induced power from the monitored load with NO output. The current sensor shall store the motor current operating parameters in non-volatile memory and have a pushbutton reset to clear the memory if the operating parameters change or the sensor is moved to another load. The device shall sense overloading, belt-loss, and power failure with a single signal. The sensor shall be mounted on the load side of variable frequency drives.

D. Miscellaneous Devices:

- a.

2. Control Relays:

- a. Form "C" contacts rated for the application with "push-to-test" contact transfer feature and an integral LED to indicate coil energization.
- b. Mount all relays and power supplies in a NEMA 1 enclosure beside the FMCS panel or controlled device and clearly label their functions.

3. Thermostat and Sensor Enclosures:

- a. Clear plastic guard with lock. Wire guard with tamperproof screws. Setpoint shall be adjustable with cover in place. Fasten to wall separately from thermostat. Provide guards in all corridors, gymnasiums, locker rooms, toilet rooms, assembly halls and as noted on the drawings.

2.10 CONDUIT AND BOXES

- A. Conduit and Boxes: Refer to Electrical Section 26 05 33 for materials, sizing, and other requirements

B. Conduit and Box Identification (Color and Labeling):

1. Refer to the Temperature Control Contractor notes located on the mechanical cover sheet for raceway and box color requirements.
2. Refer to Electrical Section 26 05 53 for raceway and box labeling requirements.

2.11 WIRE AND CABLE

- A. Wire and Cable: Refer to Electrical Section 26 05 13 for wire and cable materials.

1. Wire and Cable Color: Refer to the Temperature Control Contractor notes located on the mechanical cover sheet for wire and cable color requirements.

PART 3 - EXECUTION

3.1 GENERAL INSTALLATION

- A. Verify that systems are ready to receive work. Beginning of installation means installer accepts existing conditions.
- B. Install system and materials in accordance with manufacturer's instructions.
- C. Drawings of the TCS and FMCS network are diagrammatic only. Any apparatus not shown but required to meet the intent of the project documents shall be furnished and installed without additional cost.
- D. Install all operators, sensors, and control devices where accessible for service, adjustment, calibration, and repair. Do not install devices where blocked by piping or ductwork. Devices with manual reset or limit adjustments shall be installed below 6'-0" if practical to allow inspection without using a ladder.
- E. Verify locations of wall-mounted devices (such as thermostats, temperature and humidity sensors, and other exposed sensors) with drawings and room details before installation. Coordinate mounting heights to be consistent with other wall-mounted devices. Maximum height above finished floor shall not exceed ADA mounting requirements.
- F. Provide valves over 3/4" size with position indicators and pilot positioners where sequenced with other controls.
- G. Mount control panels adjacent to associated equipment on vibration-free walls or freestanding angle iron supports. One cabinet may accommodate more than one system in same equipment room.
- H. After completion of installation, test and adjust control equipment.
- I. Check calibration of instruments. Recalibrate or replace.
- J. Furnish and install conduit, wire, and cable per the National Electric Code, unless noted otherwise in this section.
- K. All controls associated with the proper operation of air handling units, pumps, or other mechanical equipment served by emergency power shall be connected to the emergency power system. Control components shall be powered from the equipment branch. In no instance shall panel be connected to the life safety or critical branch of the emergency power system. Panels may be connected to a common 20 amp, 120 volt circuit provided the total load on the circuit does not exceed 16 amps. Circuit conductors shall be sized per the table below. All power connections to the control panels shall be performed by a licensed electrician at the cost of this Contractor. Submit circuit information (total amperage on circuit, conductors length, and panel) for control panels to the Architect/Engineer for approval.

Circuit Load (Amps)	Circuit Max Length	Feeder Size
≤ 5	≤ 200ft	2#12 & 1#12 ground in 3/4" conduit.
≤ 10	≤ 100ft	2#12 & 1#12 ground in 3/4" conduit.

≤ 16	≤ 75ft	2#12 & 1#12 ground in 3/4" conduit.
≤ 200	≤ 325ft	2#10 & 1#10 ground in 3/4" conduit.
≤ 100	≤ 160ft	2#10 & 1#10 ground in 3/4" conduit.
≤ 75	≤ 100ft	2#10 & 1#10 ground in 3/4" conduit.

L. All hardware, software, equipment, accessories, wiring (power and sensor), piping, relays, sensors, power supplies, transformers, and instrumentation required for a complete and operational FMCS system, but not shown on the electrical drawings, are the responsibility of the TCC.

M. Remodeling:

1. All room devices as indicated on the drawings shall be removed by this Contractor. The Contractor shall also prepare the wall for finishes. Preparing the wall shall include patching old anchor holes (after the anchoring device has been removed) and sanding the wall to remove old paint outlines remaining from original devices. The wall shall be painted to match the existing wall prior to the installation of the new room device. If wall covering requires patching, the Contractor shall furnish new wall covering to match existing. If new wall covering is not available to match existing, the Contractor shall furnish a white acrylic or Plexiglas plate, 1/4" thick and sized to cover the void.

N. Labels For Control Devices:

1. Provide labels indicating service of all control devices in panels and other locations.
2. Labels may be made with permanent marking pen in the control panels if clearly legible.
3. Use engraved labels for items outside panel such as outside air thermostats.
4. Labels are not required for room thermostats, damper actuators and other items where their function is obvious.

O. VFDs:

1. This project includes several variable frequency drives to control the flow of fans and/or pumps based on a control variable.
2. Verify output signal required, 4-20 mA or 0-10V dc, with the EC.
3. If VFD has a bypass feature, auxiliary contacts on the drive may not be used for motor status. A separate relay must be used to indicate motor rotation in either hand or auto positions.
4. If a separate current transmitter or switch is indicated for status, install this device between the VFD and the motor. In this case, the drive status may be connected to the auxiliary contacts in the VFD.
5. Some devices, such as low limits and fire alarm shutdown relays, must be hardwired to the fan motor. Make connections such that fan will shut down whether in hand or auto position if the unit has a bypass feature.

3.2 CONDUIT AND BOXES INSTALLATION

A. Conduit and Box Installation: Refer to Electrical Section 26 05 33 for execution and installation.

- B. Conduit and Box Identification (color and labeling) installation. Refer to Electrical Section 26 05 53 for raceway and box identification installation.
- C. Outlet Box Schedule: Thermostat/temperature sensor:
 - 1. Dry Interior Locations: Provide 4" square galvanized steel with raised cover to fit flush with finished wall line. When located in concrete block walls, provide square edge title cover of sufficient depth to extend out to face of block or masonry boxes.
 - 2. Other Conditions: Refer to Electrical Section 26 05 33 for requirements.

3.3 WIRE AND CABLE INSTALLATION

- A. Wire and Cable Installation: Refer to Electrical Section 26 05 13 for execution and installation.
- B. Field Quality Control:
 - 1. Inspect wire and cable for physical damage and proper connection.
 - 2. Torque test conductor connections and terminations to manufacturer's recommended values.
 - 3. Perform continuity test on all conductors.
 - 4. Protection of cable from foreign materials:
 - a. It is the Contractor's responsibility to provide adequate physical protection to prevent foreign material application or contact with any cable type. Foreign material is defined as any material that would negatively impact the validity of the manufacturer's performance warranty. This includes, but is not limited, to overspray of paint (accidental or otherwise), drywall compound, or any other surface chemical, liquid or compound that could come in contact with the cable, cable jacket or cable termination components.
 - b. Overspray of paint on any cable, cable jacket or cable termination component will not be accepted. It shall be the Contractor's responsibility to replace any component containing overspray, in its entirety, at no additional cost to the project. Cleaning of the cables with harsh chemicals is not allowed. This requirement is regardless of the PASS/FAIL test results of the cable containing overspray. Should the manufacturer and warrantor of the structured cabling system desire to physically inspect the installed condition and certify the validity of the structured cabling system (via a signed and dated statement by an authorized representative of the structured cabling manufacturer), the Owner may, at their sole discretion, agree to accept said warranty in lieu of having the affected cables replaced. In the case of plenum cabling, in addition to the statement from the manufacturer, the Contractor shall also present to the Owner a letter from the local Authority Having Jurisdiction stating that they consider the plenum rating of the cable to be intact and acceptable.
- C. Installation Schedule:
 - 1. Conduit terminations to all devices installed in applications with rotating equipment, expansion/contraction or vibration shall be made with flexible metallic conduit, unless noted otherwise. Final terminations to exterior devices installed in damp or wet locations shall be made with liquidtight flexible metallic conduit. Terminations in hazardous areas, as defined in the National Electrical Code, shall be made with flexible conduit rated for the environment.

3.4 COMMISSIONING

- A. Upon completion of the installation, this Contractor shall load all system software and start up the system. This Contractor shall perform all necessary calibration, testing and de-bugging and perform all required operational checks to ensure that the system is functioning in full accordance with these specifications.
- B. This Contractor shall perform tests to verify proper performance of components, routines, and points. Repeat tests until proper performance results. This testing shall include a point-by-point log to validate 100% of the input and output points of the FMCS system operation.
- C. This Contractor shall prove that the controls network is functioning correctly and within acceptable bandwidth criteria and shall test the system with an approved protocol analysis tool. Provide a log and statistics summary showing that each channel is within acceptable parameters. Each channel shall be shown to have at least 25% spare capacity for future expansion.
- D. Upon completion of the performance tests described above, repeat these tests, point by point, as described in the validation log above in the presence of Owner's Representative, as required. Properly schedule these tests so testing is complete at a time directed by the Owner's Representative. Do not delay tests so as to prevent delay of occupancy permits or building occupancy.
- E. System Acceptance: Satisfactory completion is when this Contractor has performed successfully all the required testing to show performance compliance with the requirements of the Contract Documents to the satisfaction of the Owner's Representative. System acceptance shall be contingent upon completion and review of all corrected deficiencies.

3.5 PREPARATION FOR BALANCING

- A. Verify that all dampers are in the position indicated by the controller (e.g., open, closed or modulating).
- B. Check the calibration and setpoints of all controllers.
- C. Check the locations of all thermostats and humidistats for potential erratic operation from outside influences such as sunlight, drafts, or cold walls.
- D. Check that all sequences operate as specified. Verify that no simultaneous heating and cooling occurs, unless specified. Observe that heating cannot begin at TAB reheat terminals until the unit is at the minimum cfm.
- E. Verify the operation of all interlock systems.

3.6 TEST AND BALANCE COORDINATION

- A. The Contractor shall furnish a single set of all tools necessary to interface to the control system for test and balance purposes.
- B. The Contractor shall provide a minimum of four (4) hours training for the Balancing Contractor in the use of these tools.

- C. In addition, the Contractor shall provide a qualified technician to assist in the test and balance process until the first 20 terminal units are balanced.
- D. The tools used during the test and balance process shall be returned at the completion of the testing and balancing.

3.7 DEMONSTRATION AND ACCEPTANCE

- A. At completion of installation, provide two days minimum instruction for operators. Demonstrate operation of all controls and systems. Describe the normal operation of all equipment.

3.8 TRAINING

- A. On-Site:
 - 1. After completion of commissioning, the manufacturer shall provide 4 hours of training on consecutive days for 4 Owner's representatives. The training course shall enable the Owner's representatives to perform Day-to-Day Operations as defined herein. A factory-trained instructor with experience in presenting the training material and the system programmer for this project shall perform the training.
 - 2. One month after completion of commissioning, the manufacturer shall provide 2 hours of training on consecutive days for 2 Owner's representatives. The training course shall enable the Owner's representatives to perform Advanced Operations and System Management as defined herein. A factory-trained instructor with experience in presenting the training material and the system programmer for this project shall perform the training.
 - 3. Six months after completion of commissioning or one month prior to the end of the warranty period, the manufacturer shall provide 2 hours of training on consecutive days for 2 Owner's representatives. The training course shall update the Owner's representatives on Day-to-Day Operations as defined herein. A factory-trained instructor with experience in presenting the training material and the system programmer for this project shall perform the training.
- B. Day-to-Day Operations - Training Description:
 - 1. Proficiently operate the system.
 - 2. Understand control system architecture and configuration.
 - 3. Understand FMCS systems components.
 - 4. Understand system operation, including FMCS system control and optimizing routines (algorithms).
 - 5. Operate the workstation and peripherals.
 - 6. Log-on and off the system.
 - 7. Access graphics, point reports, and logs.
 - 8. Adjust and change system setpoints, time schedules, and holiday schedules.
 - 9. Recognize malfunctions of the system by observation of the printed copy and graphic visual signals.
 - 10. Understand system drawings and Operation and Maintenance manual.
 - 11. Understand the job layout and location of control components.
 - 12. Access data from FMCS controllers and ASCs.
 - 13. Operate portable operator's terminals.

- C. System Management - Training Description:
 - 1. Maintain software and prepare backups.
 - 2. Interface with job-specific, third-party operator software.
 - 3. Add new users and understand password security procedures.
- D. Provide course outline and materials in accordance with the "SUBMITTALS" article in Part 1 of this section. The instructor(s) shall provide one copy of training material per student.

3.9 INSTALLATION OF SENSORS

- A. Install sensors in accordance with the manufacturer's recommendations.
- B. Mount sensors rigidly and adequately for the environment within which the sensor operates.
- C. All wires attached to sensors shall be air sealed in their raceways or in the wall to stop air transmitted from other areas affecting sensor readings.
- D. Averaging sensors and low limits shall be installed at the top of the assembly with the element on a slight downward incline away from the sensor making a serpentine pattern over the cross-sectional area with elements spaced not over 12" apart and within 6" of the top and bottom of the area.
- E. All pipe-mounted temperature sensors shall be installed in immersion wells. Install all liquid temperature sensors with heat-conducting fluid in thermal wells.
- F. Install outdoor air temperature sensors on exterior of north wall, complete with sun shield at designated location approved by Architect/Engineer. TCC shall prime and paint the device enclosure. Color selection by Architect.

END OF SECTION 23 09 00

SECTION 23 09 13 - INSTRUMENTATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Pressure Gauge.
- B. Pressure Gauge Accessories.
- C. Thermometers.
- D. Test Plugs.

1.2 REFERENCES

- A. ANSI/AWWA C700 - Cold Water Meters - Displacement Type, Bronze Main Case.
- B. ANSI/AWWA C701 - Cold Water Meters - Turbine Type, for Customer Service.
- C. ANSI/AWWA C702 - Cold Water Meters - Compound Type.
- D. ANSI/AWWA C706 - Direct Reading, Remote Registration Systems for Cold Water Meters.
- E. ASME B40.1 - Gauges - Pressure Indicating Dial Type - Elastic Element.
- F. ASME MFC-3M - Measurement of Fluid Flow in Pipes Using Orifice, Nozzle and Venturi.
- G. ASTM E1 - Specification for ASTM Thermometers.

1.3 SUBMITTALS

- A. Submit shop drawings per Section 23 05 00. Include list that indicates use, operating range, total range and location for manufactured components.

PART 2 - PRODUCTS

2.1 PRESSURE GAUGES

- A. Gauges shall be 4-1/2" diameter with aluminum or stainless steel case with phosphor bronze bourdon tube, brass socket for air, steam, water or oil application, 1/4" or 1/2" bottom connection. Gauges shall be 1% full scale accurate with bronze brushed brass movement and adjustable pointer. Standard ranges to be either pressure or pressure and vacuum as required of application.
- B. Manufacturers:
 - 1. Ashcroft
 - 2. Marsh

3. Marshalltown
4. Miljoco
5. Trerice
6. Weiss

C. Select gauge range for normal reading near center of gauge.

2.2 PRESSURE GAUGE ACCESSORIES

- A. All pressure gauges shall have valves and pressure snubbers. All pressure gauges on steam shall have pigtail syphon.
- B. Shutoff Valve: 1/4" ball valve as specified for each piping system.
- C. Pressure snubber, brass with 1/4" connections, porous metal type.

2.3 THERMOMETERS

A. Dial Type:

1. 4-1/2" diameter, hermetically sealed case. Stainless steel case and stem. Accuracy of 1% full scale with external recalibrator.
2. Select thermometers for appropriate temperature range. Adjustable elbow joint with locking device to allow rotation of thermometer to any angle.
3. Stem lengths as required for application with minimum insertion of 2-1/2" .
4. Thermometers for water, steam, or oil shall have brass or steel separable socket. Thermometer wells shall be stainless steel, pressure rated to match piping system design pressure; with 2 inch extension for insulated piping and threaded cap nut with chain permanently fastened to well and cap. Thermometers for air shall have an aluminum or brass duct flange.
5. Manufacturer:
 - a. Trerice
 - b. Weiss

B. Alcohol/Spirit Filled Type:

1. 9" long phenolic case, steel stem, accuracy of 1% full scale. Adjustable elbow joint with 180 degree adjustment in vertical plane, 360 degree adjustment in horizontal plane, and locking device to allow rotation of thermometer to any angle.
2. Select thermometer for appropriate temperature range.
3. Stem: Copper plated steel, aluminum, or brass for separable socket. Stem lengths as required for application with minimum insertion of 3" .
4. Thermometers for water, steam, or oil shall have brass or steel separable socket. Thermometer wells shall be stainless steel, pressure rated to match piping system design pressure; with 2 inch extension for insulated piping and threaded cap nut with chain permanently fastened to well and cap. Thermometers for air shall have an aluminum or brass duct flange.

5. Manufacturer:

- a. Trerice
- b. Weiss

C. Select scales to cover expected range of temperatures.

2.4 TEST PLUGS

- A. Test Plug: 1/4" or 1/2" brass fitting and cap, with Nordel core for temperatures up to 275°F, for receiving 1/8" outside diameter pressure or temperature probe. Plugs shall be rated for zero leakage from vacuum to 500 psi.
- B. Provide extended units for all plugs installed in insulated piping.
- C. Test Kit: Carrying case, internally padded and fitted containing one 3-1/2" diameter pressure gauge with 0-100 psi range, one gauge adapter with 1/8" probes, two 1-1/2" dial thermometers with 0° to 220°F and -25°F to 125°F ranges and 5" stems.

PART 3 - EXECUTION

3.1 INSTALLATION

A. General Installation Requirements:

- 1. Install per manufacturer's instructions.
- 2. Coil and conceal excess capillary on remote element instruments.
- 3. Install gauges and thermometers in locations where they are easily read from normal operating level.
- 4. Do not install instrumentation when areas are under construction, except for required rough-in, taps, supports and test plugs.

B. Pressure Gauges:

- 1. Connect pressure gauges to suction and discharge side of all pumps.
- 2. Provide snubber for each pressure gauge.
- 3. Provide coil syphon for each pressure gauge connected to steam piping.

C. Thermometers:

- 1. Install thermometers in piping systems in sockets in short couplings. Enlarge pipes smaller than 2-1/2" for installation of thermometer sockets.
- 2. Install thermometer sockets adjacent to control system thermostat, transmitter and sensor sockets.
- 3. Locate duct thermometers minimum 10 feet downstream of mixing dampers, coils, or other devices causing air turbulence.

END OF SECTION 23 09 13

SECTION 23 21 00 - HYDRONIC PIPING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Pipe and Pipe Fittings
- B. Valves
- C. Check Valves
- D. System Piping Schedule

1.2 QUALITY ASSURANCE

- A. Valves: Manufacturer's name and pressure rating marked on valve body. Remanufactured valves are not acceptable.
- B. Welding Materials, Procedures, and Operators: Conform to ASME Section 9, ANSI/AWS D1.1, and applicable state labor regulations.

1.3 REFERENCES

- A. ANSI/ASTM D2466 - PVC Plastic Pipe Fittings, Schedule 40.
- B. ANSI/AWS D1.1 - Structural Welding Code.
- C. ANSI/AWWA C104/A21.4 - Cement-Mortar Lining for Ductile Iron Pipe and Fittings for Water.
- D. ANSI/AWWA C110 - Ductile Iron and Gray Iron Fittings 3" through 48", for Water and Other Liquids.
- E. ANSI/AWWA C111/A21.11 - Rubber Gasket Joints for Ductile Iron Pressure Pipe and Fittings.
- F. ANSI/AWWA C150/A21.50 - Thickness Design of Ductile Iron Pipe.
- G. ANSI/AWWA C151 - Ductile Iron Pipe, Centrifugally Cast in Metal Molds or Sand-Lined Molds, for Water or Other Liquids.
- H. ANSI/AWWA C153/A21.51 - Ductile Iron Compact Fittings, Centrifugally Cast for Water or Other Liquids.
- I. ASME - Boiler and Pressure Vessel Code.
- J. ASME B16.1 - Cast Iron Pipe Flanges and Flanged Fittings, Class 25, 125, 250, and 800.
- K. ASME B16.3 - Malleable Iron Threaded Fittings Class 150 and 300.

- L. ASME B16.4 - Cast Iron Threaded Fittings, Class 125 and 250.
- M. ASME B16.5 - Pipe Flanges and Flanged Fittings.
- N. ASME B16.9 - Factory-Made Wrought Steel Butt Welding Fittings.
- O. ASME B16.12 - Cast Iron Threaded Drainage Fittings.
- P. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings
- Q. ASME B16.21 - Nonmetallic Flat Gaskets for Pipes Flanges.
- R. ASME B16.22 - Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
- S. ASME B16.23 - Cast Copper Alloy Solder Joint Drainage Fittings (DWV).
- T. ASME B16.29 - Wrought Copper and Wrought Copper Alloy Solder Joint Drainage Fittings - DWV.
- U. ASME B18.2.1 - Square and Hex Bolts and Screws, Inch Series.
- V. ASME B18.2.2 - Square and Hex Nuts, Inch Series.
- W. ASME B31.3 - Chemical Plant and Petroleum Refinery Piping.
- X. ASME B31.9 - Building Services Piping.
- Y. ASME Section 9 - Welding and Brazing Qualifications.
- Z. ASTM A126 - Gray Cast Iron Castings for Valves, Flanges, and Pipe Fittings.
- AA. ASTM A53 - Pipe, Steel, Black and Hot-Dipped Zinc Coated, Welded and Seamless.
- BB. ASTM A181 - Forgings, Carbon Steel for General Purpose Piping.
- CC. ASTM A234 - Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and High Temperature Service.
- DD. ASTM A307 - Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
- EE. ASTM A536 - Standard Specification for Ductile Iron Castings
- FF. ASTM A733 - Standard Specification for Welded and Seamless Carbon Steel and Austenitic Stainless Steel Pipe Nipples.
- GG. ASTM B32 - Standard Specification for Solder Metal.
- HH. ASTM B88 - Seamless Copper Water Tube.
- II. ASTM B813 - Standard Specification for Liquid and Paste Fluxes for Soldering Applications of Copper and Copper Alloy Tube.

- JJ. ASTM D1599 - Standard Test Method for Short-Time Hydraulic Failure Pressure of Plastic Tubing and Fittings.
 - KK. ASTM D1785 - Polyvinylchloride (PVC) Plastic Pipe, Schedules 40, 80 and 120.
 - LL. ASTM D2105 - Standard Test Method for Longitudinal Tensile Properties of Fiberglass Pipe and tube.
 - MM. ASTM D2412 - Standard Test Method for Determination of External Loading Characteristics of Plastic Pipe by Parallel-Plate loading.
 - NN. ASTM D2513 - Standard Specification for Polyethylene (PE) Gas Pressure Pipe, Tubing, and Fittings
 - OO. ASTM D2683 - Standard Specification for Socket-Type Polyethylene Fittings for Outside Diameter-Controlled Polyethylene Pipe and Tubing
 - PP. ASTM D2774 - Standard Practice for Underground Installation of Thermoplastic Pressure Piping.
 - QQ. ASTM D2992 - Standard Practice for Obtaining Hydrostatic Design Basis for Fiberglass pipe and fittings.
 - RR. ASTM D2996 - Standard Specification for Filament Wound Fiberglass Pipe.
 - SS. ASTM D3261 - Standard Specification for Butt Heat Fusion Polyethylene (PE) Plastic Fittings for Polyethylene (PE) Plastic Pipe and Tubing
 - TT. ASTM D3350 - Standard Specification for Polyethylene Plastics Pipe and Fittings Materials
 - UU. ASTM D4024 - Standard Reinforced Thermosetting Resin Flanges.
 - VV. ASTM D5685 - Standard for Fiberglass Pressure Pipe Fittings.
 - WW. ASTM E90-02 - Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions
 - XX. ASTM E413-87 - Classification for Rating Sound Insulation
 - YY. ASTM F2389 - Standard Specification for Pressure-rated Polypropylene (PP) Piping Systems.
 - ZZ. ASTM F477 - Elastomeric Seals (Gaskets) for Joining Plastic Pipes.
- 1.4 SUBMITTALS
- A. Submit product data under provisions of Section 23 05 00. Include data on pipe materials, fittings, valves, and accessories. Include manufacturers' support spacing requirements for plastic piping.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store and protect piping to prevent entrance of foreign matter into pipe and to prevent exterior corrosion.
- B. Deliver and store valves in shipping containers with labeling in place.

1.6 COORDINATION DRAWINGS

- A. Reference Coordination Drawings article in Section 23 05 00 for required hydronic systems electronic CAD drawings to be provided to Coordinating Contractor for inclusion into composite coordination drawings.

PART 2 - PRODUCTS

2.1 STEEL PIPE (ABOVE GRADE)

- A. Design Pressure 125 psig, Maximum Design Temperature 225°F (230°F for grooved couplings).
- B. Black Steel; Standard Weight; Threaded Joints:
 - 1. Pipe: Standard weight black steel, threaded and coupled, ASTM A53; Type E, F, or S; Grade B.
 - 2. Joints: Screwed.
 - 3. Fittings: Class 125 cast iron, ASTM A126, ASME B16.4; or Class 150 malleable iron, ASTM A197, ASME B16.3.
 - 4. Unions: Class 150 malleable iron, ANSI B16.39, ground joint with copper or copper alloy-to-iron seat.
- C. Black Steel; Standard Weight; Welded or Flanged Joints:
 - 1. Pipe: Standard weight black steel, beveled ends, ASTM A53, Type E or S, Grade B.
 - 2. Joints: Butt-welded or flanged.
 - 3. Fittings: Standard weight wrought steel, butt-welding type, ASTM A234, ASME B16.9.
 - 4. Flanges: Class 150 forged steel, welding neck or slip-on, ASTM A181 or A105, Class 60, ASME B16.5 up to 24" and B16.47 above 24". ASME B16.1 for flanges mating with flat face equipment flanges. Flange face seal weld (backweld) is required for slip-on flanges.
- D. Black Steel; Standard Weight; Mechanically Coupled Grooved Joints:
 - 1. Pipe: Standard weight black steel, grooved ends, ASTM A53, Type E or S, Grade B.
 - 2. Joints: Grooved type, with Grade E EPDM molded pressure-responsive gaskets suited for 32°F to 230°F per ASTM D2000.
 - a. Rigid Type: Housings cast with offsetting, angle-pattern, bolt pads to provide system rigidity and support. Design Basis: Victaulic 107N.
 - 1) Usage: All locations unless noted elsewhere.

- b. Flexible Type: Housing cast with horizontal, angle-pattern bolt pads to provide vibration attenuation and stress relief. Design Basis: Victaulic 177N.
 - 1) Usage: As shown on drawings and first three joints adjacent to vibrating equipment (e.g., chillers, boilers, pumps, air handling equipment, etc.).
3. Fittings: ASTM A536 Grade 65-45-12 ductile or A47 malleable iron, grooved type.
4. Flanges: Grooved end, flanged adapter.

2.2 COPPER PIPE (ABOVE GRADE)

- A. Design Pressure 125 psig. Maximum Design Temperature 225°F.
- B. Copper Pipe; Type L; Soldered Joints:
 1. Tubing: Type L drawn temper seamless copper tube, ASTM B88.
 2. Joints: Solder with Type 95-5 solder. 50-50 solder is not acceptable.
 3. Fittings: Wrought copper solder joint, ASME B16.22.
 4. Copper Pipe; Type L; Mechanical Press Connection: Tubing: Type L hard drawn seamless copper tube, ASTM B88.
 5. Joints: Mechanical press connection.
 6. Fittings: Copper, ANSI B-16.22, with embedded EPDM O-ring, NSF-61.
 7. Manufacturers:
 - a. Viega ProPress.

2.3 VALVES

- A. Shutoff Valves:
 1. For pipe systems where mechanical press connections are allowed, shutoff valves with mechanical press connections are acceptable subject to the requirements in the paragraphs below.
 2. Ball Valves:
 - a. BA-1 (Steel and Copper): 3" and under, 125 psi saturated steam, 600 psi WOG, full port, screwed or solder ends (acceptable only if rated for soldering in line with 470°F melting point of lead-free solder), bronze body of a copper alloy containing less than 15% zinc, stainless steel ball and trim, Teflon seats and seals.
 - 1) Manufacturers:
 - a) Apollo
 - b) Jomar
 - c) Centerline
 - d) Red and White
 - e) Nibco

- f) Crane
 - 2) Provide extended shaft with operating handle of non-thermal conductive material and protective sleeve that allows operation of valve, adjustment of the packing, and adjustment of the memory stop without breaking the vapor seal or disturbing the insulation for all valves in insulated piping.
 - 3) Provide lock out trim for all valves opening to atmosphere installed in domestic water piping over 120°F, heating water piping over 120°F, steam, condensate, boiler feed water piping, compressed air piping and gasoline/kerosene piping, and as indicated on the drawings. Solid extended shaft is not required on valves with lock out trim.
3. Butterfly Valves:
- a. BF-1:
 - 1) 2-1/2" thru 6", 175 psi CWP, elastomers rated for 20°F to 225°F continuous and 250°F intermittent at 125 psig, fully lugged end, ductile or cast iron body (not in contact with fluid); bronze, aluminum-bronze or EPDM coated ductile iron disc; EPDM seat, stainless steel stem, extended neck, 175 psi bubble-tight, bi-directional dead-end shutoff without backing flange or nuts and with cap screws extending to centerline of valve body (for pipe extension without draining system), 10 position locking operator up to 6" size. Cv of at least 1580 in 6" size.
 - 2) All butterfly valves to have gear operators.
 - 3) Manufacturers:
 - a) Stockham
 - b) Mueller
 - c) Centerline
 - d) Red and White
 - e) Nibco
 - f) Crane
 - g) Victaulic Vic300 MasterSeal (grooved end valves)
 - 4) 8" thru 12", 175 psi CWP, elastomers for 20°F to 225°F at 130 psi, fully lugged end, ductile or cast iron body (not in contact with fluid), bronze, EPDM coated ductile iron or aluminum-bronze disc, EPDM seat, stainless steel stem, extended neck, 175 psi bubble-tight, bi-directional dead-end shutoff without backing flange or nuts and with cap screws extending to the centerline of the valve body (to permit pipe extension without draining system), weatherproof gear operator.
 - 5) Mechanically coupled grooved end valves are acceptable if they have the temperature ratings, pressure ratings, and features listed above.

2.4 CHECK VALVES

- A. For pipe systems where mechanical press connections are allowed, check valves with mechanical press connections are acceptable subject to the requirements in the paragraphs below.
- B. CK-1: Check Valves (Steel Pipe); 2" and under, 125 psi S @ 353°F, 200 psi WOG @ 150°F, screwed, bronze, horizontal swing.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Ream pipe and tube ends, remove burrs, bevel plain end ferrous pipe.
- B. Remove scale and dirt on inside and outside before assembly.
- C. Remove all scale, rust, dirt, oils, stickers and thoroughly clean exterior of all bare metal exposed piping, hangers, and accessories in preparation to be painted.
- D. Connect to all equipment with flanges or unions.
- E. After completion, fill, clean, and treat systems. Refer to Section 23 25 00 for treatment.

3.2 SYSTEMS, PIPING, AND VALVE SCHEDULE

- A. High Temperature Heating Water (Above Grade - maximum 400°F):
 - 1. Black Steel; Schedule 80; Welded Joints: All Sizes
- B. Heating Water (Above Grade - maximum 200°F):
 - 1. Black Steel; Standard Weight; Threaded Joints: 2" and Under
 - 2. Copper Pipe; Type L; Soldered Joints: 2" and Under
 - 3. Copper Pipe; Type L; Mechanical Press Connection: 4" and Under
 - 4. Black Steel; Standard Weight; Welded or Flanged Joints: 2-1/2" and Over
 - 5. Black Steel; Standard Weight; Grooved Joints: 2-1/2" and Over
 - 6. Shutoff Valves: , BA-1, BF-1
 - 7. Check Valves: CK-1
- C. Heating Water (Above Grade - maximum 140°F):
 - 1. Black Steel; Standard Weight; Threaded Joints: 2" and Under
 - 2. Copper Pipe; Type L; Soldered Joints: 2" and Under
 - 3. Black Steel; Standard Weight; Welded or Flanged Joints: 2-1/2" and Over
 - 4. Black Steel; Standard Weight; Grooved Joints: 2-1/2" and Over
 - 5. Copper Pipe; Type L; Mechanical Press Connection: 4" and Under
 - 6. Shutoff Valves: , BA-1, BF-1

3.3 TESTING PIPING

- A. Test pipes underground or in chases and walls before piping is concealed.
- B. Complete testing before insulation is applied. If insulation is applied before pipe is tested and a leak ruins the insulation, replace all damaged insulation.
- C. Test the pipe with water at 1.5 times the design pressure but not less than 100 psig pressure. Hold pressure for at least two hours.
- D. Test to be witnessed by the Architect/Engineer or their representative, if requested by the Architect/Engineer.

3.4 CLEANING PIPING

- A. Assembly:
 - 1. Prior to assembly of pipe and piping components, remove all loose dirt, scale, oil and other foreign matter on internal or external surfaces by means consistent with good piping practice subject to approval of the Architect/Engineer. Blow chips and burrs out of pipe before assembly. Wipe cutting oil from internal and external surfaces.
 - 2. During fabrication and assembly, remove slag and weld spatter from both internal and external joints by peening, chipping and wire brushing to the degree consistent with good piping practices.
 - 3. Notify the Architect/Engineer prior to starting any post erection cleaning operation in time to allow witnessing the operation. Properly dispose of cleaning and flushing fluids.
 - 4. Prior to blowing or flushing erected piping systems, disconnect all instrumentation and equipment, open wide all valves, control valves, and balance valves, and verify all strainer screens are in place.
- B. Chemical Cleaning:
 - 1. Flush pipe and components with clean water until all discharge from system is clean. Maintain minimum velocities at all points of 5 feet/second for 30 minutes. Flow shall be in same direction as when system is in normal operation. Discharge shall be from low points of pipes, ends of headers and as otherwise needed to flush entire system. After flushing, all residual water shall be drained and/or blown out.
 - 2. Add 2 pounds of trisodium phosphate per 100 gallons of system capacity. Use an alternate chemical if discharge of trisodium phosphate is not permitted. Maintain 150°F in the system if possible. If heat is not available, use 3 pounds per 100 gallons.
 - 3. Drain the system after circulating the chemical cleaner for six hours at 150°F, or 12 hours at a lower temperature. Refill. Test a water sample. Drain and fill again if excessive cleaning chemicals remain and until water appears clear.
 - 4. After each system has been cleaned and thoroughly flushed of pretreatment chemicals, it shall be immediately refilled with water and treated with chemical treatment as specified in Section 23 25 00. The system shall not be allowed to sit empty for any length of time.
 - 5. When system water is clear, remove, clean and replace all strainers.
 - 6. Water samples may be taken by the Architect/Engineer to verify a clean system. If system is not clean, the entire process, including chemical treatment specified in Section 23 25 00, shall be repeated at the Contractor's expense.

7. Chemical cleaning applies to the following systems:
 - a. Heating Water

3.5 INSTALLATION

A. General Installation Requirements:

1. Route piping in orderly manner, straight, plumb, with consistent pitch, parallel to building structure, with minimum use of offsets and couplings. Provide only offsets required for needed headroom or clearance and needed flexibility in pipe system.
2. Install piping to conserve building space, and not interfere with other work.
3. Group piping whenever practical at common elevations.
4. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
5. Reducers are generally not shown. Where pipe sizes change at tee, the tee shall be the size of the largest pipe shown connecting to it. Where pipe sizes are not shown, the larger size in either direction shall continue through the fitting nearest to the indication of a smaller pipe size.
6. Install bell and spigot pipe with bells upstream.
7. Seal pipes passing through exterior walls with a wall seal per Section 23 05 29. Provide Schedule 40 galvanized sleeve at least 2 pipe sizes larger than the pipe.
8. Branch takeoffs shall be from the top side (if branch is two sizes smaller than main), or any angle from the horizontal plane to the top of piping.

B. Installation Requirements in Electrical Rooms:

1. Do not install piping or other equipment above electrical switchboards or panelboards. This includes a dedicated space extending 25 feet from the floor to the structural ceiling with width and depth equal to the equipment plus its required clearance space.

C. Installation Requirements in MRI (Magnetic Resonance Imaging - Healthcare):

1. All piping in MRI rooms shall be non-ferrous regardless of materials described on Part 2.

D. Valves/Fittings and Accessories:

1. Provide chain operators for all valves over 2" size that are over 10'-0" above finished floor. Extend to 7'-0" above finished floor.
2. Provide valve position indicator on all valves 10'-0" or greater above finish floor and not located above ceiling.
3. Provide clearance for installation of insulation, and access to valves and fittings.
4. Prepare pipe, fittings, supports, and accessories for finish painting.
5. Install valves with stems upright or horizontal, not inverted, except install manual quarter turn valves in radiation cabinets and all butterfly valves with stems horizontal.
6. Provide shutoff valves and flanges or unions at all connections to equipment, traps, and items that require servicing.
7. Provide flanges or unions at all final connections to equipment, traps and valves.
8. Arrange piping and piping connections so equipment may be serviced or totally removed without disturbing piping beyond final connections and associated shutoff valves.

3.6 PIPE ERECTION AND LAYING

- A. Carefully inspect all pipe, fittings, valves, equipment and accessories prior to installation. Immediately reject and remove from the job any items which are unsuitable, cracked or otherwise defective.
- B. All pipe, fittings, valves, equipment and accessories shall have factory-applied markings, stampings, or nameplates sufficient to determine their conformance with specified requirements.
- C. Exercise care at every stage of storage, handling, laying and erecting to prevent entry of foreign matter into piping, fittings, valves, equipment and accessories. Do not erect or install any unclean item.
- D. During construction, until system is fully operational, keep all openings in piping and equipment closed at all times except when actual work is being performed on that item. Closures shall be plugs, caps, blind flanges or other items designed for this purpose.
- E. Change direction of pipes only with fittings or pipe bends. Change size only with fittings. Do not use miter fittings, face or flush bushings, or street elbows. 2-1/2" and larger fittings shall be long radius type, unless otherwise shown on the drawings or specified. Construct welded elbows of angles not available as standard fittings by cutting and welding standard elbows to form smooth, long radius fittings.
- F. Use full and double lengths of pipe wherever possible.
- G. Unless otherwise indicated, install all inlet and outlet piping, including shutoff valves and strainers, to coils, pumps and other equipment at line size with reduction in size being made only at control valve or pump.
- H. Cut all pipe to exact measurement and install without springing or forcing except in the case of expansion loops where cold springing is indicated on the drawings.
- I. Do not create, even temporarily, undue loads, forces or strains on valves, equipment or building elements.

3.7 DRAINING AND VENTING

- A. Unless otherwise indicated on the drawings, all horizontal pipes, including branches, shall pitch 1" in 40 feet to low points for complete drainage, removal of condensate, and venting.
- B. Provide drain valves at all low points of water piping systems or where indicated on drawings for complete or sectionalized draining. Drain valves are defined above.
- C. Use eccentric reducing fittings on horizontal runs when changing size for proper drainage and venting. Install all liquid lines with top of pipe and eccentric reducers in a continuous line.
- D. Provide air vents at all high points and wherever else required for elimination of air in all water piping systems. Do not use automatic air vents in glycol systems unless they are piped to the fill tank.

- E. Air vents shall be in accessible locations. If needed to trap and vent air in a remote location, a 1/8" pipe shall connect the tapping location to a venting device in an accessible location.
- F. All vent and drain piping shall be of same materials and construction as the service involved.

3.8 BRANCH CONNECTIONS

- A. Make branch connections with standard tee or cross fittings of the type required for the service unless otherwise specified herein or detailed on the drawings.
- B. At the option of the Contractor, branch connections from headers and mains may be cut into black steel pipe using forged weld-on fittings.
- C. Use of forged weld-on fittings is also limited as follows:
 - 1. Must have at least same pressure rating as the main.
 - 2. Header or main must be 2-1/2" or over.
 - 3. Branch line is at least two pipe sizes under header or main size.

3.9 JOINING OF PIPE

- A. Threaded Joints (Steel Pipe):
 - 1. Ream pipe ends and remove all burrs and chips.
 - 2. Protect plated pipe and valve bodies from wrench marks when making up joints.
 - 3. Apply Teflon tape to male threads.
- B. Flanged Joints (Steel Pipe):
 - 1. Bronze flanges shall conform to B16.24 and ductile iron flanges to B16.42. Steel flanges shall be raised face except when bolted to flat face cast iron flange.
 - 2. Bolting shall be ASTM A307 Grade B with bolts and heavy hexagonal nuts conforming to ASME B18.2.1 and B18.2.2.
 - 3. Torque bolts in at least three passes, tightening to 1/3, 2/3, and final torque in a cross pattern with an indicating torque wrench for equal tension in all bolts.
 - 4. Gaskets for flat face flanges shall be full-face type. Gaskets for raised faced flanges shall conform to requirements for "Group I gaskets" in ASME B16.5. All gaskets shall conform to ASME B16.21. Unless otherwise specified, gaskets shall meet the following requirements:
 - a. Gasket material and thickness approved by manufacturer for intended service, chemical compatibility, pipe system test pressure, and operating temperature range.
 - b. Maximum pressure rating of at least 250 psig.
 - c. Minimum temperature rating: -10°F.
 - d. Maximum temperature rating of at least 170°F for water and glycol solution systems operating 140°F and less.
 - e. Maximum temperature rating of at least 250°F for water and glycol solution systems operating above 140°F and up to 180°F.

C. Solder Joints (Copper Pipe):

1. Make up joints with 95% tin and 5% antimony (95-5) solder conforming to ASTM B32 Grade 95TA. Cut copper tubing ends perfectly square and remove all burrs inside and outside. Thoroughly clean sockets of fittings and ends of tubing to remove all oxide, dirt and grease just prior to soldering. Apply flux evenly, but sparingly, to all surfaces to be joined. Heat joints uniformly to proper soldering temperature so solder flows to all mated surfaces. Wipe excess solder, leaving a uniform fillet around cup of fitting.
2. Flux shall be non-acid type conforming to ASTM B813.
3. Solder end valves may be installed directly in the piping system if the entire valve is suitable for use with 470°F melting point solder. Remove composition discs and all seals during soldering if not suitable for 470°F.

D. Welded Joints (Steel Pipe):

1. Welding of all pipe joints, both as to procedures and qualification of welders, shall be in accordance with Section IX, ASME "Boiler & Pressure Vessel Code" unless local codes take precedence.
2. Furnish certificates qualifying each welder to the Owner's Representative prior to start of work.
3. The Owner's Representative reserves the right to require qualifying demonstration, at the Contractor's expense, of any welders assigned to the job.
4. Ends of pipe and fittings to be joined by butt-welding shall be beveled, cleaned to bare metal and internal diameters aligned before tack welding.
5. Single-welded butt joints may be employed with or without the use of backing rings in all sizes. Where backing rings are not used on pumped pressurized systems, the root side of the weld shall either be chipped or ground flush with the piping wall. For services such as vents, overflows, and gravity drains, the backing ring may be eliminated, and the root of the weld need not be chipped or ground. Backing rings shall be of the material being welded.

E. Mechanically Coupled Grooved Joints (Steel and Copper and HDPE):

1. Grooved connections shall mechanically engage, lock and seal the grooved pipe ends in a positive couple. Each coupling shall have malleable iron housing clamps, steel bolts and nuts, and sealing gasket designed so internal pressure increases the tightness of the seal. Couplings must be installation-ready style for quick installation and no more than two-piece housings.
2. All work, including pipe grooving, shall be accomplished in accordance with manufacturer's published instructions.
3. Final tightening of bolts shall be with a torque wrench to ensure equal tension in all bolts.
4. All fittings shall be provided by one manufacturer. Mixing grooved components is not acceptable.
5. Product Warranty:
 - a. Standard: One-year product warranty. A factory-trained manufacturer's representative shall visit the site for contractor training and installation observation.

- 1) On-site Training: Manufacturer's factory trained representative shall provide training of contractor's field personnel in use of grooving tools and installation of product. Documentation of installing contractor training with manufacturer's representative shall be submitted to the Architect/Engineer.
 - 2) Job Site Visitation: Manufacturer's representative shall periodically visit job site to ensure manufacturer^{TMTM}s installation practices are being followed.
- b. Extended 5-Year Product Warranty: Manufacturer shall provide extended 5-year warranty to replace product. Warranty shall include onsite training and inspection of all fittings by manufacturer. Manufacturer inspection report shall be provided to the Owner upon completion.
 - c. Extended 5-Year Product and Installation Warranty: Manufacturer shall provide extended 5-year warranty to replace product and any part of the system damaged as a direct result of a failure of the product. Warranty shall include onsite training and inspection of all fittings by manufacturer. Manufacturer inspection report shall be provided to the Owner upon completion.
6. Acceptable Manufacturers: Victaulic, Gruvlok, or Star Fittings.
- F. Mechanical Press Connection (Copper):
1. Copper press fitting shall be made in accordance with the manufacturer^{TMTM}s installation instructions.
 2. Fully insert tubing into the fitting and mark tubing.
 3. Prior to making connection, the fitting alignment shall be checked against the mark made on the tube to ensure the tubing is fully engaged in the fitting.
 4. Joint shall be pressed with a tool approved by the manufacturer. Installers shall be trained by manufacturer personnel or representative. Provide documentation upon request.
- 3.10 ACOUSTICAL LAGGING
- A. Where indicated on drawings, completely wrap pipe with lagging and seal all joints airtight with tape recommended by the lagging manufacturer to prevent acoustical leakage at joints. Overlap lagging a minimum of 2" at any joint. Overlap lagging 2" at any wall, floor, or structural deck penetration to prevent acoustical leakage.

END OF SECTION 23 21 00

SECTION 23 21 16 - HYDRONIC SPECIALTIES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Automatic Air Vents
- B. Safety Relief Valves
- C. Suction Diffusers
- D. Balancing Valves
- E. Combination Piping Packages
- F. Expansion Tank
- G. Air Separators
- H. Drain Valves and Blowdown Valves
- I. Glycol
- J. Glycol Feed System

1.2 QUALITY ASSURANCE

- A. Valves: Manufacturer's name and pressure rating marked on valve body. Remanufactured valves are not acceptable.
- B. Welding Materials, Procedures, and Operators: Conform to ASME Section 9, ANSI/AWS D1.1, and applicable state labor regulations.

1.3 REFERENCES

- A. ASME - Boiler and Pressure Vessel Code.
- B. ASME B31.3 - Chemical Plant and Petroleum Refinery Piping.
- C. ASME B31.9 - Building Services Piping.
- D. ASME Section 9 - Welding and Brazing Qualifications.
- E. ASTM A536 - Standard Specification for Ductile Iron Castings
- F. ASTM B32 - Standard Specification for Solder Metal.

1.4 SUBMITTALS

- A. Submit product data under provisions of Section 23 05 00. Include data on pipe materials, fittings, valves, and accessories. Include manufacturers' support spacing requirements for plastic piping.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store and protect piping to prevent entrance of foreign matter into pipe and to prevent exterior corrosion.
- B. Deliver and store valves in shipping containers with labeling in place.

PART 2 - PRODUCTS

2.1 AUTOMATIC AIR VENTS

- A. Low capacity automatic air vent (for bladder tank anti-thermosyphon loops). Maximum operating pressure and temperature of at least 240°F and 125 psi, 1/2" or 3/4" inlet.
- B. High/low capacity automatic air vent (for air separator connection). Maximum operating pressure and temperature of at least 240°F and 125 psi, 3/4" inlet, 3/8" minimum outlet.

2.2 SAFETY RELIEF VALVES

- A. SRV-1 (Hydronic Heating Systems): Spring-loaded disc type with cast iron or bronze body, bronze or stainless steel disc, side outlet and lifting lever for maximum service of 125 psig at 250°F. For relieving water during pressure fluctuations and in case of control failure. Capacities shall be ASME Section IV certified and labeled.
- B. Manufacturers:
 - 1. Watts

2.3 SUCTION DIFFUSER

- A. Furnish and install on base-mounted pumps with inlet size same as pipe size shown on the drawing.
- B. In no case shall pressure drop exceed 3.0 psi.
- C. Suction diffuser shall consist of angle body with inlet vanes and combination diffuser-strainer-orifice cylinder with 3/16" diameter openings for pump protection, gauge tappings, and blowdown connection. Orifice cylinder, with bronze or stainless steel strainer with free area at least 5 times cross section area of pump suction opening. Furnish adjustable foot to support weight of suction piping. Connect drain valve to blowdown connection. Provide 16 mesh bronze startup strainer. The startup strainer shall be removed after the system has been started, cleaned, and is operating under normal conditions, but before the system is turned over to the Owner. Hang the startup strainer on the piping near the pump after it is removed.

D. Manufacturers:

1. Amtrol
2. Armstrong
3. Bell & Gossett
4. Taco

2.4 BALANCING VALVE

- A. Rated for 125 psi working pressure and 250°F operating temperature, taps for determining flow with a portable meter, positive shutoff valves for each meter connection, memory feature, tight shutoff, and a permanent pressure drop between 1' and 2' water column at full flow with valve 100% open. Furnish with molded, removable insulation covers.
- B. Provide a nomograph to determine flow from meter reading (and valve position on units that sense pressure across a valve). Graph shall extend below the specified minimum flow.
- C. Furnish one meter kit equivalent to Bell & Gossett Model RO-5 meeting the following requirements:
1. Carrying case with handle.
 2. Pressure gauge with 0-25 feet of head scale with 3.0% full scale accuracy.
 3. High and low side hoses with 5 feet length and 250 psig pressure rating, equipped with shutoff valves, vent valves, and probes for insertion into pressure and temperature plugs.
- D. Valves in copper piping shall be brass or bronze.
1. Quarter-Turn Ball Valve Style (Brass or Bronze):
 - a. Manufacturers:
 - 1) Bell & Gossett "Circuit Setter Plus"
 2. Quarter-Turn Venturi Style (Brass or Bronze):
 - a. Manufacturers:
 - 1) HCI "Terminator B"
 - 2) Nexus Valve "UltraXB Orturi"
 - 3) MI Hydronic Engineering "Accusetter"
- E. Valves in ferrous piping 2" or smaller shall have threaded ends and steel, brass or bronze construction. Option to balancing valves noted above are flow sensors specified in Section 23 09 00 with a specified throttling valve.
1. Quarter-Turn Venturi Style (Ferrous Piping ≥ 2"):
 - a. Manufacturers:
 - 1) HCI "Terminator B"

- 2) Nexus Valve "UltraXB Orturi"
 - 3) IMI Hydronic Engineering "Accusetter"
2. Multi-Turn Style (Ferrous Piping \geq 2"):
- a. Manufacturers:
 - 1) TA Hydronics "786-789"
- F. Balancing valves in ferrous piping over 2 size shall have flanged or grooved ends and steel or cast iron construction. Option to balancing valves noted above are flow sensor specified in Section 23 09 00 with a specified throttling valve.
1. Quarter-Turn Ball Valve Style (Ferrous Piping Greater Than 2"):
 - a. Manufacturers:
 - 1) B&G "Circuit Setter"
 2. Quarter-Turn Venturi Style (Ferrous Piping Greater Than 2"):
 - a. Manufacturers:
 - 1) HCI "Terminator G"
 - 2) Nexus Valve "Nextrol NXFB"
 - 3) IMI Hydronic Engineering "Accusetter"
- G. Balancing valves in ferrous piping over 2" size shall consist of flow sensors as specified in Section 23 09 00 combined with specified throttling valves.
- H. Manufacturer shall size balancing valves for the scheduled flow rate. Flow rate shall be measurable on manufacturer's standard meters.

2.5 COMBINATION PIPING PACKAGES

- A. Combination piping packages are allowed [at unitary equipment only (1 pipe size and smaller)][at all unitary and AHU coils] in lieu of individual components specified for hydronic coils and devices containing hydronic coils. Configuration of combination pieces shall match layouts on the drawings. Each component of the combination piping packages shall meet these specifications for the individual components being combined. Coil connections shall be [rigid][or][made with flexible hose equal to Metraflex SFLXTU18]. Combination piping packages shall include:
1. Shutoff valves
 2. Wye strainers, with 1/4 turn strainer blowdown valves with hose thread and cap
 3. Manual balancing valves with memory stop. Automatic flow control devices are not allowed.
 4. Test plugs
 5. Manual air vents
 6. Unions

B. Manufacturers:

1. FDI Flowset
2. HCI Terminator
3. NIBCO, Victaulic

2.6 EXPANSION TANK

A. Bladder Type:

1. Tank shall be welded steel, ASME construction and stamped.
2. Tank shall be complete with heavy-duty replaceable butyl bladder, charging valve, lifting ring, drain tapping, and system connection.
3. 125 psig working pressure and 240°F maximum operating temperature.
4. Manufacturers:
 - a. Taco
 - b. Bell & Gossett
 - c. Armstrong
 - d. Watts
 - e. Wessels
 - f. Wheatley
 - g. Amtrol
 - h. Grundfos

2.7 coalescing type combination AIR eliminator and dirt separator

- A. Coalescing type air eliminator and dirt separator shall be fabricated from steel and ASME constructed and certified for 125 psi working pressure rated for 150 psig working pressure. Designed and constructed in accordance with with ASME stamp, with two equal chambers above and below the inlet / outlet nozzles. Flanges to be Class 150, raised face, weld neck. and 270°F operating temperature. Units 2-1/2 inches and smaller shall have threaded connections. Units 3 inches and larger shall have flanged connections.
- B. Unit shall include internally structured coalescing media elements uniformly filling the entire vessel to suppress turbulence and provide air elimination efficiency of less than 99.5% free and entrained air, and 99.6% dissolved air at the installed location. Dirt separation efficiency shall be a minimum of 80% of all particles 30 micron and larger within 100 passes. Units capable of 5 micron dirt removal.
- C. Air elimination and dirt separation shall be by coalescing action by copper tubes with continuous wound, permanently attached copper wire and followed by a separate continuous wound permanently affixed copper wire.
- D. Provide unit with factory mounted air vent at the top of the air elimination chamber.
- E. Provide brass flushing cock on the separator side to facilitate system fast-fill and to blow down impurities from the water surface within the separator.

- F. Provide factory-mounted blowdown valve on the unit bottom to allow for draining and cleaning. Unit shall be manufactured with a removable lower head for internal inspection.
- G. Units shall be painted. Units with a primer finish are not acceptable.
- H. Warranty: Three-year.
- I. Coalescing separator shall be as sized on the construction drawings, but in no case shall it have less than line size connections nor shall entering velocity exceed 10 feet per second. Pressure drop shall not exceed [5psi at design flow. Include on submittal the pressure drop of each unit at its design flow rate.
- J. Manufacturers:
 - 1. Spirotherm

2.8 DRAIN VALVES AND BLOWDOWN VALVES

- A. Drain valve and blowdown valve shall mean a shutoff valve as specified for the intended service with added 3/4" male hose thread outlet, cap, and retaining chain.

2.9 CONNECTIONS BETWEEN DISSIMILAR METALS

- A. Connections between dissimilar metals shall be insulating dielectric types that provide a water gap between the connected metals, and that either allow no metal path for electron transfer or that provide a wide water gap lined with a non-conductive material to impede electron transfer through the water path.
- B. Joints shall be rated for the temperature, pressure, and other characteristics of the service in which they are used, including testing procedure.
- C. Aluminum, iron, steel, brass, copper, bronze, galvanized steel, and stainless steel are commonly used and require isolation from each other with the following exceptions:
 - 1. Iron and steel connected to each other.
 - 2. Brass, copper, and bronze connected to each other.
 - 3. Brass or bronze valves and specialties connected in closed systems with steel, iron, or stainless steel on both sides of the brass or bronze valves and specialties. Where two or more brass or bronze items occur together, they shall be connected with brass nipples. Brass or bronze valves and specialties cannot be used as a dielectric separation between pipe materials.
- D. Dielectric protection is required at connections to equipment of a material different than the piping.
- E. Screwed Joints (acceptable up to 2" size):
 - 1. Dielectric waterway rated for 300 psi CWP and 225°F.
- F. Flanged Joints (any size):

1. Use 1/8" minimum thickness, non-conductive, full-face gaskets.
2. Employ one-piece molded sleeve-washer combinations to break the electrical path through the bolts.
3. Sleeve-washers are required on one side only, with sleeves minimum 1/32" thick and washers minimum 1/8" thick.
4. Install steel washers on both sides of flanges to prevent damage to the sleeve-washer.
5. Separate sleeves and washers may be used only if the sleeves are manufactured to exact lengths and installed carefully so the sleeves must extend partially past each steel washer when tightened.

2.10 PROPYLENE GLYCOL

- A. Fill systems with a mixture of water and industrially inhibited propylene glycol low temperature industrial heat transfer fluid with an expected life of at least 12 years in normal use. Water shall meet the glycol manufacturer's recommendations (generally less than 25ppm chloride, sulfite, and hardness). Distilled, deionized, or reverse osmosis water is acceptable, as are pre-diluted solutions from the manufacturer. Solution shall contain a dye to facilitate leak detection.
- B. Fluid suitable for use from -28°F to 250°F.
- C. Glycol shall pass ASTM D1384 (less than 0.5 mils annual penetration of all system metals). Glycol supplier shall provide a certificate of assurance.
- D. A 50% solution by weight shall depress the freezing point to at least -34°F. At 40°F the solution shall have viscosity of not over 14 centipoise, thermal conductivity of at least 0.199 Btu/hr*ft**°F, specific heat of at least 0.839 Btu/lbm**°F, and specific gravity of at least 1.06.
- E. Manufacturer shall offer a testing service to determine if inhibitor addition is needed.
- F. All three schools shall be provided to 30% upon project completion. Contractor to provide verification before and after construction. Contractor to measure concentration at each school and provide report to Owner and Engineer prior to any work.
- G. Manufacturers:
 1. Dow Chemical "Dowfrost HD"
 2. Interstate Chemical "Intercool NFP"
 3. Houghton Chemical "Safe-T-Therm HD"
 4. Texaco.

~~2. Manufacturers:~~

2.11 GLYCOL FEED SYSTEM

- A. Package system complete with storage tank, pump(s) and controls with audio and visual alarm, designed to add glycol solution to a closed loop water system. System shall automatically maintain pressure in the piping system.

- B. Provide cut-off and alarm to stop pump in case of low level or high pressure. Provide dry contact for alarm point to the DDC.
- C. Complete with polyethylene storage tank and lid. Mount on floor above pumping assembly in a steel frame with legs. Lid shall be removable for filling and provide means for system relief valve outlet to be piped back to tank without removal of piping from relief valve or automatic air vent.
- D. Pumping system shall consist of a pump, starter, pressure tank with pressure control, pressure reducing valve, shutoff valve and pressure gauge. Refer to schedule for pump requirements.
- E. 55 Gallon tank capacity.
- F. Manufacturers:
 - 1. Advantage Controls AGF
 - 2. Axiom SF100
 - 3. Approved Equal

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Valves/Fittings and Accessories:
 - 1. Where a manual balance valve is shown to be installed in series with a service (isolation) valve, separate balance and service (isolation) valves shall be installed.
 - 2. Install balancing valves with the manufacturer's recommended straight upstream and downstream diameters of pipe.

Product	Upstream Diameters	Downstream Diameters
Griswald "Quickset"	0	0
Fluid Design "Accusetter"	0 up to 2" size	0
	5 for larger sizes	
Presso "B+"	5	2
Taco "Accu-flo"	10	5
TA Hydronics 786-789	5 after fittings	2
	10 after pumps	
Bell & Gossett "Circuit Setter Plus"	3	1
Bell & Gossett "Circuit Setter"	3 up to 4" size	1 up to 4" size
	5 above 4" size	2 above 4" size
Armstrong "CVB" and "CVB-II"	10	5

Gerand "BALVALVE Venturi"	5	2
NIBCO 1710/737	5	3

3. Prepare accessories for finish painting.
4. Install accessories with stems upright or horizontal, not inverted, except install manual quarter turn valves in radiation cabinets and all butterfly valves with stems horizontal.
5. Provide shutoff valves and flanges or unions at all connections to equipment, traps, and items that require servicing.
6. Provide flanges or unions at all final connections to equipment, traps and valves.
7. Arrange piping and piping connections so equipment may be serviced or totally removed without disturbing piping beyond final connections and associated shutoff valves.

END OF SECTION 23 21 16

SECTION 23 21 23 - HVAC PUMPS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. All pumps except where integral with a manufactured piece of equipment.
- B. Pump controls where self-contained.

1.2 SUBMITTALS

- A. Submit shop drawings under provisions of Section 23 05 00.
- B. Submit certified pump performance curves with pump and system operating point plotted. Include NPSH curve when applicable.
- C. Submit motor data indicating compliance with Section 23 05 13.

PART 2 - PRODUCTS

2.1 PUMPS - GENERAL

- A. Statically and dynamically balance rotating parts.
- B. Construction shall permit complete servicing without breaking piping or motor connections.
- C. Pumps shall operate at 1750 rpm unless specified otherwise.
- D. Pump connections shall be flanged, whenever available.
- E. Heating pumps shall be suitable for 225°F water.
- F. Motors shall comply with Section 23 05 13.
- G. Pump impellers shall not have smaller diameters than those scheduled. The inlet and discharge pipe sizes shall also meet or exceed the scheduled pump.
- H. Pumps specified in this section operating in clean water with a flow greater than 25 GPM and less than 459 feet head shall have a maximum Pump Energy Index (PEI) as scheduled on the drawings. In no case shall the PEI exceed 1.0.

2.2 BASE MOUNTED END SUCTION PUMPS

- A. Type: Centrifugal, single stage.
- B. Casing: Cast iron, single suction, rated for greater of 150 psi or 1.25 times actual working discharge pressure, flanged suction and discharge with gauge ports.

- C. Impeller: Bronze, fully enclosed, keyed to shaft.
- D. Shaft: High grade alloy steel with copper, bronze or stainless steel shaft sleeves.
- E. Bearings: Grease lubricated roller or ball bearings with grease fittings. If pump will be insulated, grease fittings shall be extended 3" with rigid pipe to clear the insulation.
- F. Drive: Flexible coupling with OSHA-approved guard.
- G. Seals: Mechanical type with internal flushing rated for -20 to 225°F with Buna elastomer, carbon primary ring, and ceramic stationary ring.
- H. Baseplate: Heat treated cast iron or reinforced heavy steel.
- I. Shepardson Elementary Only - Alternate #1.
- J. Manufacturers:
 - 1. Bell & Gossett
 - 2. Taco
 - 3. Aurora
 - 4. Armstrong
 - 5. Grundfos/Peerless/PACO

2.3 IN-LINE PUMP

- A. Type: Centrifugal, single stage, close coupled in-line, back pullout design, suitable for horizontal or vertical operation.
- B. Casing: Cast iron, rated for greater of 125 psi or 1.5 times actual working discharge pressure, flanged suction and discharge with gauge ports.
- C. Impeller: Bronze or stainless steel, fully enclosed, dynamically balanced, keyed to shaft and secured with locknut.
- D. Shaft: Steel or stainless steel.
- E. Seals: Mechanical type with internal flushing rated for -20 to 225°F and comprised of Buna elastomer, carbon primary ring, and ceramic stationary ring.
- F. Seals: Mechanical type rated for -20 to 250°F with EPR or EPT bellows and seat gasket, carbon primary ring, and silicon-carbide stationary ring.
- G. Provide all inline integral ECM motor or frequency converter. Refer to schedule on drawings. Provide equal to scheduled basis of design
- H. Manufacturers:
 - 1. Bell & Gossett
 - 2. Taco
 - 3. Grundfos/Peerless/PACO

PART 3 - EXECUTION

3.1 INSTALLATION

A. General Installation Requirements:

1. Install all products per manufacturer's recommendations.
2. Support piping adjacent to pumps so that no weight is carried by pump casings. Provide supports under elbows on 4" and larger pump suction and discharge pipes. Allow a minimum of 18" clearance for removal of suction diffuser.
3. Ensure pumps operate at specified fluid temperatures without vapor binding or cavitation, are non-overloading in parallel or individual operation, and operate within 25% of midpoint of published maximum efficiency curve.
4. Install on vibration isolators as scheduled on drawings.

B. In-Line Pumps:

1. Support in-line pumps individually so there is no strain on the piping. Install with a minimum of five diameters of straight pipe on pump suction and discharge.
2. Pump orientation shall be in accordance with the manufacturer's recommendations.

C. Base-Mounted Pumps:

1. Base-mounted pump alignment shall be inspected and approved by a factory-trained representative. If alignment is not satisfactory, the representative shall field laser align the shaft. If the pump is aligned in the field, an alignment report shall be provided as part of the closeout documents.
2. Base-mounted pump shall be aligned in accordance with the pump manufacturer's recommendations. A factory-trained representative shall laser align the pump to meet the manufacturer's requirements and tolerances. An alignment report shall be provided as part of the project closeout documents.
3. Unless otherwise shown on the drawings, mount all base mounted pumps on 4" high concrete pads and anchor frames to pads with cast-in-place anchors.
4. All base-mounted pumps shall be grouted-in. Follow manufacturer's instructions for grouting.

END OF SECTION 23 21 23

SECTION 23 52 16 - CONDENSING BOILERS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Boilers.
- B. Controls and Boiler Trim.
- C. Hot Water Connections.
- D. Vent Connection.
- E. Boiler Vent Flue.

1.2 QUALITY ASSURANCE

- A. Manufacturer: Company specializing in manufacturing the products specified in this Section with at least three years documented experience.
- B. Provide factory authorized start-up service by manufacturer's agent.
- C. Conform to ANSI/ASME SEC 4 and ANSI/AGA Z21.13 for construction of boilers.
- D. Boiler Units: AGA certified, UL listed and ASME certified.
- E. Installation shall meet the requirements of ASME CSD-1, including remote emergency shutdown switches for boilers, applicable gas train, individual venting of gas regulators, and repackable shutoff valves at all boilers.
- F. Conform to ASHRAE 90.1.

1.3 REFERENCES

- A. AGA - Directory of Certified Appliances and Accessories.
- B. ANSI/AGA Z21.13 - Gas-Fired Low-Pressure Steam and Hot Water Boilers.
- C. ANSI/AGA Z223.1 - National Fuel Gas Code.
- D. ANSI/ASHRAE/IES Standard 90.1 (latest published edition) - Energy Standard for Buildings Except Low-Rise Residential Buildings.
- E. ANSI/ASME SEC 4 - Boiler and Pressure Vessels Code - Rules for Construction of Heating Boilers.
- F. ANSI/ASME SEC 8D - Boilers and Pressure Vessels Code - Rules for Construction of Pressure Vessels.

- G. ANSI/NFPA 70 - National Electrical Code.
- H. ASME CSD-1 - Controls and Safety Devices for Automatically Fired Boilers.
- I. NFPA 85 - Boiler and Combustion Systems Hazard Code.

1.4 SUBMITTALS

- A. Submit product data under provisions of Section 23 05 00.
- B. Submit product data indicating general assembly, components, controls, safety controls, and electrical power/controls wiring diagrams, and service connections.
- C. Submit manufacturer's installation instructions.
- D. Submit reports indicating condition and operation at start-up.
- E. Submit reports indicating specified performance and efficiency is met or exceeded.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Protect boilers from damage by leaving factory inspection openings and shipping packaging in place until final installation.

1.6 OPERATION AND MAINTENANCE DATA

- A. Submit operation and maintenance data. Include manufacturer's descriptive literature, operating instructions, cleaning procedures, replacement parts list, and maintenance and repair data.

PART 2 - PRODUCTS

2.1 BOILERS

- A. Provide factory assembled, factory fire-tested, self-contained unit ready for automatic operation except for connection of water, fuel, electrical, and vent services.
- B. Unit: Hot water, condensing type boiler with integral forced draft or pulse combustion burner, burner controls, boiler trim, insulation and jacket.
- C. ASME allowable working pressure of 150 psig water.
- D. Provide two lifting eyes on top of boiler.
- E. Unit casing shall be a minimum of 16 gauge steel. Factory paint boiler, base, and other components with hard finish enamel.
- F. Porcelain enameled or stainless steel exhaust manifold with gravity drain and reservoir for condensate elimination.

G. Single Fuel:

1. Manufacturers:

- a. Lochinvar (Crest)
- b. Buderus (SB with Power Flame Burner)

2.2 BOILER FLUE

- A. The boiler manufacturer shall review and approve vent size, type, and routing of all vent flue piping, fittings, dampers, and accessories as required to properly vent the equipment. Vent piping shall be UL listed for use with category III and IV appliances with operating temperatures of up to 480°F. Route, Size, and terminate flue and combustion air per manufacturers written instructions. Flue Material: AL29-4C SS
- B. Combustion Air Material: Galvanized

2.3 HOT WATER BOILER TRIM

- A. Provide ASME safety relief valve set at 125 psi or boiler maximum allowable working pressure.
- B. Provide low water cut-off with manual reset to automatically prevent burner operation whenever boiler water falls below safe level.
- C. Provide operating temperature controller to control burner operation to maintain boiler water temperature, as determined by a remote 4-20 mA signal from building DDC system or boiler controller.
- D. Limit temperature controller to control burner to prevent boiler water temperature from exceeding safe system water temperature.
- E. Provide all trim required to meet ASME CSD-1. This includes, but is not limited to, gas train and all terminals and necessary relays for connection to remote shutdown switch(es) to disconnect all power to the burner controls.

2.4 FUEL BURNING SYSTEM - SINGLE FUEL

- A. General: Forced draft automatic burner integral with boiler designed to burn natural gas at 8.5" to 14" W.C. inlet pressure. Maintain fuel-air ratios automatically.
- B. Burner to be modulating with a minimum turndown ratio of 20:1.

2.5 ACID NEUTRALIZATION KIT

- A. Kit shall consist of a PVC vessels filled with lime stone chips, inlet and out let connections with a means to replace the limestone chips. Kit shall be commercially manufactured and listed for this application
- B. Provide 50lbs of lime stone chips on boiler turnover to owner.

2.6 CONTROL PANEL

- A. Program relay to control ignition, starting and stopping of burner and provide both pre-combustion purge and post combustion purge. Burner to shut down in event of ignition or main flame failure. Interlock to shut down burner upon combustion air pressure drop.
- B. Manual-automatic selector switch to permit automatic firing in accordance with load demand, or manual control of firing rate at fixed temperature.
- C. Panel to include indicating lights to show fault conditions of low water level, flame failure, fuel pressure, exhaust temperature, water temperature, or combustion air pressure. Mount indicating lights and switches in hinged drop-panel for access to wiring.
- D. The boiler system control panel shall include contacts for a manual CSD-1 emergency shutdown switch. The switch shall be furnished, installed, and wired by the Temperature Controls Contractor. A switch shall be located at each exit just outside the boiler room door or as shown on plans. If boiler room door is on exterior of building, the switch shall be located just inside the door or as shown on plans. Verify final location with Architect/Engineer. The switch shall disable all boilers and shall be wired to the boiler burner safety control circuit to interrupt burner operation.
- E. The boiler shutdown switch shall be an emergency stop, mushroom head with N.C. contact, turn to release switch with engraved nameplate to read "BOILER EMERGENCY SHUTOFF". Square D XAL K174 or as approved by Architect/Engineer.
- F. For multiple boiler systems, furnish a boiler management system consisting of controller(s) capable of stopping, starting, and modulating all boilers to maintain maximum efficiency of the boiler plant. The boiler management system shall include all alarms, control points, and setpoints specified.
- G. Manufacturer shall provide a BACnet interface with the building automation system in accordance with ASHRAE/ANSI Standard 135. This may be accomplished through a system integration panel or "gateway". Integration panels shall be provided as part of the boiler package. Wiring between the boiler control panel(s) and the integration panel shall be the responsibility of the manufacturer.

2.7 PERFORMANCE

- A. Minimum gas-fired efficiency, verified by factory tests, shall be 86% at 100% output with 150°F return water and 88% at 25% output with 130°F return water.
- B. Rated for return temperatures as low as 40°F (4°C) and supply temperatures as high as 190° (88°C)

C. PART 3 EXECUTION

2.8 INSTALLATION

- A. General Requirements:
 - 1. Install in accordance with manufacturer's instructions.

2. Provide for connection to electrical service.
3. Provide connection of gas service in accordance with ANSI/AGA Z223.1.
4. Provide connection of fuel oil supply and return piping connections. Hydraulically separate fuel supply system from boiler fuel pumping system.
5. Pipe safety relief valve and condensate trap to glycol feed system. Route condensate pipe to acid resistant floor drain.
6. Install heating water circulation pump as recommended by the manufacturer.

B. Combustion Inlet and Venting:

1. Provide complete sealed combustion inlet and venting system.
2. Slope all horizontal runs of exhaust vent towards the boilers at a slope of 1" per 4'.

C. Service Clearance:

1. Install the boilers with a minimum of three feet clear space behind them for installation of piping and services. Verify exact maintenance clearances required by the manufacturer prior to installation.

2.9 MANUFACTURER'S FIELD SERVICES

- A. Prepare and start systems under factory authorized supervision.
- B. Provide field representative for starting unit and training operator.
- C. Provide combustion test and submit report. Test shall include boiler firing rate, overfire draft, gas flow rate, heat input, burner manifold gas pressure, percent carbon monoxide (CO), percent oxygen (O₂), percent excess air, flue gas temperature at outlet, ambient temperature, net stack temperature, percent combustion efficiency, and heat output.
- D. Dual fuel boilers shall be fired on natural gas and fuel oil. Contractor shall provide the supply of fuel oil necessary for the firing test. Provide a minimum of two hours of operation for each boiler on fuel oil prior to system turn over. Upon completion of the test, provide cleaning of the combustion chamber, breeching, and flue and then re-fire and test again on natural gas. Ensure the manufacturer's published operational efficiency is achieved. Document the results in the manufacturer's startup report.

END OF SECTION 23 52 16

SECTION 26 05 00 - BASIC ELECTRICAL REQUIREMENTS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Requirements applicable to all Division 26 Sections. Also refer to Division 1 - General Requirements.
- B. All materials and installation methods shall conform to the applicable standards, guidelines and codes referenced herein and within each specification section.

1.2 REFERENCES

- A. NFPA 70 - National Electrical Code (NEC)

1.3 SCOPE OF WORK

- A. This Specification and the associated drawings govern furnishing, installing, testing and placing into satisfactory operation the Electrical Systems.
- B. The Contractor shall furnish and install all new materials as indicated on the drawings, and/or in these specifications, and all items required to make the portion of the Electrical Work a finished and working system.
- C. Separate contracts will be awarded for the following work.
- D. All work will be awarded under a single General Contract. The division of work listed below is for the Contractor's convenience and lists normal breakdown of the work.
- E. Separate contracts will be awarded for the following work. The division of work listed below is for the contractors' convenience and lists a normal breakdown of the work. Please refer to the Construction Manager's scope statements for complete scope of work description.
- F. Description of Systems shall be as follows:
 - 1. Electrical power system to and including equipment, motors, devices, etc.
 - 2. Grounding system.
 - 3. Wiring system for temperature control system as shown on the drawings.
 - 4. Wiring of equipment furnished by others.
 - 5. Removal work and/or relocation and reuse of existing systems and equipment.
 - 6.
 - 7. Furnish and install firestopping systems for penetrations of fire-rated construction associated with this Contractor's work.
- G. Work Not Included:
 - 1. Telecommunications cabling will be by others, in raceways and conduits furnished and installed as part of the Electrical work.

2. Temperature control wiring for plumbing and HVAC equipment (unless otherwise indicated) will be by other Contractors.

1.4 WORK SEQUENCE

- A. All work that will produce excessive noise or interference with normal building operations, as determined by the Owner, shall be scheduled with the Owner. It may be necessary to schedule such work during unoccupied hours. The Owner reserves the right to determine when restricted construction hours are required.

1.5 DIVISION OF WORK BETWEEN MECHANICAL, ELECTRICAL, and CONTROL CONTRACTORS

- A. Division of work is the responsibility of the Prime Contractor. Any scope of work described at any location on the contract document shall be sufficient for including said requirement in the project. The Prime Contractor shall be solely responsible for determining the appropriate subcontractor for the described scope. In no case shall the project be assessed an additional cost for scope that is described on the contract documents on bid day. The following division of responsibility is a guideline based on typical industry practice.

B. Definitions:

1. "Mechanical Contractors" refers to the Contractors listed in Division 21/22/23 of this Specification.
2. "Technology Contractors" refers to the Contractors furnishing and installing systems listed in Division 27/28 of this Specification.
3. Motor Power Wiring: The single phase or 3 phase wiring extending from the power source (transformer, panelboard, feeder circuits, etc.) through disconnect switches and motor controllers to, and including the connections to the terminals of the motor.
4. Motor Control Wiring: The wiring associated with the remote operation of the magnetic coils of magnetic motor starters or relays, or the wiring that permits direct cycling of motors by means of devices in series with the motor power wiring. In the latter case, the devices are usually single phase, have "Manual-Off-Auto" provisions, and are usually connected into the motor power wiring through a manual motor starter.
5. Control devices such as start-stop push buttons, thermostats, pressure switches, flow switches, relays, etc., generally represent the types of equipment associated with motor control wiring.
6. Motor control wiring is single phase and usually 120 volts. In some instances, the voltage will be the same as the motor power wiring. When the motor power wiring exceeds 120 volts, a control transformer is usually used to give a control voltage of 120 volts.
7. Temperature Control Wiring: The wiring associated with the operation of a motorized damper, solenoid valve or motorized valve, etc., either modulating or two-position, as opposed to wiring that directly powers or controls a motor used to drive equipment such as fans, pumps, etc. This wiring will be from a 120-volt source and may continue as 120 volt, or be reduced in voltage (24 volt), in which case a control transformer shall be furnished as part of the temperature control wiring.
8. Control Motor: An electric device used to operate dampers, valves, etc. It may be two-position or modulating. Conventional characteristics of such a motor are 24 volts, 60 cycles, 1 phase, although other voltages may be encountered.
9. Low Voltage Technology Wiring: The wiring associated with the technology systems, used for analog or digital signals between equipment.

10. Telecommunications/Technology Rough-in: Relates specifically to the backboxes, necessary plaster rings and other miscellaneous hardware required for the installation or mounting of telecommunications/technology information outlets.

C. General:

1. The purpose of these Specifications is to outline the Electrical and Mechanical Contractors' responsibilities related to electrical work required for items such as temperature controls, mechanical equipment, fans, chillers, compressors, etc. The exact wiring requirements for much of the equipment cannot be determined until the systems have been selected and submittals approved. Therefore, the electrical drawings show only known wiring related to such items. All wiring not shown on the electrical drawings, but required for mechanical systems, is the responsibility of the Mechanical Contractor.
2. Where the drawings require the Electrical Contractor to wire between equipment furnished by the Mechanical Contractor, such wiring shall terminate at terminals provided in the equipment. The Mechanical Contractor shall furnish complete wiring diagrams and supervision to the Electrical Contractor and designate the terminal numbers for correct wiring.
3. Control low (24V) and control line (120V) voltage wiring, conduit, and related switches and relays required for the automatic control and/or interlock of motors and equipment, including final connection, are to be furnished and installed under Divisions 21, 22 and 23. Materials and installation to conform to Class 1 or 2 requirements, California Electrical Code Article 725.

D. Mechanical Contractor's Responsibility:

1. Assumes responsibility for internal wiring of all equipment furnished by the Mechanical Contractor.
2. Assumes all responsibility for miscellaneous items furnished by the Mechanical Contractor that require wiring but are not shown on the electrical drawings or specified in the Electrical Specification. If items such as relays, flow switches, or interlocks are required to make the mechanical system function correctly or are required by the manufacturer, they are the responsibility of the Mechanical Contractor.
3. Assumes all responsibility for Temperature Control wiring, if the Temperature Control Contractor is a Subcontractor to the Mechanical Contractor.
4. This Contractor is responsible for coordination of utilities with all other Contractors. If any field coordination conflicts are found, the Contractor shall coordinate with other Contractors to determine a viable layout.

E. Temperature Control Contractor's or Subcontractor's Responsibility:

1. Wiring of all devices needed to make the Temperature Control System functional.
2. Verifying any control wiring on the electrical drawings as being by the Electrical Contractor. All wiring required for the Control System, but not shown on the electrical drawings, is the responsibility of the Temperature Control Contractor or Subcontractor.
3. Coordinating equipment locations (such as PE's, EP's, relays, transformers, etc.) with the Electrical Contractor, where wiring of the equipment is by the Electrical Contractor.

F. Electrical Contractor's Responsibility:

1. Furnishes and installs all combination starters, manual starters and disconnect devices shown on the Electrical Drawings or indicated to be by the Electrical Contractor in the Mechanical Drawings or Specifications.
2. Installs and wires all remote-control devices furnished by the Mechanical Contractor or Temperature Control Contractor when so noted on the Electrical Drawings.
3. Furnishes and installs motor control and temperature control wiring, when noted on the drawings.
4. Furnishes, installs, and connects all relays, etc., for automatic shutdown of certain mechanical equipment (supply fans, exhaust fans, etc.) upon actuation of the Fire Alarm System.
5. This Contractor is responsible for coordination of utilities with all other Contractors. If any field coordination conflicts are found, the Contractor shall coordinate with other Contractors to determine a viable layout.

1.6 COORDINATION DRAWINGS

A. Definitions:

1. Coordination Drawings: A compilation of the pertinent layout and system drawings that show the sizes and locations, including elevations, of system components and required access areas to ensure that no two objects will occupy the same space.
 - a. Mechanical trades shall include, but are not limited to, mechanical equipment, ductwork, fire protection systems, plumbing piping, medical gas systems, hydronic piping, steam and steam condensate piping, and any item that may impact coordination with other disciplines.
 - b. Electrical trades shall include, but are not limited to, electrical equipment, conduit 1.5" and larger, conduit racks, cable trays, pull boxes, transformers, raceway, busway, lighting, ceiling-mounted devices, and any item that may impact coordination with other disciplines.
 - c. Maintenance clearances and code-required dedicated space shall be included.
 - d. The coordination drawings shall include all underground, underfloor, in-floor, in chase, and vertical trade items.
2. Spaces with open/cloud ceiling architecture shall indicate the overhead utilities and locate equipment as required to maintain clearance above lights. The intent for the installation is to maintain a maximum allowable vertical clearance and an organized/clean manner in the horizontal. Notify Architect/Engineer of the maximum clearance which can be maintained. Failure to comply will result in modifications with no cost to Owner.
 - a. In cloud ceiling architecture, when open cabling/wire and/or cable tray crosses gaps between ceiling clouds and/or walls, cabling is to transition to conduits to span the gaps in order to conceal cabling from below.
3. The contractors shall use the coordination process to identify the proper sequence of installation of all utilities above ceilings and in other congested areas, to ensure an orderly and coordinated end result, and to provide adequate access for service and maintenance.

B. Participation:

1. The contractors and subcontractors responsible for work defined above shall participate in the coordination drawing process.
2. One contractor shall be designated as the Coordinating Contractor for purposes of preparing a complete set of composite electronic CAD coordination drawings that include all applicable trades, and for coordinating the activities related to this process. The Coordinating Contractor for this project shall be the Mechanical Contractor.
 - a. The Coordinating Contractor shall utilize personnel familiar with requirements of this project and skilled as draftspersons/CAD operators, competent to prepare the required coordination drawings.
3. Electronic CAD drawings shall be submitted to the Coordinating Contractor for addition of work by other trades. IMEG will provide electronic file copies of ventilation drawings for contractor's use if the contractor signs and returns an "Electronic File Transfer" waiver provided by IMEG. IMEG will not consider blatant reproductions of original file copies an acceptable alternative for coordination drawings.

C. Drawing Requirements:

1. The file format and file naming convention shall be coordinated with and agreed to by all contractors participating in the coordination process and the Owner.
 - a. Scale of drawings:
 - 1) General plans: 1/4 Inch = 1'-0" (minimum).
 - 2) Mechanical, electrical, communication rooms, and including the surrounding areas within 10 feet: 1/2 Inch = 1'-0" (minimum).
 - 3) Shafts and risers: 1/2 Inch = 1'-0" (minimum).
 - 4) Sections of shafts and mechanical and electrical equipment rooms: 1/4 Inch = 1'-0" (minimum).
 - 5) Sections of congested areas: 1/2 Inch = 1'-0" (minimum).
2. Ductwork layout drawings shall be the baseline system for other components. Ductwork layout drawings shall be modified to accommodate other components as the coordination process progresses.
3. There may be more drawings required for risers, top and bottom levels of mechanical rooms, and shafts.
4. The minimum quantity of drawings will be established at the first coordination meeting and sent to the A/E for review. Additional drawings may be required if other areas of congestion are discovered during the coordination process.

D. General:

1. Coordination drawing files shall be made available to the A/E and Owner's Representative. The A/E will only review identified conflicts and give an opinion, but will not perform as a coordinator.
2. A plotted set of coordination drawings shall be available at the project site.
3. Coordination drawings are not shop drawings and shall not be submitted as such.

4. The contract drawings are schematic in nature and do not show every fitting and appurtenance for each utility. Each contractor is expected to have included in the bid sufficient fittings, material, and labor to allow for adjustments in routing of utilities made necessary by the coordination process and to provide a complete and functional system.
5. The contractors will not be allowed additional costs or time extensions due to participation in the coordination process.
6. The contractors will not be allowed additional costs or time extensions for additional fittings, reroutings or changes of duct size, that are essentially equivalent sizes to those shown on the drawings and determined necessary through the coordination process.
7. The A/E reserves the right to determine space priority of equipment in the event of spatial conflicts or interference between equipment, piping, conduit, ducts, and equipment provided by the trades.
8. Changes to the contract documents that are necessary for systems installation and coordination shall be brought to the attention of the A/E.
9. Access panels shall preferably occur only in gypsum board walls or plaster ceilings where indicated on the drawings.
 - a. Access to mechanical, electrical, technology, and other items located above the ceiling shall be through accessible lay-in ceiling tile areas.
 - b. Potential layout changes shall be made to avoid additional access panels.
 - c. Additional access panels shall not be allowed without written approval from the A/E at the coordination drawing stage.
 - d. Providing additional access panels shall be considered after other alternatives are reviewed and discarded by the A/E and the Owner's Representative.
 - e. When additional access panels are required, they shall be provided without additional cost to the Owner.
10. Complete the coordination drawing process and obtain sign-off of the drawings by all contractors prior to installing any of the components.
11. Conflicts that result after the coordination drawings are signed off shall be the responsibility of the contractor or subcontractor who did not properly identify their work requirements, or installed their work without proper coordination.
12. Updated coordination drawings that reflect as-built conditions may be used as record documents.

1.7 QUALITY ASSURANCE

A. Contractor's Responsibility Prior to Submitting Pricing/Bid Data:

1. The Contractor is responsible for constructing complete and operating systems. The Contractor acknowledges and understands that the Contract Documents are a two-dimensional representation of a three-dimensional object, subject to human interpretation. This representation may include imperfect data, interpreted codes, utility guides, three-dimensional conflicts, and required field coordination items. Such deficiencies can be corrected when identified prior to ordering material and starting installation. The Contractor agrees to carefully study and compare the individual Contract Documents and report at once in writing to the Architect/Engineer any deficiencies the Contractor may discover. The Contractor further agrees to require each subcontractor to likewise study the documents and report at once any deficiencies discovered.

2. The Contractor shall resolve all reported deficiencies with the Architect/Engineer prior to awarding any subcontracts, ordering material, or starting any work with the Contractor's own employees. Any work performed prior to receipt of instructions from the Architect/Engineer will be done at the Contractor's risk.

B. Qualifications:

1. Only products of reputable manufacturers as determined by the Architect/Engineer are acceptable.
2. All Contractors and subcontractors shall employ only workmen who are skilled in their trades. At all times, the number of apprentices at the job site shall be less than or equal to the number of journeymen at the job site.

C. Compliance with Codes, Laws, Ordinances:

1. Conform to all requirements of the State of Colorado Codes, Laws, Ordinances and other regulations having jurisdiction.
2. Conform to all published standards of Poudre School District.
3. If there is a discrepancy between the codes and regulations and these specifications, the Architect/Engineer shall determine the method or equipment used.
4. If the Contractor notes, at the time of bidding, that any parts of the drawings or specifications do not comply with the codes or regulations, Contractor shall inform the Architect/Engineer in writing, requesting a clarification. If there is insufficient time for this procedure, Contractor shall submit with the proposal a separate price to make the system comply with the codes and regulations.
5. All changes to the system made after the letting of the contract to comply with codes or the requirements of the Inspector, shall be made by the Contractor without cost to the Owner.
6. If there is a discrepancy between manufacturer's recommendations and these specifications, the manufacturer's recommendations shall govern.
7. If there are no local codes having jurisdiction, the current issue of the National Electrical Code shall be followed.

D. Permits, Fees, Taxes, Inspections:

1. Procure all applicable permits and licenses.
2. Abide by all laws, regulations, ordinances, and other rules of the State or Political Subdivision where the work is done, or as required by any duly constituted public authority.
3. Pay all charges for permits or licenses.
4. Pay all fees and taxes imposed by State, Municipal, and other regulatory bodies.
5. Pay all charges arising out of required inspections by an authorized body.
6. Pay all charges arising out of required contract document reviews associated with the project and as initiated by the Owner or authorized agency/consultant.
7. Where applicable, all fixtures, equipment and materials shall be listed by Underwriter's Laboratories, Inc. or a nationally recognized testing organization.

E. Examination of Drawings:

1. The drawings for the electrical work are completely diagrammatic, intended to convey the scope of the work and to indicate the general arrangements and locations of equipment, outlets, etc., and the approximate sizes of equipment.
2. Contractor shall determine the exact locations of equipment and rough-ins, and the exact routing of raceways to best fit the layout of the job. Conduit entry points for electrical equipment including, but not limited to, panelboards, switchboards, switchgear and unit substations, shall be determined by the Contractor unless noted in the contract documents.
3. Scaling of the drawings will not be sufficient or accurate for determining these locations.
4. Where job conditions require reasonable changes in arrangements and locations, such changes shall be made by the Contractor at no additional cost to the Owner.
5. Because of the scale of the drawings, certain basic items, such as junction boxes, pull boxes, conduit fittings, etc., may not be shown, but where required by other sections of the specifications or required for proper installation of the work, such items shall be furnished and installed.
6. If an item is either shown on the drawings or called for in the specifications, it shall be included in this contract.
7. The Contractor shall determine quantities and quality of material and equipment required from the documents. Where discrepancies arise between drawings, schedules and/or specifications, the greater and better-quality number shall govern.
8. Where used in electrical documents the word "furnish" shall mean supply for use, the word "install" shall mean connect up complete and ready for operation, and the word "provide" shall mean to supply for use and connect up complete and ready for operation.
9. Any item listed as furnished shall also be installed unless otherwise noted.
10. Any item listed as installed shall also be furnished unless otherwise noted.

F. Electronic Media/Files:

1. Construction drawings for this project have been prepared utilizing Revit.
2. Contractors and Subcontractors may request electronic media files of the contract drawings and/or copies of the specifications. Specifications will be provided in PDF format.
3. Upon request for electronic media, the Contractor shall complete and return a signed "Electronic File Transmittal" form provided by IMEG.
4. If the information requested includes floor plans prepared by others, the Contractor will be responsible for obtaining approval from the appropriate Design Professional for use of that part of the document.
5. The electronic contract documents can be used for preparation of shop drawings and as-built drawings only. The information may not be used in whole or in part for any other project.
6. The drawings prepared by IMEG for bidding purposes may not be used directly for ductwork layout drawings or coordination drawings.
7. The use of these CAD documents by the Contractor does not relieve them from their responsibility for coordination of work with other trades and verification of space available for the installation.
8. The information is provided to expedite the project and assist the Contractor with no guarantee by IMEG as to the accuracy or correctness of the information provided. IMEG accepts no responsibility or liability for the Contractor's use of these documents.

G. Field Measurements:

1. Verify all pertinent dimensions at the job site before ordering any conduit, conductors, wireways, bus duct, fittings, etc.

1.8 SUBMITTALS

A. Submittals shall be required for the following items, and for additional items where required elsewhere in the specifications or on the drawings.

1. Submittals list:

Referenced Specification Section	Submittal Item	Coordination Drawing
26 05 13	Wire and Cable	
26 05 26	Grounding and Bonding	
26 05 33	Conduit and Boxes	+> 1.5"
26 05 53	Electrical Identification	
26 22 00	Dry Type Transformers	Yes
26 24 16	Panelboards	Yes
26 27 16	Cabinets and Enclosures	Yes
26 27 26	Wiring Devices	Ceiling mount
26 28 13	Fuses	
26 28 16	Disconnect Switches	Yes

B. General Submittal Procedures: In addition to the provisions of Division 1, the following are required:

1. Transmittal: Each transmittal shall include the following:

- a. Date
- b. Project title and number
- c. Contractor's name and address
- d. Division of work (e.g., electrical, plumbing, heating, ventilating, etc.)
- e. Description of items submitted and relevant specification number
- f. Notations of deviations from the contract documents
- g. Other pertinent data

2. Submittal Cover Sheet: Each submittal shall include a cover sheet containing:

- a. Date
- b. Project title and number
- c. Architect/Engineer
- d. Contractor and subcontractors' names and addresses
- e. Supplier and manufacturer's names and addresses
- f. Division of work (e.g., electrical, plumbing, heating, ventilating, etc.)
- g. Description of item submitted (using project nomenclature) and relevant specification number
- h. Notations of deviations from the contract documents

- i. Other pertinent data
 - j. Provide space for Contractor's review stamps
3. Composition:
 - a. Submittals shall be submitted using specification sections and the project nomenclature for each item.
 - b. Individual submittal packages shall be prepared for items in each specification section. All items within a single specification section shall be packaged together where possible. An individual submittal may contain items from multiple specifications sections if the items are intimately linked (e.g., pumps and motors).
 - c. All sets shall contain an index of the items enclosed with a general topic description on the cover.
4. Content: Submittals shall include all fabrication, erection, layout, and setting drawings; manufacturers' standard drawings; schedules; descriptive literature, catalogs and brochures; performance and test data; wiring and control diagrams; dimensions; shipping and operating weights; shipping splits; service clearances; and all other drawings and descriptive data of materials of construction as may be required to show that the materials, equipment or systems and the location thereof conform to the requirements of the contract documents.
5. Contractor's Approval Stamp:
 - a. The Contractor shall thoroughly review and approve all shop drawings before submitting them to the Architect/Engineer. The Contractor shall stamp, date and sign each submittal certifying it has been reviewed.
 - b. Unstamped submittals will be rejected.
 - c. The Contractor's review shall include, but not be limited to, verification of the following:
 - 1) Only approved manufacturers are used.
 - 2) Addenda items have been incorporated.
 - 3) Catalog numbers and options match those specified.
 - 4) Performance data matches that specified.
 - 5) Electrical characteristics and loads match those specified.
 - 6) Equipment connection locations, sizes, capacities, etc. have been coordinated with other affected trades.
 - 7) Dimensions and service clearances are suitable for the intended location.
 - 8) Equipment dimensions are coordinated with support steel, housekeeping pads, openings, etc.
 - 9) Constructability issues are resolved (e.g., weights and dimensions are suitable for getting the item into the building and into place, sinks fit into countertops, etc.).
 - d. The Contractor shall review, stamp and approve all subcontractors' submittals as described above.

- e. The Contractor's approval stamp is required on all submittals. Approval will indicate the Contractor's review of all material and a complete understanding of exactly what is to be furnished. Contractor shall clearly mark all deviations from the contract documents on all submittals. If deviations are not marked by the Contractor, then the item shall be required to meet all drawing and specification requirements.
6. Submittal Identification and Markings:
- a. The Contractor shall clearly mark each item with the same nomenclature applied on the drawings or in the specifications.
 - b. The Contractor shall clearly indicate the size, finish, material, etc.
 - c. Where more than one model is shown on a manufacturer's sheet, the Contractor shall clearly indicate exactly which item and which data is intended.
 - d. All marks and identifications on the submittals shall be unambiguous.
7. Schedule submittals to expedite the project. Coordinate submission of related items.
8. Identify variations from the contract documents and product or system limitations that may be detrimental to the successful performance of the completed work.
9. Reproduction of contract documents alone is not acceptable for submittals.
10. Incomplete submittals will be rejected without review. Partial submittals will only be reviewed with prior approval from the Architect/Engineer.
11. Submittals not required by the contract documents may be returned without review.
12. The Architect/Engineer's responsibility shall be to review one set of shop drawing submittals for each product. If the first submittal is incomplete or does not comply with the drawings and/or specifications, the Contractor shall be responsible to bear the cost for the Architect/Engineer to recheck and handle the additional shop drawing submittals.
13. Submittals shall be reviewed and approved by the Architect/Engineer before releasing any equipment for manufacture or shipment.
14. Contractor's responsibility for errors, omissions or deviation from the contract documents in submittals is not relieved by the Architect/Engineer's approval.
15. Schedule shall allow for adequate time to perform orderly and proper review of submittals, including time for consultants and Owner if required, and resubmittals by Contractor if necessary, and to cause no delay in Work or in activities of Owner or other contractors.
- a. Allow at least two weeks for Architect^{TMTM}s/Engineer's review and processing of each submittal, excluding mailing.
16. Architect/Engineer reserves the right to withhold action on a submittal which, in the Architect/Engineer^{TMTM}s opinion, requires coordination with other submittals until related submittals are received. The Architect/Engineer will notify the Contractor, in writing, when they exercise this right.
- C. Electronic Submittal Procedures:
1. Distribution: Email submittals as attachments to all parties designated by the Architect/Engineer, unless a web-based submittal program is used.
 2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.

3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.
4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. Submittal file name: 26 XX XX.description.YYYYMMDD
 - b. Transmittal file name: 26 XX XX.description.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.

D. Paper Copy Submittal Procedures:

1. Paper copies are acceptable where electronic copies are not provided.
2. The Contractor shall submit ten (10) paper copies of each shop drawing.
3. Each set shall be bound in a three-ring binder or presentation binder. Copies that are loose or in pocket folders are not acceptable.

1.9 SCHEDULE OF VALUES

A. The requirements herein are in addition to the provisions of Division 1.

B. Format:

1. Use AIA Document Continuation Sheets G703 or another similar form approved by the Owner and Architect/Engineer.
2. Submit in Excel format.
3. Support values given with substantiating data.

C. Preparation:

1. Itemize work required by each specification section and list all providers. All work provided by subcontractors and major suppliers shall be listed on the Schedule of Values. List each subcontractor and supplier by company name.
2. Break down all costs into:
 - a. Material: Delivered cost of product with taxes paid.
 - b. Labor: Labor cost, excluding overhead and profit.
3. Itemize the cost for each of the following:
 - a. Overhead and profit.
 - b. Bonds.
 - c. Insurance.
 - d. General Requirements: Itemize all requirements.

4. For each line item having an installed cost of more than \$5,000, break down costs to list major products or operations under each item. At a minimum, provide material and labor cost line items for the following:
 - a. Each piece of equipment requiring shop drawings. Use the equipment nomenclature (SB-1, PANEL P-1, etc.) on the Schedule of Values.
 - b. Each type of small unitary equipment (e.g., FDS, FCS, CS, etc.). Multiple units of the same type can be listed together provided quantities are also listed so unit costs can be determined.
 - c. Each conduit system (medium voltage, normal, emergency, low voltage systems, etc.). In addition, for larger projects breakdown the material and labor for each conduit system based on geography (building, floor, and/or wing).
 - d. Fire alarm broken down into material and labor for the following:
 - 1) Engineering
 - 2) Controllers, devices, sensors, etc.
 - 3) Conduit
 - 4) Wiring
 - 5) Programming
 - 6) Commissioning
 - e. Site utilities (5' beyond building)
 - f. Seismic design
 - g. Testing
 - h. Commissioning
 - i. Record drawings
 - j. Punchlist and closeout

D. Update Schedule of Values when:

1. Indicated by Architect/Engineer.
2. Change of subcontractor or supplier occurs.
3. Change of product or equipment occurs.

1.10 CHANGE ORDERS

- A. A detailed material and labor takeoff shall be prepared for each change order, along with labor rates and markup percentages. Change orders shall be broken down by sheet or associated individual line item indicated in the change associated narrative, whichever provides the most detailed breakdown. Change orders with inadequate breakdown will be rejected.
- B. Itemized pricing with unit cost shall be provided from all distributors and associated subcontractors.
- C. Change order work shall not proceed until authorized.

1.11 PRODUCT DELIVERY, STORAGE, HANDLING and MAINTENANCE

- A. Exercise care in transporting and handling to avoid damage to materials. Store materials on the site to prevent damage.

- B. Keep all materials clean, dry and free from damaging environments.
- C. Coordinate the installation of heavy and large equipment with the General Contractor and/or Owner. If the Electrical Contractor does not have prior documented experience in rigging and lifting similar equipment, he/she shall contract with a qualified lifting and rigging service that has similar documented experience. Follow all equipment lifting and support guidelines for handling and moving.
- D. Contractor is responsible for moving equipment into the building and/or site. Contractor shall review site prior to bid for path locations and any required building modifications to allow movement of equipment. Contractor shall coordinate the work with other trades.

1.12 NETWORK / INTERNET CONNECTED EQUIPMENT

- A. These specifications may require certain equipment or systems to have network, Internet and/or remote access capability ("Network Capability"). Any requirement for Network Capability shall be interpreted only as a functional capability and is not to be construed as authority to connect or enable any Network Capability. Network Capability may only be connected or enabled with the express written consent of the Owner.

1.13 WARRANTY

- A. Provide one-year warranty for all fixtures, equipment, materials, and workmanship.
- B. The warranty period for all work in this specification Division shall commence on the date of Substantial Completion or successful system performance whichever occurs later. The warranty may also commence if a whole or partial system or any separate piece of equipment or component is put into use for the benefit of any party other than the installing contractor with prior written authorization of the Owner. In this instance, the warranty period shall commence on the date when such whole system, partial system or separate piece of equipment or component is placed in operation and accepted in writing by the Owner.
- C. Warranty requirements extend to correction, without cost to the Owner, of all work found to be defective or nonconforming to the contract documents. The Contractor shall bear the cost of correcting all damage due to defects or nonconformance with contract documents excluding repairs required as a result of improper maintenance or operation, or of normal wear as determined by the Architect/Engineer.

1.14 INSURANCE

- A. This Contractor shall maintain insurance coverage as set forth in Division 1 of these specifications.

1.15 MATERIAL SUBSTITUTION

- A. Where several manufacturers' names are given, the manufacturer for which a catalog number is given is the basis for job design and establishes the quality.

- B. Equivalent equipment manufactured by the other listed manufacturers may be used. Contractor shall ensure that all items submitted by these other manufacturers meet all requirements of the drawings and specifications and fits in the allocated space. When using other listed manufacturers, the Contractor shall assume responsibility for any and all modifications necessary (including, but not limited to structural supports, electrical connections and rough-in, and regulatory agency approval, etc.) and coordinate such with other contractors. The Architect/Engineer shall make the final determination of whether a product is equivalent.
- C. Any material, article or equipment of other unnamed manufacturers which will adequately perform the services and duties imposed by the design and is of a quality equal to or better than the material, article or equipment identified by the drawings and specifications may be used if approval is secured in writing from the Architect/Engineer via addendum. The Contractor assumes all costs incurred as a result of using the offered material, article or equipment, on the Contractors part or on the part of other Contractors whose work is affected.
- D. Voluntary add or deduct prices for alternate materials may be listed on the bid form. These items will not be used in determining the low bidder. This Contractor assumes all costs incurred as a result of using the offered material or equipment on the Contractors part or on the part of other Contractors whose work is affected.
- E. All material substitutions requested after the final addendum must be listed as voluntary changes on the bid form.

PART 2 - PRODUCTS

2.1 GENERAL

- A. All items of material having a similar function (e.g., safety switches, panelboards, switchboards, contactors, motor starters, dry type transformers) shall be of the same manufacturer unless specifically stated otherwise on drawings or elsewhere in specifications.

PART 3 - EXECUTION

3.1 JOBSITE SAFETY

- A. Neither the professional activities of the Architect/Engineer, nor the presence of the Architect/Engineer or the employees and subconsultants at a construction site, shall relieve the Contractor and any other entity of their obligations, duties and responsibilities including, but not limited to, construction means, methods, sequence, techniques or procedures necessary for performing, superintending or coordinating all portions of the work of construction in accordance with the contract documents and any health or safety precautions required by any regulatory agencies. The Architect/Engineer and personnel have no authority to exercise any control over any construction contractor or other entity or their employees in connection with their work or any health or safety precautions. The Contractor is solely responsible for jobsite safety. The Architect/Engineer and the Architect/Engineer's consultants shall be indemnified and shall be made additional insureds under the Contractor's general liability insurance policy.

3.2 ARCHITECT/ENGINEER OBSERVATION OF WORK

- A. The contractor shall provide seven (7) calendar days' notice to the Architect/Engineer prior to:
 - 1. Placing fill over underground and underslab utilities.
 - 2. Covering exterior walls, interior partitions and chases.
 - 3. Installing hard or suspended ceilings and soffits.
- B. The Architect/Engineer will review the installation and provide a written report noting deficiencies requiring correction. The contractor's schedule shall account for these reviews and show them as line items in the approved schedule.
- C. Above-Ceiling Final Observation:
 - 1. All work above the ceilings must be complete prior to the Architect/Engineer's review. This includes, but is not limited to:
 - a. All junction boxes are closed and identified in accordance with Section 26 05 53 Electrical Identification.
 - b. Luminaires, including ceiling-mounted exit and emergency lights, are installed and operational.
 - c. Luminaire whips are supported above the ceiling.
 - d. Conduit identification is installed in accordance with Section 26 05 53 Electrical Identification.
 - e. Luminaires are suspended independently of the ceiling system when required by these contract documents.
 - f. All wall penetrations have been sealed.
 - 2. To prevent the Above-Ceiling Final Observation from occurring too early, the Contractor shall review the status of the work and certify, in writing, that the work is ready for the Above-Ceiling Final Observation.
 - 3. It is understood that if the Architect/Engineer finds the ceilings have been installed prior to this review and prior to seven days elapsing, the Architect/Engineer may not recommend further payments to the contractor until full access has been provided.

3.3 PROJECT CLOSEOUT

- A. The following paragraphs supplement the requirements of Division 1.
- B. Final Jobsite Observation:
 - 1. To prevent the Final Jobsite Observation from occurring too early, the Contractor shall review the completion status of the project and certify that the job is ready for the final jobsite observation.
 - 2. Attached to the end of this section is a typical list of items that represent the degree of job completeness expected prior to requesting a review. The Contractor shall sign the attached certification and return it to the Architect/Engineer so that the final observation can be scheduled.

3. It is understood that if the Architect/Engineer finds the job not ready for the final observation and additional trips and observations are required to bring the project to completion, the cost of the additional time and expenses incurred by the Architect/Engineer will be deducted from the Contractor's final payment.
4. Contractor shall notify Architect/Engineer 48 hours prior to installation of ceilings or lay-in ceiling tiles.

C. The following must be submitted before Architect/Engineer recommends final payment:

1. Operation and maintenance manuals with copies of approved shop drawings.
2. Record documents including marked-up drawings and specifications.
3. A report documenting the instructions given to the Owner's representatives complete with the number of hours spent in the instruction. The report shall bear the signature of an authorized agent of this Contractor and shall be signed by the Owner's representatives.
4. Provide spare parts, maintenance, and extra materials in quantities specified in individual specification sections. Deliver to project site and submit receipt to Architect/Engineer.
5. Inspection and testing report by the fire alarm system manufacturer.
6. Start-up reports on all equipment requiring a factory installation or start-up.

D. Circuit Directories:

1. Provide custom typed circuit directory for each branch circuit panelboard. Provide updated custom typed circuit directory for each existing branch circuit panelboard with new or revised circuits per the scope of work. Label shall include equipment name or final approved room name, room number, and load type for each circuit (examples: SUMP SP-1 or ROOM 101 RECEIPT). Revise directory to reflect circuit changes required to balance phase loads. Printed copies of the bid document panel schedules are not acceptable as circuit directories.

3.4 OPERATION AND MAINTENANCE MANUALS

A. General:

1. Provide an electronic copy of the O&M manuals as described below for Architect/Engineer's review and approval. The electronic copy shall be corrected as required to address the Architect/Engineer's comments. Once corrected, electronic copies and paper copies shall be distributed as directed by the Architect/Engineer.
2. Approved O&M manuals shall be completed and in the Owner's possession prior to Owner's acceptance and at least 10 days prior to instruction of operating personnel.

B. Electronic Submittal Procedures:

1. Distribution: Email the O&M manual as attachments to all parties designated by the Architect/Engineer.
2. Transmittals: Each submittal shall include an individual electronic letter of transmittal.
3. Format: Electronic submittals shall be in PDF format only. Scanned copies, in PDF format, of paper originals are acceptable. Submittals that are not legible will be rejected. Do not set any permission restrictions on files; protected, locked, or secured documents will be rejected.

4. File Names: Electronic submittal file names shall include the relevant specification section number followed by a description of the item submitted, as follows. Where possible, include the transmittal as the first page of the PDF instead of using multiple electronic files.
 - a. O&M file name: O&M.div26.contractor.YYYYMMDD
 - b. Transmittal file name: O&Mtransmittal.div26.contractor.YYYYMMDD
5. File Size: Files shall be transmitted via a pre-approved method. Larger files may require an alternative transfer method, which shall also be pre-approved.
6. Provide the Owner with an approved copy of the O&M manual on compact discs (CD), digital video discs (DVD), or flash drives with a permanently affixed label, printed with the title "Operation and Maintenance Instructions", title of the project and subject matter of disc/flash drive when multiple disc/flash drives are required.
7. All text shall be searchable.
8. Bookmarks shall be used, dividing information first by specification section, then systems, major equipment and finally individual items. All bookmark titles shall include the nomenclature used in the construction documents and shall be an active link to the first page of the section being referenced.

C. Operation and Maintenance Instructions shall include:

1. Title Page: Include title page with project title, Architect, Engineer, Contractor, all subcontractors, and major equipment suppliers, with addresses, telephone numbers, website addresses, email addresses and point of contacts. Website URLs and email addresses shall be active links in the electronic submittal.
2. Table of Contents: Include a table of contents describing specification section, systems, major equipment, and individual items.
3. Copies of all final approved shop drawings and submittals. Include Architect's/Engineer's shop drawing review comments. Insert the individual shop drawing directly after the Operation and Maintenance information for the item(s) in the review form.
4. Copies of all factory inspections and/or equipment startup reports.
5. Copies of warranties.
6. Schematic wiring diagrams of the equipment that have been updated for field conditions. Field wiring shall have label numbers to match drawings.
7. Dimensional drawings of equipment.
8. Detailed parts lists with lists of suppliers.
9. Operating procedures for each system.
10. Maintenance schedule and procedures. Include a chart listing maintenance requirements and frequency.
11. Repair procedures for major components.
12. Replacement parts and service material requirements for each system and the frequency of service required.
13. Instruction books, cards, and manuals furnished with the equipment.
14. Include record drawings of the one-line diagrams for each major system. The graphic for each piece of equipment shown on the one-line diagram shall be an active link to its associated Operation & Maintenance data.
15. Copies of all panel schedules in electronic Microsoft Excel spreadsheet (.xlsx) file. Each panelboard shall be a separate tab in the workbook.

3.5 INSTRUCTING THE OWNER'S REPRESENTATIVE

- A. Adequately instruct the Owner's designated representatives in the maintenance, care, and operation of the complete systems installed under this contract.
- B. Provide verbal and written instructions to the Owner's representatives by FACTORY PERSONNEL in the care, maintenance, and operation of the equipment and systems.
- C. Contractor shall make a DVD video recording of instructions to the Owner while explaining the system so additional personnel may view the instructions at a later date. The video recording shall be the property of the Owner.
- D. The Owner has the option to make a video recording of all instructions. Coordinate schedule of instructions to facilitate this recording.
- E. The instructions shall include:
 - 1. Maintenance of equipment.
 - 2. Start-up procedures for all major equipment.
 - 3. Description of emergency system operation.
- F. Notify the Architect/Engineer of the time and place for the verbal instructions to be given to the Owner's representative so a representative can be present if desired.
- G. Minimum hours of instruction time for each item and/or system shall be as indicated in each individual specification section.
- H. Operating Instructions:
 - 1. Contractor is responsible for all instructions to the Owner's representatives for the electrical and specialized systems.
 - 2. If the Contractor does not have staff that can adequately provide the required instructions, the Contractor shall include in the bid an adequate amount to reimburse the Owner for the Architect/Engineer to perform these services.

3.6 RECORD DOCUMENTS

- A. The following paragraphs supplement Division 1 requirements.
- B. Maintain at the job site a separate and complete set of electrical drawings and specifications with all changes made to the systems clearly and permanently marked in complete detail.
- C. Mark drawings and specifications to indicate approved substitutions; Change Orders, and actual equipment and materials used. All Change Orders, RFI responses, Clarifications and other supplemental instructions shall be marked on the documents. Record documents that merely reference the existence of the above items are not acceptable. Should this Contractor fail to complete Record Documents as required by this contract, this Contractor shall reimburse Architect/Engineer for all costs to develop record documents that comply with this requirement. Reimbursement shall be made at the Architect/Engineer's hourly rates in effect at the time of work.

- D. Record changes daily and keep the marked drawings available for the Architect/Engineer's examination at any normal work time.
- E. Upon completing the job, and before final payment is made, give the marked-up drawings to the Architect/Engineer.
- F. Record actual routing of conduits exceeding 2 inches.

3.7 PAINTING

- A. Paint all equipment that is marred or damaged prior to the Owner's acceptance. Paint and color shall match original equipment paint and shall be obtained from the equipment supplier if available. All equipment shall have a finished coat of paint applied unless specifically allowed to be provided with a prime coat only.
- B. Equipment in finished areas that will be painted to match the room decor will be painted by others. Should this Contractor install equipment in a finished area after the area has been painted, the Contractor shall have the equipment and all its supports, hangers, etc., painted to match the room decor. Painting shall be performed as described in project specifications.
- C. Equipment cabinets, casings, covers, metal jackets, etc., located in equipment rooms or concealed spaces, shall be furnished in standard finish, free from scratches, abrasions, chippings, etc.
- D. Equipment in occupied spaces, or if standard to the unit, shall have a baked primer with baked enamel finish coat free from scratches, abrasions, chipping, etc. If color option is specified or is standard to the unit, verify with the Architect the color preference before ordering.
- E. Paint all equipment in unfinished areas such as boiler room, mechanical spaces, and storage rooms. Equipment furnished with a suitable factory finish need not be painted; provided the factory applied finish is not marred or spattered. If so, equipment shall be refinished with the same paint as was factory applied.
- F. All electrical conduit and equipment, fittings, hangers, structural supports, etc., in unfinished areas, such as equipment and storage room area, shall be painted two (2) coats of oil paint of colors selected by the Architect.
- G. Do NOT paint electric conduits in crawl spaces, tunnels, or spaces above suspended ceilings except that where conduit is in a damp location give exposed threads at joints two coats of sealer after joint is made up.
- H. After surfaces have been thoroughly cleaned and are free of oil, dirt or other foreign matter, paint all raceway and equipment with the following:
 - 1. Bare Metal Surfaces - Apply one coat of metal primer suitable for the metal being painted. Finish with two coats of Alkyd base enamel paint.
 - 2. Plastic Surfaces - Paint plastic surfaces with two coats of semi-gloss acrylic latex paint.

3.8 ADJUST AND CLEAN

- A. Thoroughly clean all equipment and systems prior to the Owner's final acceptance of the project.
- B. Clean all foreign paint, grease, oil, dirt, labels, stickers, etc. from all equipment.
- C. Remove all rubbish, debris, etc., accumulated during construction from the premises.

3.9 SPECIAL REQUIREMENTS

- A. Coordinate the installation of all equipment, controls, devices, etc., with other trades to maintain clear access area for servicing.
- B. Install all equipment to maximize access to parts needing service or maintenance. Review the final location, placement, and orientation of equipment with the Owner's representative prior to setting equipment.
- C. Installation of equipment or devices without regard to coordination of access requirements and confirmation with the Owner's representative will result in removal and reinstallation of the equipment at the Contractor's expense.
- D. Raceway and Cable Routing Restrictions: Raceways and cable are restricted from being routed in the following locations, unless serving the space or permitted by the authority having jurisdiction.
 - 1. Elevator machine rooms and hoistways.
 - 2. Exit enclosures.
 - 3. Other areas restricted by code.
 - 4. Technology, data, server rooms.
 - 5. Fire pump and sprinkler rooms.
 - 6. Normal power in emergency power equipment rooms: Limited to feeders and branch circuits serving the emergency power equipment located in the room.
 - 7. Emergency power in normal power equipment rooms: Limited to feeders and branch circuits serving the normal power equipment located in the room.

3.10 SYSTEM STARTING AND ADJUSTING

- A. The electrical systems shall be complete and operating. System startup, testing, adjusting, and balancing to obtain satisfactory system performance is the responsibility of the Contractor. This includes all calibration and adjustment of electrical controls, balancing of loads, troubleshooting and verification of software, and final adjustments that may be needed.
- B. Complete all manufacturer-recommended startup procedures and checklists to verify proper equipment operation and does not pose a danger to personnel or property.
- C. All operating conditions and control sequences shall be tested during the start-up period. Testing all interlocks, safety shut-downs, controls, and alarms.

- D. The Contractor, subcontractors, and equipment suppliers shall have skilled technicians to ensure that all systems perform properly. If the Architect/Engineer is requested to visit the job site for trouble shooting, assisting in start-up, obtaining satisfactory equipment operation, resolving installation and/or workmanship problems, equipment substitution issues or unsatisfactory system performance, including call backs during the warranty period, through no fault of the design; the Contractor shall reimburse the Owner on a time and materials basis for services rendered at the Architect/Engineer's standard hourly rates in effect when the services are requested. The Contractor shall pay the Owner for services required that are product, installation or workmanship related. Payment is due within 30 days after services are rendered.

3.11 FIELD QUALITY CONTROL

A. General:

1. Conduct all tests required during and after construction. Submit test results in NETA format, or equivalent form, that shows the test equipment used, calibration date, tester's name, ambient test conditions, humidity, conductor length, and results corrected to 40°C.
2. Supply necessary instruments, meters, etc., for the tests. Supply competent technicians with training in the proper testing techniques.
3. All cables and wires shall be tested for shorts and grounds following installation and connection to devices. Replace shorted or grounded wires and cables.
4. Any wiring device, electrical apparatus or luminaire, if grounded or shorted on any integral "live" part, shall have all defective parts or materials replaced.
5. Test cable insulation of service and panel feeder conductors for proper insulation values. Tests shall include the cable, all splices, and all terminations. Each conductor shall be tested and shall test free of short circuits and grounds and have an insulation value not less than Electrical Code Standards. Take readings between conductors, and between conductors and ground.
6. If the results obtained in the tests are not satisfactory, make adjustments, replacements, and changes as needed. Then repeat the tests, and make additional tests, as the Architect/Engineer or authority having jurisdiction deems necessary.

B. Ground Resistance:

1. Conduct service ground resistance tests using an approved manufactured ground resistance meter. Submit to the Architect/Engineer a proposed test procedure including type of equipment to be used. (The conventional ohmmeter is not an acceptable device.)
2. Make ground resistance measurements during normal dry weather and not less than 48 hours after a rain. Ground resistance values shall be verified by the Architect/Engineer at the time the readings are taken.
3. If the ground resistance value obtained is more than the value set forth in Section 26 05 26, the following shall be done to obtain the value given:
 - a. Verify that all connections in the service ground system are secure.
 - b. Increase the depth to which ground rods are driven by adding section lengths to the rods and retest. If the resistance is still excessive increase the depth by adding an additional rod section and retest.
 - c. If the resistance is still excessive, furnish and install additional ground rods, spaced not less than 20 feet from other ground rods unless otherwise noted on plans, and connect into the ground electrode system. Retest.
 - d. Review results with the Architect/Engineer.

4. Before final payment is made to the Contractor submit a written report to the Architect/Engineer including the following:
 - a. Date of test.
 - b. Number of hours since the last rain.
 - c. Soil condition at the time of the test in the ground electrode location. That is: dry, wet, moist, sand, clay, etc.
 - d. Diagram of the test set-up showing distances between test equipment, ground electrode, auxiliary electrodes, etc.
 - e. Make, model, and calibration date of test equipment.
 - f. Tabulation of measurements taken and calculations made.

- C. Ground-Fault Equipment Performance Testing:
 1. Test: Perform ground-fault performance testing when system is installed. The test process shall use primary current injection per manufacturer instruction and procedures. Perform test for the following:
 - a. Service disconnects
 - b. Solid state molded case circuit breakers and solid-state insulated case circuit breakers equipped with ground fault protection.
 - c. Fusible switches with ground fault relay protection.
 - d. Outside branch circuits and feeders.
 - e. Code required.
 2. Report: Provide copy of test result report with Operation and Maintenance manuals. Provide report to Authority Having Jurisdiction when requested.

- D. Arc Energy Reduction Equipment Performance Testing:
 1. Test: Perform arc energy protection performance testing when system is installed. The test process shall use primary current injection or approved method per manufacturer instructions and procedures. Perform test for the following:
 - a. All arc energy reduction systems installed.
 2. Report: Provide copy of test result report with Operation and Maintenance manuals. Provide report to Authority Having Jurisdiction when requested.

- E. Other Equipment:
 1. Give other equipment furnished and installed by the Contractor all standard tests normally made to assure that the equipment is electrically sound, all connections properly made, phase rotation correct, fuses and thermal elements suitable for protection against overloads, voltage complies with equipment nameplate rating, and full load amperes are within equipment rating.

- F. If any test results are not satisfactory, make adjustments, replacements and changes as needed and repeat the tests and make additional tests as the Architect/Engineer or authority having jurisdiction deem necessary.

- G. Contractor shall thermographic study all electrical gear, switchboard, panelboards, etc. at the end of construction to identify any unusual conditions/heating within the equipment. Coordinate with Owner/Architect/Engineer to have an Owner/Architect/Engineer representative present during testing.
- H. Report shall include color printouts, in binder, of pictures taken to use as a baseline reading after building is occupied.
- I. Upon completion of the project, the Contractor shall provide amperage readings for all panelboards and switchboards and turn the results over to the Owner for "benchmark" amperages.

READINESS CERTIFICATION PRIOR TO FINAL JOBSITE OBSERVATION

To prevent the final job observation from occurring too early, we require that the Contractor review the completion status of the project and, by copy of this document, certify that the job is indeed ready for the final job observation. The following is a typical list of items that represent the degree of job completeness expected prior to your requesting a final job observation.

1. Penetrations of fire-rated construction fire sealed in accordance with specifications.
2. Electrical panels have typed circuit identification.
3. Smoke and fire/smoke dampers are wired and have been tested.
4. Per Section 26 05 00, cable insulation test results have been submitted.
5. 6. Per Section 26 05 00, ground resistance test results have been submitted.
7. Operation and Maintenance manuals have been submitted as per Section 26 05 00.
8. Bound copies of approved shop drawings have been submitted as per Section 26 05 00.
9. Report of instruction of Owner's representative has been submitted as per Section 26 05 00.
- 10.
11. Start-up reports from factory representative have been submitted as per Section 26 05 00.

Accepted by:

Prime Contractor _____

By _____ Date _____

Upon Contractor certification that the project is complete and ready for a final job observation, we require the Contractor to sign this agreement and return it to the Architect/Engineer so that the final observation can be scheduled.

It is understood that if the Architect/Engineer finds the job not ready for the final observation and that additional trips and observations are required to bring the project to completion, the costs incurred by the Architect/Engineers for additional time and expenses will be deducted from the Contractor's contract retainage prior to final payment at the completion of the job.

END OF SECTION 26 05 00

SECTION 26 05 03 - THROUGH PENETRATION FIRESTOPPING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Through-Penetration Firestopping.

1.2 QUALITY ASSURANCE

- A. Manufacturer: Company specializing in manufacturing products specified in this Section.
- B. Installer: Individuals performing work shall be certified by the manufacturer of the system selected for installation.

1.3 REFERENCES

- A. UL 263 - Fire Tests of Building Construction and Materials
- B. UL 723 - Surface Burning Characteristics of Building Materials
- C. ANSI/UL 1479 - Fire Tests of Through Penetration Firestops
- D. UL 2079 - Tests for Fire Resistance of Building Joint Systems
- E. UL Fire Resistance Directory Through Penetration Firestop Systems (XHEZ)
- F. Intertek / Warnock Hersey - Directory of Listed Products
- G. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials
- H. ASTM E814 - Standard Test Method for Fire Tests of Through-Penetration Firestops
- I. The Building Officials and Code Administrators National Building Code
- J. 1997 Uniform Building Code
- K. 2015 International Building Code
- L. NFPA 5000 - Building Construction Safety Code

1.4 SUBMITTALS

- A. Submit under provisions of Division 1.
- B. Submit Firestopping Installers Certification for all installers on the project.
- C. Shop Drawings: Submit for each condition requiring firestopping. Include descriptions of the specific penetrating item, actual wall/floor construction, manufacturer's installation instructions, and UL or Interek / Warnock Hersey Assembly number.

- D. Through-Penetration Firestop System Schedule: Indicate locations of each through-penetration firestop system, along with the following information:
 - 1. Types of penetrating items.
 - 2. Types of constructions penetrated, including fire-resistance ratings and, where applicable, thicknesses of construction penetrated.
 - 3. Through-penetration firestop systems for each location identified by firestop design designation of qualified testing and inspecting agency.
 - 4. F ratings for each firestop system.
- E. Maintain a notebook on the job site at all times that contains copies of approved submittals for all through penetration firestopping to be installed. Notebook shall be made available to the Authority Having Jurisdiction at their request and turned over to the Owner at the end of construction as part of the O&M Manuals.
- F. Submit VOC rating of firestopping material in g/L (less water) with documentation that it meets the limits set forth in SCAQMD Rule 1168.

1.5 DELIVERY, STORAGE, AND HANDLING

- A. Store, protect and handle products on site. Accept material on site in factory containers and packing. Inspect for damage. Protect from deterioration or damage due to moisture, temperature changes, contaminants, or other causes. Follow manufacturer's instructions for storage.
- B. Install material prior to expiration of product shelf life.

1.6 PERFORMANCE REQUIREMENTS

- A. General: For penetrations through the following fire-resistance-rated constructions, including both empty openings and openings containing penetrating items, provide through-penetration firestop systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of construction penetrated.
 - 1. Fire-resistance-rated walls including fire partitions, fire barriers, and smoke barriers.
 - 2. Fire-resistance-rated horizontal assemblies including floors, floor/ceiling assemblies, and ceiling membranes of roof/ceiling assemblies.
- B. For through-penetration firestop systems exposed to light, traffic, moisture, or physical damage, provide products that, after curing, do not deteriorate when exposed to these conditions both during and after construction.
- C. For through-penetration firestop systems exposed to view, provide products with flame-spread and smoke-developed indexes of less than 25 and 450, respectively, as determined per ASTM E 84.
- D. For through-penetration firestop systems in air plenums, provide products with flame-spread and smoke-developed indexes of less than 25 and 50, respectively, as determined per ASTM E 84.

1.7 MEETINGS

- A. Pre-installation meeting: A pre-installation meeting shall be scheduled and shall include the Construction Manager, General Contractor, all Subcontractors associated with the installation of systems penetrating fire barriers, Firestopping Manufacturer's Representative, and the Owner.
 - 1. Review foreseeable methods related to firestopping work.
 - 2. Tour representative areas where firestopping is to be installed; inspect and discuss each type of condition and each type of substrate that will be encountered, and preparation to be performed by other trades.

1.8 WARRANTY

- A. Provide one year warranty on parts and labor.
- B. Warranty shall cover repair or replacement of firestop systems which fail in joint adhesion, cohesion, abrasion resistance, weather resistance, extrusion resistance, migration resistance, stain resistance, general durability, or appear to deteriorate in any manner not clearly specified by the manufacturer as an inherent quality of the material.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Products: Subject to compliance with requirements, provide one of the through-penetration firestop systems indicated for each application that are produced by one of the following manufacturers. All firestopping systems installed shall be provided by a single manufacturer.
 - 1. 3M; Fire Protection Products Division
 - 2. Hilti, Inc.
 - 3. RectorSeal Corporation, Metacaulk
 - 4. Tremco; Sealant/Weatherproofing Division
 - 5. Johns-Manville
 - 6. Specified Technologies Inc. (S.T.I.)
 - 7. Spec Seal Firestop Products
 - 8. AD Firebarrier Protection Systems
 - 9. Wiremold/Legrand: FlameStopper
 - 10. Dow Corning Corp
 - 11. Fire Trak Corp
 - 12. International Protective Coating Corp

2.2 THROUGH PENETRATION FIRESTOP SYSTEMS

- A. Provide materials and systems classified by or listed by Intertek / Warnock Hersey to provide firestopping equal to time rating of construction being penetrated.
- B. All firestopping materials shall be free of asbestos, lead, PCB's, and other materials that would require hazardous waste removal.

- C. Firestopping shall be flexible to allow for normal penetrating item movement due to expansion and contraction.
- D. Provide firestopping systems capable of supporting floor loads where systems are exposed to possible floor loading or traffic.
- E. Provide firestopping systems allowing continuous insulation for all insulated pipes.
- F. Provide firestopping systems classified by UL or listed by Intertek / Warnock Hersey for penetrations through all fire rated construction. Firestopping systems shall be selected from the UL or listed by Intertek / Warnock Hersey Fire Resistance Directory Category XHEZ based on substrate construction and penetrating item size and material and shall fall within the range of numbers listed:
 - 1. Combustible Framed Floors and Chase Walls - 1 or 2 Hour Rated:
 - a. F Rating = Floor/Wall Rating
 - b. L Rating = Penetrations in Smoke Barriers

Penetrating Item	UL System No.
No Penetrating Item	FC 0000-0999*
Metallic Pipe or Conduit	FC 1000-1999
Non-Metallic Pipe or Conduit	FC 2000-2999
Electrical Cables	FC 3000-3999
Cable Trays	FC 4000-4999
Insulated Pipes	FC 5000-5999
Bus Duct and Misc. Electrical	FC 6000-6999
Duct without Damper and Misc. Mechanical	FC 7000-7999
Multiple Penetrations	FC 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

- 2. Non-Combustible Framed Walls - 1 or 2 Hour Rated:
 - a. F Rating = Wall Rating
 - b. L Rating = Penetrations in Smoke Barriers

Penetrating Item	UL System No.
No Penetrating Item	WL 0000-0999*
Metallic Pipe or Conduit	WL 1000-1999
Non-Metallic Pipe or Conduit	WL 2000-2999
Electrical Cables	WL 3000-3999
Cable Trays	WL 4000-4999
Insulated Pipes	WL 5000-5999
Bus Duct and Misc. Electrical	WL 6000-6999
Duct without Damper and Misc. Mechanical	WL 7000-7999
Multiple Penetrations	WL 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

- 3. Concrete or Masonry Floors and Walls - 1 or 2 Hour Rated:
 - a. F Rating = Wall/Floor Rating
 - b. L Rating = Penetrations in Smoke Barriers

<u>Penetrating Item</u>	<u>UL System No.</u>
No Penetrating Item	CAJ 0000-0999*
Metallic Pipe or Conduit	CAJ 1000-1999
Non-Metallic Pipe or Conduit	CAJ 2000-2999
Electrical Cables	CAJ 3000-3999
Cable Trays	CAJ 4000-4999
Insulated Pipes	CAJ 5000-5999
Bus Duct and Misc. Electrical	CAJ 6000-6999
Duct without Damper and Misc. Mechanical	CAJ 7000-7999
Multiple Penetrations	CAJ 8000-8999

*Alternate method of firestopping is patching opening to match original rated construction.

- G. Any opening in walls or floors not covered by the listed series of numbers shall be coordinated with the firestopping manufacturer.
- H. Any openings in floors or walls not described in the UL or listed by Intertek / Warnock Hersey Fire Resistance Directory, or outlined in manufacturer's information shall be sealed in a manner agreed upon by the Firestopping Manufacturer, Owner, and the Authority Having Jurisdiction.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Ensure all surfaces that contact seal materials are free of dirt, dust, grease, oil, rust, or loose materials. Clean and repair surfaces as required. Remove laitance and form-release agents from concrete.
- B. Ensure substrate and penetrating items have been permanently installed prior to installing firestopping systems. Ensure penetrating items have been properly spaced and have proper clearance prior to installing firestopping systems.
- C. Surfaces to which sealing materials are to be installed must meet the selected UL or Intertek / Warnock Hersey system substrate criteria.
- D. Prime substrates where recommended in writing by through-penetration firestop system manufacturer. Confine primer to area of bond.

3.2 INSTALLATION

- A. In existing construction, provide firestopping of openings prior to and after installation of penetrating items. Remove any existing coatings on surfaces prior to firestopping installation. Temporary firestopping shall consist of packing openings with fire resistant mineral wool for the full thickness of substrate, or an alternate method approved by the Authority Having Jurisdiction. All openings shall be temporarily firestopped immediately upon their installation and shall remain so until the permanent UL or listed by Intertek / Warnock Hersey listed firestopping system is installed.
- B. Install penetration seal materials in accordance with printed instructions of the UL or Intertek / Warnock Hersey Fire Resistance Directory and with the manufacturer's printed application instructions.
- C. Install dams as required to properly contain firestopping materials within openings and as required to achieve required fire resistance rating. Remove combustible damming after appropriate curing.

3.3 CLEANING AND PROTECTING

- A. Clean excess fill materials adjacent to openings as Work progresses by methods and with cleaning materials that are approved in writing by through-penetration firestop system manufacturers and that do not cause damage.
- B. Provide final protection and maintain conditions during and after installation that ensure that through-penetration firestop systems are without damage or deterioration at time of Substantial Completion. If, despite such protection, damage or deterioration occurs, remove damaged or deteriorated through-penetration firestop systems immediately and install new materials to produce systems complying with specified requirements.

3.4 IDENTIFICATION

- A. Provide and install labels adjacent to each firestopping location. Label shall be provided by the firestop system supplier and contain the following information in a contrasting color:
 - 1. The words "Warning - Through Penetration Firestop System - Do Not Disturb. Notify Building Management of Any Damage."
 - 2. Firestop System Supplier; UL or listed by Intertek / Warnock Hersey system number; date installed; contractor name and phone number; manufacturer's representative name, address, and phone number.

3.5 INSPECTION

- A. All penetrations shall be inspected by the manufacturer's representative to ensure proper installation.
- B. Access to firestop systems shall be maintained for examination by the Authority Having Jurisdiction at their request.
- C. Proceed with enclosing through-penetration firestop system with other construction only after inspection reports are issued and firestop installations comply with requirements.

- D. The contractor shall allow for visual destructive review of 5% of installed firestop systems (minimum of one) to prove compliance with specifications and manufacturer's instructions and details. Destructive system removal shall be performed by the contractor and witnessed by the Architect/Engineer and manufacturer's factory representative. The Architect/Engineer shall have sole discretion of which firestop system installations will be reviewed. The contractor is responsible for all costs associated with this requirement including labor and material for removing and replacing the installed firestop system. If any firestop system is found to not be installed per manufacturer's specific instructions and details, all firestop systems are subject to destructive review and replacement at the Architect/Engineer's discretion and the contractor's expense.

END OF SECTION 26 05 03

SECTION 26 05 05 - ELECTRICAL DEMOLITION FOR REMODELING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Electrical demolition

PART 2 - PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- A. Materials and equipment for patching and extending work shall be as specified in individual Sections.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. THE DRAWINGS ARE INTENDED TO INDICATE THE SCOPE OF WORK REQUIRED AND DO NOT INDICATE EVERY BOX, CONDUIT, OR WIRE THAT MUST BE REMOVED. THE CONTRACTOR SHALL VISIT THE SITE PRIOR TO SUBMITTING A BID AND VERIFY EXISTING CONDITIONS.
- B. Where walls, ceilings, structures, etc., are indicated as being removed on general or electrical drawings, the Contractor shall be responsible for the removal of all electrical equipment, devices, fixtures, raceways, wiring, systems, etc., from the removed area.
- C. Where ceilings, walls, structures, etc., are temporarily removed and replaced by others, this Contractor shall be responsible for the removal, storage, and replacement of equipment, devices, fixtures, raceways, wiring, systems, etc.
- D. Where mechanical or technology equipment is indicated as being removed on electrical, mechanical, or technology drawings, the Contractor shall be responsible for disconnecting the equipment and removing all starters, VFD, controllers, electrical equipment, raceways, wiring, etc. associated with the device.
- E. Verify that abandoned wiring and equipment serve only abandoned equipment or facilities. Extend conduit and wire to facilities and equipment that will remain in operation following demolition. Extension of conduit and wire to equipment shall be compatible with the surrounding area. Extended conduit and conductors to match existing size and material.
- F. Coordinate scope of work with all other Contractors and the Owner at the project site. Schedule removal of equipment and electrical service to avoid conflicts.
- G. Bid submittal shall mean the Contractor has visited the project site and has verified existing conditions and scope of work.

3.2 PREPARATION

- A. The Contractor shall obtain approval from the Owner before turning off power to circuits, feeders, panels, etc. Coordinate all outages with Owner.
- B. Coordinate utility service outages with Utility Company.
- C. Provide temporary wiring and connections to maintain existing systems in service during construction. When work must be performed on energized equipment or circuits, use personnel experienced in such operations. Assume all equipment and systems must remain operational unless specifically noted otherwise on drawings.
- D. Disconnect electrical systems in walls, floors, structures, and ceilings scheduled for removal.
- E. Existing insert System: Maintain existing system in service until new system is complete and ready for service. Disable system only to make switchovers and connections. Obtain permission from the Owner at least 48 hours before partially or completely disabling system. Minimize outage duration. Make temporary connections to maintain service in areas adjacent to work area. System downtime shall occur on an overtime basis.

3.3 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Demolish and extend existing electrical work under provisions of Division 1 of Specifications and this Section.
- B. Remove, relocate, and extend existing installations to accommodate new construction.
- C. Remove abandoned wiring and raceway to source of supply. Existing conduit in good condition may be reused in place by including an equipment ground conductor in reused conduit. Reused conduit and boxes shall have supports revised to meet current codes. Relocating conduit shall not be allowed.
- D. Remove exposed abandoned raceway, including abandoned raceway above accessible ceiling finishes. Cut raceway flush with walls and floors, and patch surfaces. Remove all associated clamps, hangers, supports, etc. associated with raceway removal.
- E. Disconnect and remove outlets and devices that are to be demolished. Remove conduit, supports, and conductors back to source. Devices' back box and conduit mounted in walls that are to remain can be abandoned in place. Provide appropriate cover plate for all abandoned back boxes. Cover plates shall match existing plates used in the adjacent areas.
- F. Disconnect and remove electrical devices and equipment serving utilization equipment that has been removed.
- G. Repair adjacent construction and finishes damaged during demolition and extension work. Patch openings to match existing surrounding finishes.
- H. Maintain access to existing electrical installations that remain active. Modify installation or provide junction boxes and access panel as appropriate.

- I. Extend existing installations using materials and methods compatible with existing electrical installations, or as specified. Extended conduit and conductors to match existing size and material.
- J. Regulatory Requirements: Comply with governing EPA notification regulations before beginning demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- K. Floor slab is post-tensioned. All penetrations shall be x-rayed prior to cutting and/or drilling to avoid any tension cables or utilities encased in floor construction.
- L. Floor slabs may contain conduit systems. This Contractor is responsible for taking any measures required to ensure no conduits or other services are damaged. This includes x-ray or similar non-destructive means. Where conduit is in concrete slab, cut conduit flush with floor, pull out conductors, and plug conduit ends.
- M. This Contractor is responsible for all costs incurred in repair, relocations, or replacement of any cables, conduits, or other services if damaged without proper investigation.

3.4 CLEANING AND REPAIR

- A. Clean and repair existing materials and equipment that remain or are to be reused.
- B. Panelboards: Clean exposed surfaces and check tightness of electrical connections. Replace damaged circuit breakers and provide closure plates for vacant positions. Provide typed circuit directory showing revised circuiting arrangement.

3.5 INSTALLATION

- A. Install relocated materials and equipment under the provisions of Division 1 of Specifications.

END OF SECTION 26 05 05

SECTION 26 05 13 - WIRE AND CABLE

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Building wire
- B. Cabling for remote control, signal, and power limited circuits
- C. Fire rated and circuit integrity (CI) cable and assemblies
- D. Armored cable (AC)
- E. Nonmetallic-sheathed cable (NM)

1.2 RELATED WORK

- A. Section 26 05 53 - Electrical Identification: Refer to electrical identification for color and identification labeling requirements.

1.3 REFERENCES

- A. ASTM B800-05 - Standard Specification for 8000 Series Aluminum Alloy Wire Electrical Purposes-Annealed and Intermediate Tempered.
- B. ASTM B801-07 - Standard Specification for Concentric-Lay-Stranded Conductors of 8000 Series Aluminum Alloy for Subsequent Covering or Insulation
- C. NEMA WC 70 - Power Cables Rated 2,000V or Less for the Distribution of Electrical Energy
- D. NFPA 70 - National Electrical Code (NEC)
- E. UL 44 - Thermoset-Insulated Wires and Cables
- F. UL 83 - Thermoplastic-Insulated Wires and Cables
- G. UL 854 - Service-Entrance Cables
- H. UL 1581 - Standard for Electrical Wires, Cables, and Flexible Cords
- I. UL 2196 - Fire Resistive, Fire Resistant and Circuit Integrity Cables

1.4 SUBMITTALS

- A. Submit shop drawings and product data under the provisions of Section 26 05 00.
- B. Submit manufacturer's installation instructions.

PART 2 - PRODUCTS

2.1 BUILDING WIRE

- A. Feeders and Branch Circuits 8 AWG and larger: Copper, stranded conductor, 600-volt insulation, THHN/THWN or XHHW-2.
- B. Feeders and Branch Circuits 8 AWG and larger in Underground Conduit: Copper, stranded conductor, 600-volt insulation, THWN or XHHW-2.
- C. Feeders and Branch Circuits 10 AWG and Smaller: Copper, solid or stranded conductor, 600-volt insulation, THHN/THWN, unless otherwise noted on the drawings.
- D. Motor Feeder from Variable Frequency Drives: Copper conductor, 600-volt XHHW-2 insulation, stranded conductor, unless otherwise noted on the drawings. Three conductor stranded copper, 600-volt XHHW-2 insulation, with copper ground and overall helical copper tape shield. Shield shall be terminated at both ends of cable with an approved termination.
- E. Control Circuits: Copper, stranded conductor 600-volt insulation, THHN/THWN.
- F. Each 120 and 277-volt branch circuit shall have a dedicated neutral conductor. Neutral conductors shall be considered current-carrying conductors for wire derating.

2.2 CABLING FOR REMOTE CONTROL, SIGNAL, AND POWER LIMITED CIRCUITS

- A. Wire for the following specialized systems shall be as designated on the drawings, or elsewhere in these specifications. If not designated on the drawings or specifications, the system manufacturer's recommendations shall be followed.
 - 1. Fire alarm
- B. Control Cable for Class 1 Remote Control and Signal Circuits: Copper conductor, 600-volt insulation, rated 60°C, individual conductors twisted together, shielded, and covered with a PVC jacket.
- C. Control Cable for Class 2 or Class 3 Remote Control and Signal Circuits: Copper conductor, 300-volt insulation, rated 60°C, individual conductors twisted together, shielded, and covered with a PVC jacket; UL listed.
- D. Plenum Cable for Class 2 or Class 3 Remote Control and Signal Circuits: Copper conductor, 300-volt insulation, rated 60°C, individual conductors twisted together, shielded, and covered with a nonmetallic jacket; UL listed for use in air handling ducts, hollow spaces used as ducts, and plenums.

2.3 FIRE-RATED AND CIRCUIT INTEGRITY (CI) CABLE AND ASSEMBLIES

- A. Properties and requirements of fire rated cables and assemblies:
 - 1. 2HR fire rated for horizontal and vertical installations.

B. Acceptable fire-rated cables and listed assemblies:

1. Feeder assembly located outside the structure (example: below finished grade), rated metal stud and drywall enclosure, or encased in concrete; minimum 2 inches of concrete).
2. Exothermal Mat Material: Raceway / Cable protected with exothermic mat material, UL listed.
 - a. Install per manufacturer guidelines and requirements. Apply appropriate quantity of wrapped layers of material as required to achieve rating.
 - b. Contractor shall upsize cable / wiring / raceway sizes as required for derating.
 - c. Provide cable / wire ampacity derating calculations for each application, reference manufacturer for additional information, document and submit derated calculations as a shop drawing submittal for approval prior to installation. Minimum cable / wire derating shall be:
 - 1) Individual conduit raceways (less than or equal to 4" trade size): 10%.
 - 2) Parallel conduit raceways associated with the same feeder and protected by a common installation assembly: 15%.
 - 3) Cable tray raceway: 50%.
 - d. Manufacturer:
 - 1) 3M Interam Endothermic Mat
 - 2) Or submitted for engineer review prior to bid.
3. Mineral Insulated Cables: Copper conductor, 600-volt insulation, rated 90°C, Type MI.
 - a. Manufacturer:
 - 1) Raychem Pyrotenax MI
4. Fire rated cable in EMT or IMC raceway: Copper conductor, 300-volt or ethernet power-limited circuit cables low smoke zero halogen (LSZH), rated 105°C. Assembly including raceway shall be UL listed 2196 and UL circuit integrity (FHIT).
 - a. Manufacturers:
 - 1) VITALINK CI/CIC or ethernet series
 - 2) Draka RHW-2 EMT Series
5. Fire rated cable in phenolic RTRC conduit: Copper conductor, 600-volt RHW-2 or RW90 low smoke zero halogen (LSZH) insulation, rated 90°C. Assembly shall be UL listed 2196 and UL circuit integrity (FHIT).
 - a. Manufacturer:
 - 1) Draka Lifeline RHW-2

2.4 ARMORED CABLE (AC)

- A. Conductors shall be copper, 600-volt insulation, THHN. Armored cable shall be constructed in strict accordance with Underwriters Laboratories, Inc. Standard for Armored Cables, UL 4, and include flexible metallic interlocked armor.
- B. Minimum conductor size for branch circuit wiring shall be 12 AWG, with larger wires used where specified.
- C. Armored cable shall NOT be used for circuits serving the Essential Electrical System.

2.5 NONMETALLIC-SHEATHED CABLE

- A. Nonmetallic-Sheathed Cable, Size 14 through 4 AWG:
 - 1. Copper conductor, 600-volt insulation, rated 90°C, Type NM. Nonmetallic-sheathed cable shall be constructed in strict accordance with Underwriters Laboratories, Inc. Standard for Nonmetallic-sheathed Cables, UL 719.
 - 2. An equipment grounding conductor shall be provided with circuit conductors in all cables. Size per Electrical Code.
 - 3. Nonmetallic-sheathed cables may be used for branch circuit wiring as defined in the Electrical Code. Nonmetallic-sheathed cables shall not be used for other circuits.
- B. Underground Feeder and Branch Circuit Cable: Copper conductor, 600-volt insulation, rated 60°C, Type UF.
- C. Service Entrance Cable: Copper conductor, 600-volt insulation, XHHW, Type USE.

PART 3 - EXECUTION

3.1 WIRE AND CABLE INSTALLATION SCHEDULE

- A. Above Accessible Ceilings:
 - 1. Building wire shall be installed in raceway.
 - 2. Metal clad cable, Type MC, 1/2" size with minimum #12 conductors and ground, shall be allowed for flexible whips to individual luminaires on non-essential circuits. The flexible whips shall be between 18" to 72" in length per Electrical Code.
- B. All Other Locations: Building wire in raceway.
- C. Above Grade: All conductors installed above grade shall be type "THHN".
- D. Underground or In Slab: All conductors shall be type "THWN".
- E. Low Voltage Cable (less than 100 volts): Low voltage cables in ducts, plenums, and other air handling spaces shall be plenum listed. Low voltage cables in non-accessible areas shall be installed in conduit. Low voltage cable may be installed without conduit in accessible areas using the following types of cable supports. Cable support types/systems shall comply with the warranty requirements of the low voltage cable manufacturer.

1. J-hooks
2. Bridle rings with saddle supports

- F. Low Voltage Cable (less than 100 volts): Low voltage cable shall be installed in raceway.
- G. Fire-Rated 2-Hour Feeders and Circuit Requiring Continuous Operation (CI): Refer to Part 2 of this section for acceptable products and assemblies. Installation shall meet UL 2196.

3.2 CONTRACTOR CHANGES

- A. The basis of design is copper conductors installed in raceway based on ambient temperature of 30°C, NEC Table 310.16 (2011 - 2017 edition 310.15(B)(16)). Service entrance conductors are based on copper conductor installed in underground electrical ducts, NEC Table B.2(7) (2011 - 2017 edition Table B310.15(B)(2)(7); 2008 or later edition B.301.7) or calculated in accordance with Annex B Application Information for Ampacity Calculation..
- B. The Contractor shall be responsible for derating and sizing conductors and conduits to equal or exceed the ampacity of the basis of design circuits, if he/she chooses to use methods or materials other than the basis of design.
- C. Record drawing shall include the calculations and sketches.

3.3 GENERAL WIRING METHODS

- A. Use no wire smaller than 12 AWG for power and lighting circuits, and no smaller than 14 AWG for control wiring.
- B. Use no wire smaller than 18 AWG for low voltage control wiring below 100 volts.
- C. Use 10 AWG conductor for 20 ampere, 120-volt branch circuit home runs longer than 75 feet, and for 20 ampere, 277-volt branch circuit home runs longer than 200 feet.
- D. Use no wire smaller than 8 AWG for outdoor lighting circuits.
- E. The ampacity of multiple conductors in one conduit shall be derated per the Electrical Code. In no case shall more than 4 conductors be installed in one conduit to such loads as motors larger than 1/4 HP, panelboards, motor control centers, etc.
- F. Where installing parallel feeders, place an equal number of conductors for each phase of a circuit in same raceway or cable.
- G. Splice only in junction or outlet boxes.
- H. Neatly train and lace wiring inside boxes, equipment, and panelboards.
- I. Make conductor lengths for parallel circuits equal.
- J. All conductors shall be continuous in conduit from last outlet to their termination.
- K. Terminate all spare conductors on terminal blocks, and label the spare conductors.

- L. Cables or wires shall not be laid out on the ground before pulling.
- M. Cables or wires shall not be dragged over earth or paving.
- N. Care shall be taken so as not to subject the cable or wire to high mechanical stresses that would cause damage to the wire and cable.
- O. At least six (6)-inch loops or ends shall be left at each outlet for installation connection of luminaires or other devices.
- P. All wires in outlet boxes not connected to fixtures or other devices shall be rolled up, spliced if continuity of circuit is required, and insulated.

3.4 WIRING INSTALLATION IN RACEWAYS

- A. Pull all conductors into a raceway at the same time. Use UL listed wire pulling lubricant for pulling 4 AWG and larger wires. Do not use wire pulling lubricant for isolated (ungrounded) power system wiring.
- B. Install wire in raceway after interior of building has been physically protected from the weather and all mechanical work likely to injure conductors has been completed.
- C. Pulling shall be continuous without unnecessary stops and starts with wire or cable only partially through raceway.
- D. Where reels of cable or wire are used, they shall be set up on jacks close to the point where the wire or cable enters the conduit or duct so that the cable or wire may be unreeled and run into the conduit or duct with a minimum of change in the direction of the bend.
- E. Conductors shall not be pulled through conduits until plastering or masonry work is completed and conduits are free from moisture. Care shall be taken so that long pulls of wire or pulls around several bends are not made where the wire may be permanently stretched and the insulation damaged.
- F. Only nylon rope shall be permitted to pull cables into conduit and ducts.
- G. Completely and thoroughly swab raceway system before installing conductors.
- H. Conductor Supports in Vertical Raceways:
 - 1. Support conductors in vertical raceways in accordance with the Electrical Code Spacing of Conductors Supports.
 - 2. Supports shall be of insulated wedge type (OZ Gedney Type S, or equal) and installed in a tapered insulated bushing fitting or a metal woven mesh with a support ring that fits inside conduit fitting installed in an accessible junction box (Hubbell Kellems support grip or equal).

3.5 CABLE INSTALLATION

- A. Provide protection for exposed cables where subject to damage.

- B. Use suitable cable fittings and connectors.
- C. Run all open cable parallel or perpendicular to walls, ceilings, and exposed structural members. Follow the routing as illustrated on the drawings as closely as possible. Cable routing on drawings scaled 1/4"=1'-0" or less shall be considered diagrammatical, unless noted otherwise. The correct routing, when shown diagrammatically, shall be chosen by the Contractor based on information in the contract documents; in accordance with the manufacturer's written instructions, applicable codes, the NECA's "Standard of Installation", recognized industry standards; and coordinated with other contractors.
- D. Open cable shall be supported by the appropriate size J-hooks or other means if called for on the drawings. Wire and cable from different systems shall not be installed in the same J-hook. J-hooks shall be sized with 20% spare capacity. J-hooks shall provide proper bend radius support for data cable and fiber cables.
- E. Open cable installed above suspended ceilings shall not rest on the suspended ceiling construction, nor utilize the ceiling support system for wire and cable support.
- F. J-hook support spans shall be based on the smaller of the manufacturer's load ratings and code requirements. In no case shall horizontal spans exceed 5 feet and vertical spans exceed 4 feet. All J-hooks shall be installed where completely accessible and not blocked by piping, ductwork, inaccessible ceilings, etc. J-hooks shall be independently rigidly attached to a structural element. J-hooks shall be installed to provide 2" horizontal separation and 6" vertical separation between systems.
- G. Open cable shall only be installed where specifically shown on the drawings, or permitted in these specifications.

3.6 FIRE-RATED CABLE AND ASSEMBLY INSTRUCTIONS

- A. Terminations of the fire-rated cable must be outside of the fire zone.
- B. Fire-rated cable shall be installed according to the manufacturer's instructions, recommendations, and UL listing.
- C. Route fire-rated cable and assemblies separate from other feeders and distribution. Install cable and assemblies in locations protected from physical damage.
- D. Refer to Electrical Identification Section 26 05 53 for specific identification requirements.

3.7 WIRING CONNECTIONS AND TERMINATIONS

- A. Splice and tap only in accessible junction boxes.
- B. Use solderless, tin-plated copper, compression terminals (lugs) applied with circumferential crimp for conductor terminations, 8 AWG and larger.
- C. Use solderless, tin-plated, compression terminals (lugs) applied with indenter crimp for copper conductor terminations, 10 AWG and smaller.

- D. Use solderless pressure connectors with insulating covers for copper wire splices and taps, 8 AWG and smaller. For 10 AWG and smaller, use insulated spring wire connectors with plastic caps.
- E. Use compression connectors applied with circumferential crimp for conductor splices and taps, 6 AWG and larger. Tape uninsulated conductors and connectors with electrical tape to 150 percent of the insulation value of conductor. Cold shrink connector insulator with 1kV rating shall be used in damp and wet locations.
- F. Thoroughly clean wires before installing lugs and connectors.
- G. Make splices, taps and terminations to carry full ampacity of conductors without perceptible temperature rise.
- H. Phase Sequence: All apparatus shall be connected to operate in the phase sequence A-B-C representing the time sequence in which the phase conductors so identified reach positive maximum voltage.
- I. As a general rule, applicable to switches, circuit breakers, starters, panelboards, switchgear and the like, the connections to phase conductors are intended thus:
 - 1. Facing the front and operating side of the equipment, the phase identification shall be:
 - a. Left to Right - A-B-C
 - b. Top to Bottom - A-B-C
- J. Connection revisions as required to achieve correct rotation of motors shall be made at the load terminals of the starters or disconnect switches.
- K. Use antioxidant joint compound on all aluminum conductor terminations. Apply antioxidant joint compound per manufacturer's recommendations.

3.8 FIELD QUALITY CONTROL

- A. Field inspection and testing will be performed under provisions of Division 1.
- B. Building Wire and Power Cable Testing: Perform an insulation-resistance test on each conductor with respect to ground and adjacent conductors. Test shall be made by means of a low-resistance ohmmeter, such as a "Megger". The applied potential shall be 500 volts dc for 300 volt rated cable and 1000 volts dc for 600 volt rated cable. The test duration shall be one minute. Insulation resistance must be greater than 100 mega-ohm for 600 volt and 25 mega-ohm for 300 volt rated cables per NETA Acceptance Testing Standard. Verify uniform resistance of parallel conductors.
- C. MI cable shall have the insulation resistance of each cable tested with a 500-volt dc megohmmeter prior to energizing the cables. Tabulate resistance values and submit to Architect/Engineer for acceptance.
- D. Inspect wire and cable for physical damage and proper connection.
- E. Torque test conductor connections and terminations to manufacturer's recommended values.

- F. Perform continuity test on all power and equipment branch circuit conductors. Verify proper phasing connections.
- G. copper and aluminum conductors, the date the lugs were torqued, and installed torque readings. Documentation indicating that the torque wrench has been calibrated not more than 30 days prior to tightening of lugs shall be provided.
- H. Protection of wire and cable from foreign materials:
 - 1. It is the Contractor's responsibility to provide adequate physical protection to prevent foreign material application or contact with any wire or cable type. Foreign material is defined as any material that would negatively impact the validity of the manufacturer's performance warranty. This includes, but is not limited to, overspray of paint (accidental or otherwise), drywall compound, or any other surface chemical, liquid, or compound that could come in contact with the cable, cable jacket, or cable termination components.
- I. Overspray of paint on any wire or cable will not be accepted. It shall be the Contractor's responsibility to replace any component containing overspray, in its entirety, at no additional cost to the project. Cleaning of the cables with harsh chemicals is not allowed.

END OF SECTION 26 05 13

SECTION 26 05 26 - GROUNDING AND BONDING

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Equipment grounding system
- B. Bonding system
- C. Grounding electrode system

1.2 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Testing agency as defined by OSHA in 29 CFR 1910.7 or a member company of the International Electrical Testing Association and that is acceptable to authorities having jurisdiction.
- B. Testing Agency's Field Supervisor: Person currently certified by the International Electrical Testing Association to supervise on-site testing specified in Part 3.
- C. Electrical Components, Devices, and Accessories: Listed and labeled as defined in Electrical Code, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- D. Comply with UL 467 Grounding and Bonding Equipment.
- E. Comply with NFPA 780 and UL 96 when interconnecting with lightning protection system.
- F. Comply with Electrical Code; for overhead-line construction and medium-voltage underground construction, comply with IEEE/ANSI C2 National Electrical Safety Code (NESC).

1.3 REFERENCES

- A. NFPA 70 - National Electrical Code (NEC)
- B. CEC California Electrical Code

1.4 SUMMARY

- A. This section includes grounding of electrical systems and equipment. Grounding requirements specified in this Section may be supplemented by special requirements of systems described in other Sections.

PART 2 - PRODUCTS

2.1 GROUNDING CONDUCTORS

- A. For insulated conductors, comply with Division 26 Section 26 05 13 "Wire and Cable".

- B. Material: Copper.
- C. Equipment Grounding Conductors: Insulated. Refer to Section 26 05 53 for insulation color.
- D. Grounding Electrode Conductors: Stranded cable.
- E. Underground Conductors: Bare, tinned, stranded, unless otherwise indicated.
- F. Copper Bonding Conductors: As follows:
 - 1. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG copper conductor, 1/4 inch in diameter.
 - 2. Bonding Conductor: No. 4 or No. 6 AWG, stranded copper conductor.
 - 3. Bonding Jumper: Bare copper tape, braided bare copper conductors, terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.
 - 4. Tinned Bonding Jumper: Tinned-copper tape, braided copper conductors, terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.

2.2 CONNECTOR PRODUCTS

- A. Comply with UL 467; listed for use for specific types, sizes, and combinations of conductors and connected items.
- B. Connectors: Hydraulic compression type, in kit form, and selected per manufacturer's written instructions.
- C. Bolted Connectors: Bolted-pressure-type connectors.
- D. Substation connectors shall comply with IEEE 837 listed for use for specific types, sizes, and combinations of conductors and connected items.

PART 3 - EXECUTION

3.1 CONNECTIONS

- A. General: Make connections so galvanic action or electrolysis possibility is minimized. Select connectors, connection hardware, conductors, and connection methods so metals in direct contact will be galvanically compatible.
 - 1. Use electroplated or hot-tin-coated materials to ensure high conductivity and to make contact points closer to order of galvanic series.
 - 2. Make connections with clean, bare metal at points of contact.
 - 3. Make aluminum-to-steel connections with stainless-steel separators and mechanical clamps.
 - 4. Make aluminum-to-galvanized steel connections with tin-plated copper jumpers and mechanical clamps.
 - 5. Coat and seal connections having dissimilar metals with inert material to prevent future penetration of moisture to contact surfaces.

- B. Exothermic-Welded Connections: Comply with manufacturer's written instructions. Welds that are puffed up or that show convex surfaces indicating improper cleaning are not acceptable.
- C. Compression-Type Connections: Use hydraulic compression tools to provide correct circumferential pressure for compression connectors. Use tools and dies recommended by connector manufacturer. Provide embossing die code or other standard method to make a visible indication that a connector has been adequately compressed on grounding conductor.
- D. Equipment Grounding Conductor Terminations: For No. 8 AWG and larger, use pressure-type grounding lugs. No. 10 AWG and smaller grounding conductors may be terminated with winged pressure-type connectors.
- E. Noncontact Metal Raceway Terminations: If metallic raceways terminate at metal housings without mechanical and electrical connection to housing, terminate each conduit with a grounding bushing. Connect grounding bushings with a bare grounding conductor to grounding bus or terminal in housing. Bond electrically non-continuous conduits at entrances and exits with grounding bushings and bare grounding conductors, unless otherwise indicated.
- F. Structural Steel Connection: Exothermic-welded connections to structural steel. Coordinate with structure to provide physical protection.
- G. Connections at Test Wells: Use compression-type connectors on conductors and make two bolted- and clamped-type connections between conductors and ground rods.
- H. Connections at back boxes, junction boxes, pull boxes, and equipment terminations: The equipment grounding conductor(s) associated with all circuits in the box shall be connected together and to the box using a suitable grounding screw. The removal of the respective receptacle, luminaire, or other device served by the box shall not interrupt the grounding continuity. The connection to the non-metallic boxes shall be made to any metallic fitting or device requiring grounding.
- I. Tighten screws and bolts for grounding and bonding connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B.
- J. Moisture Protection: If insulated grounding conductors are connected to ground rods or grounding buses, insulate entire area of connection and seal against moisture penetration of insulation and cable.

3.2 INSTALLATION

- A. Use only copper conductors for both insulated and bare grounding conductors in direct contact with earth, concrete, masonry, crushed stone, and similar materials.
- B. Grounding Conductors: Route along shortest and straightest paths possible, unless otherwise indicated. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage. Each grounding conductor that passes through a below grade wall must be provided with a waterstop.
- C. Grounding electrode conductor (GEC) shall be protected from physical damage by rigid polyvinyl chloride conduit (PVC) in exposed locations.

- D. Bonding Straps and Jumpers: Install so vibration by equipment mounted on vibration isolation hangers and supports is not transmitted to rigidly mounted equipment. Use exothermic-welded connectors for outdoor locations, unless a disconnect-type connection is required; then use a bolted clamp. Bond straps directly to the basic structure, taking care not to penetrate any adjacent parts. Install straps only in locations accessible for maintenance.
- E. In raceways, use insulated equipment grounding conductors.

3.3 EQUIPMENT GROUNDING SYSTEM

- A. Comply with Electrical Code, for types, sizes, and quantities of equipment grounding conductors, unless specific types, larger sizes, or more conductors than required by Electrical Code are indicated.
- B. Install equipment grounding conductors in all feeders and circuits. Terminate each end on a grounding lug or bus.
- C. Install insulated equipment grounding conductor with circuit conductors for the following items, in addition to those required by Electrical Code:
 - 1. Lighting and receptacle circuits. Terminate each end on a grounding lug or bus.
 - 2. Single-phase and three-phase motor and appliance branch circuits.
 - 3. Flexible raceway runs, including FMC and LFMC.
 - 4. Armored and metal-clad cable runs.
- D. Busway Supply Circuits: Install insulated equipment grounding conductor from the grounding bus in the switchgear, switchboard, or distribution panel to equipment grounding bar terminal on busway.
- E. Computer Outlet Circuits: Install insulated equipment grounding conductor in branch-circuit runs from computer-area power panels or power-distribution units.
- F. X-Ray Equipment Circuits: Install insulated equipment grounding conductor in circuits supplying x-ray equipment.
- G. Isolated Grounding Circuits: Install an insulated equipment grounding conductor connected to the receptacle or equipment grounding terminal. Isolate grounding conductor from raceway and from panelboard grounding terminals. Terminate at isolated equipment grounding conductor terminal of the applicable derived system or service, unless otherwise indicated.
- H. Nonmetallic Raceways: Install an equipment grounding conductor in nonmetallic raceways unless they are designated for telephone or data cables.

3.4 BONDING SYSTEM

- A. At building expansion joints, provide flexible bonding jumpers to connect to columns or beams on each side of the expansion joint.

- B. Isolated Equipment Enclosure: For designated equipment supplied by a branch circuit or feeder, isolate equipment enclosure from supply raceway with a nonmetallic raceway fitting listed for the purpose. Install fitting where raceway enters enclosure, and install a separate equipment bonding conductor.
- C. Exterior Metallic Pull and Junction Box Covers, Metallic Hand Rails: Bond to grounding system using flexible grounding conductors.
- D. Equipment Circuits: Install a bonding conductor to duct-mounted electrical devices operating at 120 V and more, including air cleaners, dampers, and heaters. Bond conductor to each unit and to air duct. Bond interior metal piping systems and metal air ducts to equipment grounding conductors of associated pumps, fans, blowers, electric heaters, and air cleaners. Use braided-type bonding straps or copper conductor sized equal to the equipment grounding conductor.
- E. Bond metal ducts of dust collectors, particulate conveying, fume hoods, and other hazardous materials to the equipment grounding conductors of associated pumps, fans, or blowers. Use braided-type bonding straps. Provide braided bare copper bonding conductor in nonmetallic dust collector ductwork to each equipment inlet location, and bond to equipment.
- F. Water Heater, Heat-Tracing, Metal Well Casing, and Heating Cables: Install a separate equipment grounding conductor to each electric water heater, heat-tracing, and anti-frost heating cable. Bond conductor to heater units, piping, well casing, connected equipment, and components.
- G. Connect bonding conductors to metal water pipe using a suitable ground clamp. Make connections to flanged piping at street side of flange. Provide bonding jumper around water meter.
- H. Signal and Communication Systems: For telephone, alarm, voice and data, and other communication systems, provide No. 6 AWG minimum insulated bonding conductor in raceway from grounding electrode system to each service location, terminal cabinet, wiring closet, and central equipment location. Leave 10 feet of slack conductor at terminal board.
- I. Telecom Service and Central Equipment Locations and Wiring Closets: Terminate grounding conductor on a 1/4-by-2-by-12-inch grounding bar.
- J. Terminal Cabinets: Terminate bonding conductor on cabinet grounding terminal.
- K. Remote control, signaling, and fire alarm circuits shall be bonded in accordance with the most recent version of the National Electric Code.
- L. Metal Poles Supporting Outdoor Lighting Fixtures > 15 feet: Provide a grounding electrode in addition to installing a separate equipment grounding conductor with supply branch-circuit conductors.
- M. Common Ground Bonding with Lightning Protection System: Bond electrical power system ground directly to lightning protection system grounding conductor at closest point to electrical service grounding electrode. Use bonding conductor sized same as system grounding electrode conductor, and install in conduit.

- N. Medical Gas Piping: Bond to pipe with grounding clamp connectors. Bonding conductor shall be a #6 AWG minimum and may be connected to panelboard ground bar serving the area.

3.5 FIELD QUALITY CONTROL

- A. Inspect grounding and bonding system conductors and connections for tightness and proper installation.
 - 1. Measure ground resistance from system neutral connection at service entrance to convenient ground reference points using suitable ground testing equipment. Resistance shall not exceed 5 ohms.
 - 2. Testing: Owner will engage a qualified testing agency to perform the following field quality-control testing:
 - 3. Testing: Engage a qualified testing agency to perform the following field quality-control testing:
 - 4. Testing: Perform the following field quality-control testing:
 - a. After installing grounding system but before permanent electrical circuitry has been energized, test for compliance with requirements.
 - b. Test completed grounding system at each location where a maximum ground-resistance level is specified, at service disconnect enclosure grounding terminal, and at ground test wells. Measure ground resistance not less than two full days after the last trace of precipitation, and without the soil being moistened by any means other than natural drainage or seepage and without chemical treatment or other artificial means of reducing natural ground resistance. Perform tests, by the fall-of-potential method according to IEEE 81.
 - c. Provide drawings locating each ground rod and ground rod assembly and other grounding electrodes, identify each by letter in alphabetical order, and key to the record of tests and observations. Include the number of rods driven and their depth at each location and include observations of weather and other phenomena that may affect test results. Describe measures taken to improve test results.
 - 1) Equipment Rated 500 kVA and Less: 10 ohms.
 - 2) Equipment Rated 500 to 1000 kVA: 5 ohms.
 - 3) Equipment Rated More Than 1000 kVA: 3 ohms.
 - 4) Substations and Pad-Mounted Switching Equipment: 5 ohms.
 - 5) Manhole Grounds: 10 ohms.
 - d. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect/Engineer promptly and include recommendations to reduce ground resistance.

END OF SECTION 26 05 26

SECTION 26 05 27 - SUPPORTING DEVICES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Conduit and equipment supports
- B. Fastening hardware
- C. Concrete housekeeping pads

1.2 QUALITY ASSURANCE

- A. Support systems shall be adequate for weight of equipment and conduit, including wiring, which they carry.

1.3 COORDINATION

- A. Coordinate size, shape and location of concrete pads with section on Cast-in-Place Concrete or Concrete Topping.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Allied Support Systems
- B. Cooper B-Line
- C. Erico, Inc.
- D. Hilti
- E. Power Fasteners
- F. Orbit Industries

2.2 MATERIAL

- A. Support Channel: Hot-dip galvanized; painted steel for interior/dry locations. All field cut ends shall be touched up with matching finish to inhibit rusting.
- B. Hardware: Corrosion resistant.
- C. Anchorage and Structural Attachment Components:
 - 1. Strength: Defined in reports by ICBO Evaluation Service or another agency acceptable to Authorities Having Jurisdiction.

- a. Structural Safety Factor: Strength in tension and shear of components used shall be at least two times the maximum seismic forces to which they will be subjected.
2. Through Bolts: Structural type, hex head, high strength. Comply with ASTM A 325.
3. Welding Lugs: Comply with MSS-SP-69, Type 57.
4. Beam clamps for Steel Beams and Joists: Double sided or concentric open web joist hangers. Single-sided type is not acceptable.
5. Bushings for Floor-Mounted Equipment Anchors: Neoprene units designed for seismically rated rigid equipment mountings, and matched to the type and size of anchor bolts and studs used.
6. Bushing Assemblies for Wall-Mounted Equipment Anchorage: Assemblies of neoprene elements and steel sleeves designed for seismically rated rigid equipment mountings, and matched to the type and size of attachment devices used.
7. Concrete Anchors: Fasten to concrete using cast-in or post-installed anchors designed per the requirements of Appendix D of ACI 318-05. Post-installed anchors shall be qualified for use in cracked concrete by ACI-355.2.
8. Masonry Anchors: Fasten to concrete masonry units with expansion anchors or self-tapping masonry screws. For expansion anchors into hollow concrete block, use sleeve-type anchors designed for the specific application. Do not fasten in masonry joints. Do not use powder actuated fasteners, wooden plugs, or plastic inserts.

D. Conduit Sleeves and Lintels:

1. Each Contractor shall provide, to the General Contractor for installation, lintels for all openings required for the Contractor's work in masonry walls and conduit sleeves for floors, unless specifically shown as being by others.
2. Refer to Structural General Notes for lintel requirements in masonry construction.
3. Refer to Structural plans and specifications for lintel requirements and sizes.
4. Lintels:
 - a. Lintels in non-bearing masonry wall openings can be sized in accordance with the note below. Lintels that occur in existing bearing walls are to be sized according to similar conditions and spans in the new construction and lintel schedule. Bottom plate size shall be a minimum of 3/8" thick. The width of the plate shall be 3/4" less than the field verified wall thickness. The plate shall be the full length of the lintel member. Lintels are not required over openings that are 12" wide or less and at least 1 course below the top of the wall.
 - b. All lintels shall have a minimum of 8" end bearing.
 - c. All lintels in exterior wall construction shall be hot-dip galvanized.
 - d. For all openings not otherwise detailed or scheduled, minimum lintels shall be for each 4 inch of masonry width:
 - 1) 0 to 2'-0" span: 5/16" plate (3/4" less than wall width)
 - 2) 2'-0" to 4'-0" span: L 3 1/2 x 3 1/2 x 1/4
 - 3) 4'-0" to 6'-0" span: L4 x 3 1/2 x 5/16 (llv)
 - 4) 6'-0" to 8'-0" span: L5 x 3 1/2 x 5/16 (llv)
 - e. All angles that are back to back shall be welded top and bottom 3" at 12" minimum.

5. Fabricate all lintels from structural steel shapes or as indicated on the drawings. All lintels and grouped wall openings shall be approved by the Architect or Structural Engineer.
6. Fabricate all sleeves from standard weight black steel pipe. Provide continuous sleeve. Cut or split sleeves are not acceptable. Sleeves through concrete walls may be high density polyethylene pipe penetration sleeve with a water stop collar, suitable for use with Link-Seal mechanical seals. Century-Line Model CS.
7. Sleeves through the floors on exposed risers shall be flush with the ceiling, with planed squared ends extending 1" above the floor in unfinished areas, and flush with the floor in finished areas, to accept spring closing floor plates.
8. Sleeves shall not penetrate structural members without approval from the Structural Engineer.
9. Openings through unexcavated floors and/or foundation walls below the floor shall have a smooth finish with sufficient annular space around material passing through opening so slight settling will not place stress on the material or building structure.
10. Install all sleeves concentric with conduits. Secure sleeves in concrete to wood forms. This Contractor is responsible for sleeves dislodged or moved when pouring concrete.
11. Where conduits rise through concrete floors that are on earthen grade, provide 3/4" resilient expansion joint material (asphalt and cork) wrapped around the pipe, the full depth of concrete, at the point of penetration. Secure to prevent shifting during concrete placement and finishing.
12. Size sleeves large enough to allow expansion and contraction movement.

E. Concrete Housekeeping Pads:

1. Concrete bases for all floor mounted equipment and wall mounted equipment which is surface mounted and extends to within 6" of the finished floor, unless shown otherwise on the drawings, shall be 3-1/2" thick concrete.
2. Bases shall extend 3" on all sides of the equipment (6" larger than factory base).
3. Where the base is less than 12" from a wall, the base shall be carried to the wall to prevent a "dirt-trap".
4. Concrete materials and workmanship required for the Contractor's work shall be provided by the Contractor. Materials and workmanship shall conform to the applicable standards of the Portland Cement Association. Reinforce with 6" x 6", W1.4-W1.4 welded wire fabric. Concrete shall withstand 3,000 pounds compression per square inch at twenty-eight days.
5. Additional equipment requiring bases is as follows:
 - a. SPECIFIER: Delete if not applicable. See Evaluations..

F. Rooftop Support System:

1. Provide pre-fabricated roof supports for all conduit and equipment installed above the roof. Support all conduit and equipment a minimum of 4" above roof.
2. Support system shall be compatible with single ply, bituminous, metal, and spray foam roof systems. The base shall be rounded to prevent damage to the roof, and drainage holes shall prevent ponding of water in the support.
3. All metal components shall be hot dipped galvanized. Mounting hardware shall be stainless steel or hot dipped galvanized. Support shall be UV, corrosion, and freeze/thaw resistant. Support shall include orange paint, reflective safety orange accents, or similar markings for increased visibility.

4. Products:
 - a. Anvil International HBS-Base Series
 - b. Cooper B-Line Dura-Blok
 - c. Erico Caddy Pyramid 50, 150, 300, or 600 (to match load).

- G. Truss and Joist Support System: Provided the installation complies with all loading requirements of truss and joist manufacturers, the following practices are acceptable:
 1. Loads of 100 lbs. or less may be attached anywhere along the top or bottom chords of trusses or joists with a minimum 3' spacing between loads.
 2. Loads greater than 100 lbs. must be hung concentrically and may be hung from top or bottom chord, provided one of the following conditions is met:
 - a. The hanger is attached within 6" from a web/chord joint.
 - b. Additional L2x2x1/4 web reinforcement is installed per manufacturer's requirements.
 3. It is prohibited to cantilever a load using an angle or other structural component that is attached to a truss or joist in such a fashion that a torsional force is applied to that structural member.
 4. If conditions cannot be met, coordinate installation with truss or joist manufacturer and contact Architect/Engineer.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Fasten hanger rods, conduit clamps, and outlet and junction boxes to building structure using expansion anchors in concrete and beam clamps on structural steel.
- B. Trapeze support installation: Cut hanger rods back at trapeze supports so they do not extend more than 3/4" below bottom face of lowest fastener and blunt any sharp edges.
- C. Use toggle bolts or hollow wall fasteners in hollow masonry, plaster, or gypsum board partitions and walls; expansion anchors or preset inserts in solid masonry walls; self-drilling anchors or expansion anchor on concrete surfaces; sheet metal screws in sheet metal studs; and wood screws in wood construction.
- D. Do not fasten supports to ceiling systems, piping, ductwork, mechanical equipment, or conduit, unless otherwise noted.
- E. Do not use powder-actuated anchors without specific permission.
- F. Do not drill structural steel members.
- G. Fabricate supports from structural steel or steel channel, rigidly welded or bolted to present a neat appearance. Use hexagon head bolts with spring lock washers under all nuts.

- H. In wet locations and on all building floors below exterior earth grade install free-standing electrical equipment on concrete pads.
- I. Install cabinets and panelboards with minimum of four anchors. Provide horizontal backing/support framing in stud walls for rigid mounting. Provide steel channel supports to stand surface-mounted panelboard or cabinet one inch off wall.
- J. Bridge studs top and bottom with channels to support flush-mounted cabinets and panelboards in stud walls.
- K. Do not exceed 25 lbs. per hanger and a minimum spacing of 2'-0" on center when attaching to metal roof decking (excludes concrete on metal deck). This 25 lbs. load and 2'-0" spacing include adjacent electrical and mechanical items hanging from deck. If the hanger restrictions cannot be achieved, supplemental framing off steel framing will need to be added.
- L. Refer to Section 26 05 33 for special conduit supporting requirements.

3.2 FINISH

- A. Prime coat exposed steel hangers and supports. Hangers and supports in crawl spaces, pipe shafts, and above suspended ceiling spaces are not considered exposed.
- B. Trim all ends of exposed field fabricated steel hangers, slotted channel and threaded rod to within 1" of support or fastener to eliminate potential injury to personnel unless shown otherwise on the drawings. Smooth ends and install elastomeric insulation with two coats of latex paint if exposed steel is within 6'-6" of finish floor and presents potential injury to personnel.

END OF SECTION 26 05 27

SECTION 26 05 33 - CONDUIT AND BOXES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Rigid metallic conduit and fittings (RMC)
- B. Stainless steel conduit (316SS) and fittings
- C. Intermediate metallic conduit and fittings (IMC)
- D. Electrical metallic tubing and fittings (EMT)
- E. Flexible metallic conduit and fittings (FMC)
- F. Liquidtight flexible metallic conduit and fittings (LFMC)
- G. Rigid polyvinyl chloride conduit and fittings (PVC)
- H. High density polyethylene conduit and fittings (HDPE)
- I. Reinforced thermosetting resin conduit (RTRC)
- J. Phenolic reinforced thermosetting resin conduit (Phenolic RTRC)
- K. Wall and ceiling outlet boxes
- L. Electrical connection
- M. Pull and junction boxes
- N. Rough-ins
- O. Handholes
- P. Accessories

1.2 RELATED WORK

- A. Section 26 05 53 - Electrical Identification: Refer to electrical identification for color and identification labeling requirements.

1.3 REFERENCES

- A. American National Standards Institute (ANSI):
 - 1. ANSI C80.1 - Rigid Steel Conduit, Zinc-Coated
 - 2. ANSI C80.3 - Electrical Metallic Tubing, Zinc-Coated and Fittings
 - 3. ANSI C80.4 - Fittings for Rigid Metal Conduit and Electrical Metallic Tubing
 - 4. ANSI C80.6 - Intermediate Metal Conduit, Zinc Coated

5. ANSI/NEMA OS 1 - Sheet-Steel Outlet Boxes, Device Boxes, Covers and Box Supports
 6. ANSI/NEMA OS 2 - Nonmetallic Outlet Boxes, Device Boxes, Covers and Box Supports
- B. Federal Specifications (FS):
1. A-A-50553A - Fittings for Conduit, Metal, Rigid, (Thick-Wall and Thin-Wall (EMT) Type
 2. A-A-55810 - Specification for Flexible Metal Conduit
- C. NECA "Standards of Installation"
- D. National Electrical Manufacturers Association (NEMA):
1. ANSI/NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing and Cable
 2. RN 1 - Polyvinyl chloride (PVC) Externally Coated Galvanized Rigid Steel Conduit, Rigid Aluminum Conduit, and Intermediate Metal Conduit
 3. TC 2 - Electrical Polyvinyl Chloride (PVC) Conduit
 4. TC 9 - Fittings for PVC Plastic Utilities Duct for Underground Installation
- E. NFPA 70 - National Electrical Code (NEC)
- F. Underwriters Laboratories (UL): Applicable Listings
1. UL 1 - Flexible Metal Conduit
 2. UL 6 - Rigid Metal Conduit
 3. UL 360 - Liquid Tight Flexible Steel Conduit
 4. UL514-B - Conduit Tubing and Cable Fittings
 5. UL651-A - Type EB and a PVC Conduit and HDPE Conduit
 6. UL651-B - Continuous Length HDPE Conduit
 7. UL746A - Standard for Polymeric Materials - Short Term Property Evaluations
 8. UL797 - Electrical Metal Tubing
 9. UL1242 - Intermediate Metal Conduit
- G. American Standard of Testing and Materials (ASTM):
1. ASTM D 570 - Standard Test Method for Water Absorption of Plastics
 2. ASTM D 638 - Standard Test Method for Tensile Properties of Plastics
 3. ASTM D 648 - Standard Test Method for Deflection Temperature of Plastics under Flexural Load in the Edge Wise Position
 4. ASTM D 2412 - Standard Test Method for Determination of External Loading Characteristics of Plastic Pipe by Parallel-Plate Loading
 5. ASTM D 2447 - Standard Specification for Polyethylene (PE) Plastic Pipe, Schedules 40 and 80, Based on Outside Diameter
 6. ASTM D 3350 - Standard Specification for Polyethylene Plastic Pipe and Fittings Material
- H. Definitions:
1. Fittings: Conduit connection or coupling.

2. Body: Enlarged fittings with opening allowing access to the conductors for pulling purposes only.
3. Mechanical Spaces: Enclosed areas, usually kept separated from the general public, where the primary use is to house service equipment and to route services. These spaces generally have exposed structures, bare concrete and non-architecturally emphasized finishes.
4. Finished Spaces: Enclosed areas where the primary use is to house personnel and the general public. These spaces generally have architecturally emphasized finishes, ceilings and/or floors.
5. Concealed: Not visible by the general public. Often indicates a location either above the ceiling, in the walls, in or beneath the floor slab, in column coverings, or in the ceiling construction.
6. Above Grade: Not directly in contact with the earth. For example, an interior wall located at an elevation below the finished grade shall be considered above grade but a wall retaining earth shall be considered below grade.
7. Slab: Horizontal pour of concrete used for a floor or sub-floor.

1.4 SUBMITTALS

- A. Include fittings and conduits 1.5" and larger in coordination files. Include all in--floor and underfloor conduit in coordination files. Refer to Section 26 05 00 for coordination drawing requirements.

PART 2 - PRODUCTS

2.1 RIGID METALLIC CONDUIT (RMC) AND FITTINGS

A. Manufacturers:

1. Allied
2. LTV
3. Steelduct
4. Calbond Calpipe
5. Wheatland Tube Co
6. O-Z Gedney
7. or approved equal.

B. Manufacturers of RMC Conduit Fittings:

1. Appleton Electric
2. O-Z/Gedney Co.
3. Electroline
4. Raco
5. Bridgeport
6. Midwest
7. Regal
8. Thomas & Betts
9. Crouse-Hinds
10. Killark

11. Orbit Industries
12. or approved equal.

C. Minimum Size Galvanized Steel: 3/4 inch, unless otherwise noted.

D. Fittings and Conduit Bodies:

1. End Bell Fittings: Malleable iron, hot dip galvanized, threaded flare type with provisions for mounting to form.
2. Expansion Joints: Malleable iron and hot dip galvanized providing a minimum of 4 inches of movement. Fitting shall be watertight with an insulating bushing and a bonding jumper.
3. Expansion Joint for Concrete Encased Conduit: Neoprene sleeve with bronze end coupling, stainless steel bands and tinned copper braid bonding jumper. Fittings shall be watertight and concrete-tight.
4. Conduit End Bushings: Malleable iron type with molded-on high impact phenolic thermosetting insulation. Where required elsewhere in the contract documents, bushing shall be complete with ground conductor saddle and clamp. High impact phenolic threaded type bushings are not acceptable.
5. All other fittings and conduit bodies shall be of malleable iron construction and hot dip galvanized.

E. PVC Externally Coated Conduit: Compliant with UL 6, ANSI C80.1 and NEMA RN 1; rigid galvanized steel conduit with external 40 mil PVC coating and internal 2 mil urethane coating surface. All fittings and conduit bodies shall be complete with coating. Threads shall be hot galvanized and coated with a clear coat of urethane. The PVC coated system shall include necessary PVC coated fittings, boxes and covers to form a complete encapsulated system.

1. Acceptable Manufacturers:

- a. Calbond Calpipe
- b. Robroy
- c. T&B Ocal
- d. or approved equal.

2.2 STAINLESS STEEL CONDUIT (316SS) AND FITTINGS

A. Manufacturers:

1. Gibson Stainless & Specialty
2. Calbond Calpipe
3. Calbrite
4. Eaton/Crouse-Hinds
5. Thomas & Betts
6. or approved equal.

B. All material shall be Type 316 stainless steel, meet ASTM A-321 and SA-312 standards, and be UL 6A approved.

C. All conduit shall be heavy wall Schedule 40 with standard NPT threads.

- D. Minimum Size Stainless Steel: 3/4 inch, unless otherwise noted.
- E. Fittings, conduit bodies, couplings, nipples, bushings, connectors, supports, clamps, and all accessory hardware shall be made of Type 316 stainless steel.

2.3 INTERMEDIATE METALLIC CONDUIT (IMC) AND FITTINGS

- A. Minimum Size Galvanized Steel: 3/4 inch, unless otherwise noted.
- B. Manufacturers:
 - 1. Allied
 - 2. LTV
 - 3. Steelduct
 - 4. Wheatland Tube Co
 - 5. O-Z Gedney
 - 6. or approved equal.
- C. Fittings and Conduit Bodies:
 - 1. End Bell Fittings: Malleable iron, hot dip galvanized, threaded flare type with provisions for mounting to form.
 - 2. Expansion Joints: Malleable iron and hot dip galvanized providing a minimum of 4 inches of movement. Fitting shall be watertight with an insulating bushing and a bonding jumper.
 - 3. Expansion Joint for Concrete Encased Conduit: Neoprene sleeve with bronze end coupling, stainless steel bands and tinned copper braid bonding jumper. Fittings shall be watertight and concrete-tight.
 - 4. Conduit End Bushings: Malleable iron type with molded-on high impact phenolic thermosetting insulation. Where required elsewhere in the contract documents, bushing shall be complete with ground conductor saddle and clamp. High impact phenolic threaded type bushings are not acceptable.
 - 5. All other fittings and conduit bodies shall be of malleable iron construction and hot dip galvanized.

2.4 ELECTRICAL METALLIC TUBING (EMT) AND FITTINGS

- A. Minimum Size Electrical Metallic Tubing: 3/4 inch, unless otherwise noted.
- B. Manufacturers of EMT Conduit:
 - 1. Allied
 - 2. Calbond Calpipe
 - 3. LTV
 - 4. Steelduct
 - 5. Wheatland Tube Co
 - 6. or approved equal.
- C. Fittings and Conduit Bodies:
 - 1. 2" Diameter or Smaller: Compression type of steel designed for their specific application.

2. 1/2" and 3/4" Conduit: Push-on connectors and couplers with locking ring and washer of zinc plated steel, listed for use in dry locations.
3. Larger than 2": Compression type of steel designed for their specific application.
4. Manufacturers of EMT Conduit Fittings:
 - a. Appleton Electric
 - b. O-Z/Gedney Co.
 - c. Electroline
 - d. Raco
 - e. Bridgeport
 - f. Midwest
 - g. Regal
 - h. Thomas & Betts
 - i. Orbit Industries
 - j. or approved equal.

2.5 FLEXIBLE METALLIC CONDUIT (FMC) AND FITTINGS

- A. Minimum Size Galvanized Steel: 3/4 inch, unless otherwise noted. Lighting branch circuit wiring to an individual luminaire may be a manufactured, UL listed 3/8" flexible metal conduit and fittings with #14 AWG THHN conductors and an insulated ground wire. Maximum length of 3/8" FMC shall be six (6) feet.
- B. Manufacturers:
 1. American Flex
 2. Alflex
 3. Electri-Flex Co
 4. or approved equal.
- C. Construction: Flexible steel, approved for conduit ground, zinc coated, threadless type formed from a continuous length of spirally wound, interlocked zinc coated strip steel. Provide a separate equipment grounding conductor when used for equipment where flexibility is required.
- D. Fittings and Conduit Bodies:
 1. Threadless hinged clamp type, galvanized zinc coated cadmium plated malleable cast iron or screw-in type, die-cast zinc.
 2. Fittings and conduit bodies shall include plastic or cast metal inserts supplied by the manufacturer to protect conductors from sharp edges.
 3. Manufacturers:
 - a. O-Z/Gedney Co.
 - b. Thomas & Betts
 - c. Appleton Electric
 - d. Electroline
 - e. Bridgeport
 - f. Midwest
 - g. Regal
 - h. Orbit Industries
 - i. or approved equal.

2.6 LIQUIDTIGHT FLEXIBLE METALLIC CONDUIT (LFMC) AND FITTINGS

- A. Manufacturers:
 - 1. Anaconda Type UA
 - 2. Electri-Flex Type LA
 - 3. Alflex
 - 4. Carlon (Lamson & Sessions)
 - 5. or approved equal.
- B. Construction: Flexible steel, approved for conduit ground, zinc coated, threadless type formed from a continuous length of spirally wound, interlocked zinc coated strip steel and an extruded PVC cover.
- C. Fittings and Conduit Bodies:
 - 1. Watertight, compression type, galvanized zinc coated cadmium plated malleable cast iron, UL listed.
 - 2. Fittings and conduit bodies shall include plastic or cast metal inserts supplied by the manufacturer to protect conductors from sharp edges.
 - 3. Manufacturers:
 - a. Appleton Electric
 - b. O-Z/Gedney Co.
 - c. Electroline
 - d. Bridgeport
 - e. Thomas & Betts
 - f. Midwest
 - g. Regal
 - h. Carlon (Lamson & Sessions)
 - i. Orbit Industries
 - j. or approved equal.

2.7 RIGID NON-METALLIC CONDUIT (PVC) AND FITTINGS

- A. Minimum Size Rigid Smooth-Wall Nonmetallic Conduit: 3/4 inch, unless otherwise noted.
- B. Acceptable Manufacturers:
 - 1. Carlon (Lamson & Sessions) Type 40
 - 2. Cantex, J.M. Mfg.
 - 3. or approved equal.
- C. Construction: Schedule 40 and Schedule 80 rigid polyvinyl chloride (PVC), UL labeled for 90°C.
- D. Fittings and Conduit Bodies: NEMA TC 3; sleeve type suitable for and manufactured especially for use with the conduit by the conduit manufacturer.
- E. Plastic cement for joining conduit and fittings shall be provided as recommended by the manufacturer.

2.8 HIGH DENSITY POLYETHYLENE (HDPE)

- A. Minimum Size: 2 inch, unless noted otherwise.
- B. Acceptable Manufacturers:
 - 1. Carlon
 - 2. Chevron Phillips Chemical Company
 - 3. or approved equal.
- C. Materials used for the manufacture of polyethylene pipe and fittings shall be extra high molecular weight, high-density polyethylene resin. The material shall be listed by PPI (Plastic Pipe Institute) and shall meet the following resin properties:

ASTM Test	Description	Values HDPE
D-1505	Density g/CM 3	less than 0.941
D-1238	Melt Index, g/10 min Condition E	greater than 0.55 grams/10 min.
D-638	Tensile Strength at yield (psi)	3000 min.
D-1693	Environmental Stress Crack Resistance Condition B, F 20	96 hrs.
D-790	Flexural Modulus, MPa (psi)	less than 80,000
D-746	Brittleness Temperature	-75°C Max

- D. The pipe shall contain no recycled compound except that generated in the manufacturer's own plant from resin of the same raw material, including both the base resin and coextruded resin. The pipe shall be homogeneous throughout and free of visible cracks, holes, voids, foreign inclusions, or other defects that may affect the wall integrity.
- E. Fitting and Conduit Bodies:
 - 1. Directional Bore and Plow Type Installation: Electrofusion or Universal Aluminum threaded couplings. Tensile strength of coupled pipe must be greater than 2,000 lbs.
 - 2. For all other type of installation: Coupler must provide a water tight connection. The tensile strength of coupled pipe must be greater than 1,000 lbs.
 - 3. E-loc type couplings are not acceptable in any situations.
 - 4. Acceptable Manufacturers:
 - a. ARCON
 - b. Carlon
 - c. or approved equal.

2.9 REINFORCED THERMOSETTING RESIN CONDUIT (RTRC) AND FITTINGS

- A. Minimum Size: 1 inch.
- B. Acceptable Manufacturers:
 - 1. Champion Fiberglass
 - 2. FRE Composites
 - 3. or approved equal.

- C. Conduit shall be fiberglass reinforced epoxy using a filament winding process. Conduit, elbows and fittings shall be manufactured from the same resin/hardener/glass system and the same filament wound system. Resin systems shall be epoxy with no fillers. Glass used shall be E-type.
- D. Fitting and Conduit Bodies:
 - 1. Expansion fittings for RTRC shall be provided in accordance with Electrical Code.
 - 2. Joints in wet locations and underground locations shall be watertight.

2.10 PHENOLIC REINFORCED THERMOSETTING RESIN CONDUIT AND FITTINGS
(PHENOLIC RTRC)

- A. Minimum Size: 1 inch.
- B. Manufacturers:
 - 1. Champion Fiberglass Flameshield XW
 - 2. FRE Composites BreathSaver
 - 3. or approved equal.
- C. Conduit shall be low smoke, no flame, low toxicity. Conduit shall be fiberglass reinforced phenolic using a filament winding process. Conduit, elbows, conduit bodies, and fittings shall be manufactured from the same resin/hardener/glass system and the same filament wound system. Resin systems shall be phenol with no fillers. Fiberglass used shall be E-type.
- D. Fitting and Conduit Bodies:
 - 1. Expansion fittings shall be provided in accordance with Electrical Code.
 - 2. Joints in wet locations and underground locations shall be watertight.

2.11 OUTLET BOXES

- A. Sheet Metal Outlet Boxes: ANSI/NEMA OS 1; galvanized steel, 16 gauge (approximately 0.0625 inches), with 1/2-inch male fixture studs where required.
- B. Nonmetallic Outlet Boxes: ANSI/NEMA OS 2.
- C. Cast Boxes: Nema FB1, Type FD, Aluminum, cast ferrous alloy, or stainless steel deep type, gasketed cover, threaded hubs.
- D. Outlet boxes for luminaires to be not less than 1-1/2" deep, deeper if required by the number of wires or construction. The box shall be coordinated with surface luminaires to conceal the box from view or provide a finished trim plate.

- E. Switch outlet boxes for local light control switches, dimmers and occupancy sensors shall be 4 inches square by 2-1/8 inches deep, with raised cover to fit flush with finish wall line. Multiple gang switch outlets shall consist of the required number of gang boxes appropriate to the quantity of switches comprising the gang. Where walls are plastered, provide a plaster raised cover. Where switch outlet boxes occur in exposed concrete block walls, boxes shall be installed in the block cavity with a raised square edge tile cover of sufficient depth to extend out to face of block or masonry boxes.
- F. Outlet boxes for telephone substations in walls and columns shall be 4 inches square and 2-1/8 inches deep with single gang raised cover to fit flush with finished wall line equipped with flush telephone plate.
- G. Wall or column receptacle outlet boxes shall be 4 inches square with raised cover to fit flush with finished wall line. Boxes in concrete block walls shall be installed the same as for switch boxes in block walls.

2.12 ECONN; ELECTRICAL CONNECTION

- A. Electrical connection to equipment and motors, sized per Electrical Code. Coordinate requirements with contractor furnishing equipment or motor. Refer to specifications and general installation notes for terminations to motors.

2.13 JB; PULL AND JUNCTION BOXES

- A. Sheet Metal Boxes: ANSI/NEMA OS 1; galvanized steel.
- B. Sheet metal boxes larger than 12 inches in any dimension that contain terminations or components: Continuous hinged enclosure with 1/4 turn latch and white back panel for mounting terminal blocks and electrical components.
- C. Cast Metal Boxes for Outdoor and Wet Location Installations: NEMA 250; Type 4 and Type 6, flat-flanged, surface-mounted junction box, UL listed as raintight. Galvanized cast iron box and cover with ground flange, neoprene gasket, and stainless steel cover screws.
- D. Cast Metal Boxes for Underground Installations: NEMA 250; Type 4, inside flanged, recessed cover box for flush mounting, UL listed as raintight. Galvanized cast iron box and plain cover with neoprene gasket and stainless steel cover screws.
- E. Flanged type boxes shall be used where installed flush in wall.

2.14 ROUGH-IN

- A. Provide with one (1) flush mount double gang box with single gang plaster ring and appropriate cover plate,
- B. Conduit stubbed to above the lay-in ceiling.
- C. RI-TECH-W; Technology Rough-in - Wall Phone:
 - 1. Mount on wall +54" or as noted in plans. Rough-in shall have one (1) 1" conduit.

- D. RI-TECH-C; Technology Rough-in - Ceiling Flush Mounted:
 - 1. Mount flush in finished ceiling or as noted in plans. Rough-in shall have one (1) 1" conduit.
- E. RI-TV; Television Antenna Outlet Box Rough-in:
 - 1. Rough-in shall have one (1) 3/4" conduit.

PART 3 - EXECUTION

3.1 CONDUIT INSTALLATION SCHEDULE AND SIZING

- A. In the event the location of conduit installation represents conflicting installation requirements as specified in the following schedule, a clarification shall be obtained from the Architect/Engineer. If this Contractor is unable to obtain a clarification as outlined above, concealed rigid galvanized steel conduit installed per these specifications and the Electrical Code shall be required.
- B. Installation Schedule: Refer to drawings.
- C. Fire Rated Assemblies:
 - 1. Listed Fire Rated Assemblies: Phenolic RTRC
- D. Size conduit as shown on the drawings and specifications. Where not indicated in the contract documents, conduit size shall be according to the Electrical Code. Conduit and conductor sizing shall be coordinated to limit conductor fill to less than 40%, maintain conductor ampere capacity as required by the Electrical Code (to include enlarged conductors due to temperature and quantity derating values) and to prevent excessive voltage drop and pulling tension due to long conduit/conductor lengths.
- E. Minimum Conduit Size (Unless Noted Otherwise):
 - 1. Above Grade: 3/4 inch. (The use of 1/2 inch would be allowed for installation conduit to individual light switches, individual receptacles and individual fixture whips from junction box.)
 - 2. Below Grade 5' or less from Building Foundation: 3/4 inch.
 - 3. Below Grade More than 5' from Building Foundation: 3/4 inch.
 - 4. Telecommunication Conduit: 1 inch.
 - 5. Controls Conduit: 1/2 inch.
- F. Conduit Embedded in Slabs above Grade:
 - 1. Embedded installation NOT allowed in elevated slabs with metal composite decks nor structural pour in place slabs less than 6 inches in depth unless specifically noted or shown on drawings otherwise.
 - 2. Maximum size 1-1/4 inch for conduits crossing each other.

- G. Conduit sizes shall change only at the entrance or exit to a junction box, unless specifically noted on the drawings.

3.2 CONDUIT ARRANGEMENT

- A. In general, conduit shall be installed concealed in walls, in finished spaces and where possible or practical, or as noted otherwise. Conduit shall be installed parallel or perpendicular to walls, ceilings, and exposed structural members. In unfinished spaces, mechanical and utility areas, conduit may run either concealed or exposed as conditions dictate and as practical unless noted otherwise on drawings. Installation shall maintain headroom in exposed vicinities of pedestrian or vehicular traffic.
- B. Exposed conduit on exterior walls or above roof will not be allowed without prior written approval of Architect/Engineer. A drawing of the proposed routing and a photo of the location shall be submitted 14 days prior to start of conduit rough-in. Routing shall be shown on coordination drawings.
- C. Conduit arrangement in elevated slabs (restricted to applications specifically noted or shown on drawings):
 - 1. Conduit size shall not exceed one-third of the structural slab thickness. Place conduit between the top and bottom reinforcing with a minimum of 3" concrete cover.
 - 2. Parallel conduits shall be spaced at least 8 inches apart. Exception: Within 18 inches of commonly served floor boxes, junction boxes, or similar floor devices. Arrange conduits parallel or perpendicular to building lines and walls.
- D. Conduit shall not share the same cell as structural reinforcement in masonry walls.
- E. Conduit runs shall be routed as shown on large scale drawings. Conduit routing on drawings scaled 1/4"=1'-0" or less shall be considered diagrammatic, unless noted otherwise. The correct routing, when shown diagrammatically shall be chosen by the Contractor based on information in the contract documents, in accordance with manufacturer's written instructions, applicable codes, the NECA's "Standard of Installation", in accordance with recognized industry standards, and coordinated with other contractors.
- F. Contractor shall adapt Contractor's work to the job conditions and make such changes as required and permitted by the Architect/Engineer, such as moving to clear beams and joists, adjusting at columns, avoiding interference with windows, etc., to permit the proper installation of other mechanical and/or electrical equipment.
- G. Contractor shall cooperate with all contractors on the project. Contractor shall obtain details of other contractor's work to ensure fit and avoid conflict. Any expense due to the failure of This Contractor to do so shall be paid for in full by Contractor. The other trades involved as directed by the Architect/Engineer shall perform the repair of work damaged as a result of neglect or error by This Contractor. The resultant costs shall be borne by This Contractor.

3.3 CONDUIT SUPPORT

- A. Conduit runs installed above a suspended ceiling shall be properly supported. In no case shall conduit rest on the suspended ceiling construction, nor utilize ceiling support system for conduit support.

1. Support wire used to independently support raceway and wiring systems above suspending ceilings shall be supported on both ends, minimum 12 gauge suspended ceiling support wire, and distinguishable from ceiling support systems by color (field paint), tagging, or equivalent means.
- B. Conduit shall not be supported from ductwork, water, sprinkler piping, or other non-structural members, unless approved by the Architect/Engineer. All supports shall be from structural slabs, walls, structural members, and bar joists, and coordinated with all other applicable contractors, unless noted otherwise.
- C. Conduit shall be held in place by the correct size of galvanized one-hole conduit clamps, two-hole conduit straps, patented support devices, clamp back conduit hangers, or by other means if called for on the drawings.
- D. Support individual horizontal raceways with separate, malleable-iron pipe hangers or clamps.
- E. Spring-steel conduit clips specifically designed for supporting single conduits or tubing may be used in lieu of malleable-iron hangers for 1-1/2" and smaller raceways serving lighting and receptacle branch circuits above accessible ceilings and for securing raceways to slotted channel and angle supports.
- F. Group conduits in parallel runs where practical and use conduit racks or trapeze hangers constructed of steel channel, suspended with threaded solid rods or wall mounted from metal channels with conduit straps or clamps. Provide space in each rack or trapeze for 25% additional conduits.
- G. Do not exceed 25 lbs. per hanger and a minimum spacing of 2'-0" on center when attaching to metal roof decking (excludes concrete on metal deck). This 25 lbs. load and 2'-0" spacing include adjacent electrical and mechanical items hanging from deck. If the hanger restrictions cannot be achieved, supplemental framing off steel framing will need to be added.
- H. Arrange supports in vertical runs so the weight of raceways and enclosed conductors is carried entirely by raceway supports, with no weight load on raceway terminals.
- I. Supports for metallic conduit shall be no greater than 10 feet. A smaller interval may be used if necessitated by building construction, but in no event shall support spans exceed the Electrical Code requirements. Conduit shall be securely fastened within 3 feet of each outlet box, junction box, device box, cabinet, or fitting.
- J. Supports of flexible conduit shall be within 12 inches of each outlet box, junction box, device box, cabinet, or fitting and at intervals not to exceed 4.5 feet.
- K. Supports for non-metallic conduit shall be at sufficiently close intervals to eliminate any sag in the conduit. The manufacturer's recommendations shall be followed, but in no event shall support spans exceed the Electrical Code requirements.
- L. Where conduit is to be installed in poured concrete floors or walls, provide concrete-tight conduit inserts securely fastened to forms to prevent conduit misplacement.

M. Finish:

1. Prime coat exposed steel hangers and supports. Hangers and supports in crawl spaces, pipe shafts, and above suspended ceiling spaces are not considered exposed.
2. Trim all ends of exposed field fabricated steel hangers, slotted channel and threaded rod to within 1" of support or fastener to eliminate potential injury to personnel unless shown otherwise on the drawings. Smooth ends and install elastomeric insulation with two coats of latex paint if exposed steel is within 6'-6" of finish floor and presents potential injury to personnel.

3.4 CONDUIT INSTALLATION

A. Conduit Connections:

1. Shorter than standard conduit lengths shall be cut square using industry standards. The ends of all conduits cut shall be reamed or otherwise finished to remove all rough edges.
2. Metallic conduit connections in slab on grade installation shall be sealed and one coat of rust inhibitor primer applied after the connection is made.
3. Where conduits with tapered threads cannot be coupled with standard couplings, then approved split or Erickson couplings shall be used. Running threads will not be permitted.
4. Install expansion/deflection joints where conduit crosses structure expansion/seismic joints.

B. Conduit terminations for all low voltage wiring shall have nylon bushings installed on each end of every conduit run.

C. Conduit Bends:

1. Use a hydraulic one-shot conduit bender or factory elbows for bends in conduit 2" in size or larger. All steel conduit bending shall be done cold; no heating of steel conduit shall be permitted.
2. A run of conduit shall not contain more than the equivalent of four (4) quarter bends (360°), including those bends located immediately at the outlet or body.
3. Telecommunications conduits shall have no more than two (2) 90-degree bends between pull points and contain no continuous sections longer than 100 feet. Insert pull points or pull boxes for conduits exceeding 100 feet in length.
 - a. A third bend is acceptable if:
 - 1) The total run is not longer than (33) feet.
 - 2) The conduit size is increased to the next trade size.
4. Telecommunications pull boxes shall not be used in lieu of a bend. Align conduits that enter the pull box from opposite ends with each other. Pull box size shall be twelve (12) times the diameter of the largest conduit. Slip sleeves or gutters can be used in place of a pull box.
5. Telecommunications Conduit(s): Maintain appropriate conduit bend radius at all times. For conduits with an internal diameter of less than 2", maintain a bend radius of at least 6 times the internal diameter. For conduits with an internal diameter 2" or greater, maintain a bend radius of at least 10 times the internal diameter.

6. Rigid polyvinyl chloride conduit (PVC) runs longer than 100 feet or runs which have more than two 90° equivalent bends (regardless of length) shall use rigid metal or RTRC factory elbows for bends.
7. Use conduit bodies to make sharp changes in direction (i.e. around beams).

D. Conduit Placement:

1. Conduit shall be mechanically continuous from source of current to all outlets. Conduit shall be electrically continuous from source of current to all outlets, unless a properly sized grounding conductor is routed within the conduit. All metallic conduits shall be bonded per the Electrical Code.
2. Route exposed conduit and conduit above suspended ceilings (accessible or not) parallel/perpendicular to the building structural lines, and as close to building structure as possible. Wherever possible, route horizontal conduit runs above water and steam piping.
3. Route conduit through roof openings provided for piping and ductwork where possible. If not provided or routing through provided openings is not possible, route through roof jack with pitch pocket. Coordinate roof penetrations with other trades.
4. Conduits, raceway, and boxes shall not be installed in concealed locations in metal deck roofing or less than 1.5" below bottom of roof decking.
5. Avoid moisture traps where possible. Where unavoidable, provide a junction box with drain fitting at conduit low point.
6. All conduits through walls shall be grouted or sealed into openings. Where conduit penetrates firewalls and floors, seal with a UL listed sealant. Seal penetrations with intumescent caulk, putty, or sheet installed per manufacturer's recommendations. All materials used to seal penetrations of firewalls and floors shall be tested and certified as a system per ASTM E814 Standard for fire tests or through-penetration fire stops as manufactured by 3M or approved equal.
7. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL OPENINGS REQUIRED IN MASONRY OR EXTERIOR WALLS UNDER THIS DIVISION. A QUALIFIED MASON AT THE EXPENSE OF THIS CONTRACTOR SHALL REPAIR ALL OPENINGS TO MATCH EXISTING CONDITIONS.
8. Seal interior of conduit at exterior entries, air handling units, coolers/freezers, etc., and where the temperature differential can potentially be greater than 20°F, to prevent moisture penetration. Seal shall be placed where conduit enters warm space. Conduit seal fitting shall be a drain/seal, with sealing compound, identified for use with cable and raceway system, equal to O-Z/Gedney type EYD.
9. Horizontal conduit routing through slabs above grade
 - a. Conduits, if run in concrete structure, shall be in middle one-third of slab thickness, and leave at least 3" min. concrete cover. Conduits shall run parallel to each other and spaced at least 8" apart centerline to centerline. Secure raceways to reinforcing rods to prevent sagging or shifting during concrete placement. Maximum conduit outside diameter 1".
 - b. No conduits are allowed in concrete on metal deck unless expressly approved in writing by the Structural Engineer.
 - c. No conduits are allowed to be routed horizontally through slabs above grade.
10. Do not route conduits across each other in slabs on grade.
11. Rigid polyvinyl chloride conduit (PVC) shall be installed when material surface temperatures and ambient temperature are greater than 40°F.

12. Where rigid polyvinyl chloride conduit (PVC) is used below grade, in a slab, below a slab, etc., a transition to rigid galvanized steel or PVC-coated steel conduit shall be installed before conduit exits earth. The metallic conduit shall extend a minimum of 6" into the surface concealing the non-metallic conduit.
13. Contractor shall provide suitable mechanical protection around all conduits stubbed out from floors, walls or ceilings during construction to prevent bending or damaging of stubs due to carelessness with construction equipment.
14. Contractor shall provide a polypropylene pull cord with 2000 lbs. tensile strength in each empty conduit (indoor and outdoor), except in sleeves and nipples.

3.5 CONDUIT TERMINATIONS

- A. Where conduit bonding is indicated or required in the contract documents, the bushings shall be a grounding type sized for the conduit and ground bonding conductor as manufactured by O-Z/Gedney, Appleton, Thomas & Betts, Burndy, Regal, Orbit Industries or approved equal.
- B. Conduits with termination fittings shall be threaded for one (1) lock nut on the outside and one (1) lock nut and bushing on the inside of each box.
- C. Where conduits terminate in boxes with knockouts, they shall be secured to the boxes with lock nuts and provided with approved screw type tinned iron bushings or fittings with plastic inserts.
- D. Where conduits terminate in boxes, fittings, or bodies with threaded openings, they shall be tightly screwed against the shoulder portion of the threaded openings.
- E. Conduit terminations to all motors shall be made with flexible metallic conduit (FMC), unless noted otherwise. Final connections to roof exhaust fans, or other exterior motors and motors in damp or wet locations shall be made with liquidtight flexible metallic conduit (LFMC). Motors in hazardous areas, as defined in the Electrical Code, shall be connected using flexible conduit rated for the environment. Flexible conduit shall not exceed 6' in length. Route equipment ground conductors from circuit ground to motor ground terminal through flexible conduit.
- F. Rigid polyvinyl chloride conduit (PVC) shall be terminated using fittings and bodies produced by the manufacturer of the conduit, unless noted otherwise. Prepare conduit as per manufacturer's recommendations before joining. All joints shall be solvent welded by applying full even coat of plastic cement to the entire areas that will be joined. Turn the conduit at least a quarter to one half turn in the fitting and let the joint cure for 1-hour minimum or as per the manufacturer's recommendations.
- G. All conduit ends shall be sealed with plastic immediately after installation to prevent the entrance of any foreign matter during construction. The seals shall be removed and the conduits blown clear of all foreign matter prior to any wires or pull cords being installed.

3.6 RIGID POLYVINYL CHLORIDE CONDUIT (PVC) OVERHEAD CONDUIT INSTALLATION

- A. Conduit shall be installed away from high temperature piping and equipment.
- B. Conduit shall be installed to prevent exposure to ultraviolet radiation.

- C. Proper allowances shall be made for expansion and/or contraction of the conduit during installation.
- D. Expansion fittings shall be installed in any 100' continuous run of conduit and at each 100' thereafter.
- E. Supports shall be made from non-corroding materials and spacing shall not be greater than the listing in the Electrical Code, but also shall not exceed the manufacturer's recommendations depending on the expected surface temperature.

3.7 UNDERGROUND CONDUIT INSTALLATION

A. Conduit Connections:

- 1. Conduit joints in a multiple conduit run shall be staggered at least one foot apart.

B. Conduit Bends (Lateral):

- 1. Conduits shall have long sweep radius elbows instead of standard elbows wherever special bends are indicated and noted on the drawings, or as required by the manufacturer of the equipment or system being served.
- 2. Telecommunications conduit bend radius shall be six times the diameter for conduits under 2" and ten times the diameter for conduits over 2". Where long cable runs are involved, sidewall pressures may require larger radius bends. Coordinate with Architect/Engineer prior to conduit installation to determine bend radius.

C. Conduit Elbows (vertical):

- 1. Minimum metal or RTRC elbow radiuses shall be 30 inches for primary conduits (greater than 600V) and 18 inches for secondary conduits (less than 600V). Increase radius, as required, based on pulling tension calculation requirements.

D. Conduit Placement:

- 1. Conduit runs shall be pitched a minimum of 4" per 100 feet to drain toward the terminations. Duct runs shall be installed deeper than the minimum wherever required to avoid any conflicts with existing or new piping, tunnels, etc.
- 2. For parallel runs, use suitable separators and chairs installed not greater than 4' on centers. Band conduit together with suitable banding devices. Securely anchor conduit to prevent movement during concrete placement or backfilling.
- 3. Where concrete is required, the materials for concreting shall be thoroughly mixed to a minimum f'c = 2500 and immediately placed in the trench around the conduits. No concrete that has been allowed to partially set shall be used.
- 4. Before the Contractor pulls any cables into the conduit, Contractor shall have a mandrel 1/4" smaller than the conduit inside diameter pulled through each conduit and if any concrete or obstructions are found, the Contractor shall remove them and clear the conduit. Spare conduit shall also be cleared of all obstructions.
- 5. Conduit terminations in manholes, masonry pull boxes, or masonry walls shall be with malleable iron end bell fittings.
- 6. All spare conduits not terminated in a covered enclosure shall have its terminations plugged as described above.

7. Ductbanks and conduit shall be installed a minimum of 24" below finished grade, unless otherwise noted on the drawings or elsewhere in these specifications.
8. All non-metallic conduit installed underground outside of a slab shall be rigid.

E. Horizontal Directional Drilling:

1. Entire drill path shall be accurately surveyed, with entry and exit stakes placed and coordinated with other contractors. If using a magnetic guidance system, entire drill path shall be surveyed for any surface geo-magnetic variations or anomalies.
2. Any utility locates within 20 feet of the bore path shall have the exact location physically verified by hand digging or vacuum excavation. Restore inspection holes to original condition after verification.

F. Raceway Seal:

1. Where a raceway enters a building or structure, it shall be sealed with a sealing bushing or duct seal to prevent the entry of liquids or gases. Seal must be compatible with conductors and raceway system. Spare or unused raceway shall also be sealed.
2. All telecommunications conduits and innerducts, including those containing cables, shall be plugged at the building and vault with "JackMoon" or equivalent duct seal, capable of withstanding a 10-foot head of water (5 PSI).
3. Duct Seal Alternative Option: Inflatable duct seal system. Capable of withstanding a 10-foot head of water (5 PSEI).

a. Manufacturers:

- 1) Raychem Rayflate Duct Sealing Systems RDSS
- 2) Approved equal

3.8 BOX INSTALLATION SCHEDULE

A. Galvanized steel boxes may be used in:

1. Concealed interior locations above ceilings and in hollow studded partitions.
2. Exposed interior locations in mechanical rooms and in rooms without ceilings; higher than 8' above the highest platform level.
3. Direct contact with concrete except slab on grade.
4. Recessed in stud wall of kitchens and laundries.

B. Cast boxes shall be used in:

1. Exterior locations.
2. Hazardous locations.
3. Exposed interior locations within 8' of the highest platform level.
4. Direct contact with earth.
5. Direct contact with concrete in slab on grade.
6. Wet locations.
7. Kitchens and laundries when exposed on wall surface.

3.9 COORDINATION OF BOX LOCATIONS

- A. Provide electrical boxes as shown on the drawings, and as required for splices, taps, wire pulling, equipment connections, and code compliance.
- B. Electrical box locations shown on the Contract Drawings are approximate, unless dimensioned. Verify location of floor boxes and outlets in offices and work areas prior to rough-in.
- C. Locate and install boxes to allow access. Avoid interferences with ductwork, piping, structure, equipment, etc. Recessed luminaires shall not be used as access to outlet, pull, and junction boxes. Where installation is inaccessible, provide access doors. Coordinate locations and sizes of required access doors with the Architect/Engineer and General Contractor.
- D. Locate and install to maintain headroom and to present a neat appearance.
- E. Coordinate locations with Heating Contractor to avoid baseboard radiation cabinets.

3.10 OUTLET BOX INSTALLATION

- A. Do not install boxes back-to-back in walls.
 - 1. Provide a minimum horizontal separation of 6 inches between boxes installed on opposite sides of non-rated stud walls. When the minimum separation cannot be maintained, install sound insulation pads on all five sides of the back box in accordance with the manufacturer's instructions.
 - 2. Provide a minimum horizontal separation of 24 inches between boxes installed on opposite sides of fire-rated walls. When the minimum separation cannot be maintained, the box is greater than 16 square inches or the total box area (all trades) per 100 square feet is greater than or equal to 100 square inches, install fire-rated moldable pads to all five sides of the back box to maintain the fire rating of the wall. Install moldable pads in accordance with UL listing for the specific product. Sound insulation pads are not acceptable for use in fire-rated wall applications unless the product carries the necessary fire rating.
- B. Install sound insulation pads on all five sides of the back of all boxes in sound-rated wall assemblies. Sound-rated wall assemblies are defined as partition types carrying a Sound Transmission Class (STC) rating.
- C. The Contractor shall anchor switch and outlet box to wall construction so that it is flush with the finished masonry, paneling, drywall, plaster, etc. The Contractor shall check the boxes as the finish wall surface is being installed to assure that the box is flush. (Provide plaster rings as necessary.)
- D. Mount at heights shown or noted on the drawings or as generally accepted if not specifically noted.
- E. Locate boxes in masonry walls to require cutting of masonry unit corner only. Coordinate masonry cutting to achieve neat openings for boxes.
- F. Provide knockout closures for unused openings.

- G. Support boxes independently of conduit.
- H. Use multiple-gang boxes where more than one device is mounted together; do not use sectional boxes. Provide barriers to separate wiring of different voltage systems.
- I. Install boxes in walls without damaging wall insulation.
- J. Coordinate mounting heights and locations of outlets mounted above counters, benches, backsplashes, and below baseboard radiation.
- K. Position outlets to locate luminaires as shown on reflected ceiling drawings.
- L. Provide recessed outlet boxes in finished areas; secure boxes to interior wall and partition studs, accurately positioned to allow for surface finish thickness. Use stamped steel stud bridges for flush outlets in hollow stud wall, and adjustable steel channel fasteners for flush ceiling outlet boxes.
- M. Align wall-mounted outlet boxes for switches, thermostats, and similar devices.
- N. Provide cast outlet boxes in exterior locations and wet locations, and where exposed rigid or intermediate conduit is used.

3.11 PULL AND JUNCTION BOX INSTALLATION

- A. Locate pull boxes and junction boxes above accessible ceilings or in unfinished areas.
- B. Support pull and junction boxes independent of conduit.
- C. Do not install boxes back-to-back in walls.
 - 1. Provide a minimum horizontal separation of 6 inches between boxes installed on opposite sides of non-rated stud walls. When the minimum separation cannot be maintained, install sound insulation pads on all five sides of the back box in accordance with the manufacturer's instructions.
 - 2. Provide a minimum horizontal separation of 24 inches between boxes installed on opposite sides of fire-rated walls. When the minimum separation cannot be maintained, the box is greater than 16 square inches or the total box area (all trades) per 100 square feet is greater than or equal to 100 square inches, install fire-rated moldable pads to all five sides of the back box to maintain the fire rating of the wall. Install moldable pads in accordance with UL listing for the specific product. Sound insulation pads are not acceptable for use in fire-rated wall applications unless the product carries the necessary fire rating.
- D. Install sound insulation pads on all five sides of the back of all boxes in sound-rated wall assemblies. Sound-rated wall assemblies are defined as partition types carrying a Sound Transmission Class (STC) rating.

3.12 EXPOSED BOX INSTALLATION

- A. Boxes shall be secured to the building structure with proper size screws, bolts, hanger rods, or structural steel elements.

- B. On brick, block and concrete walls or ceilings, exposed boxes shall be supported with no less than two (2) Ackerman-Johnson, Paine, Phillips, or approved equal screw anchors or expansion shields and round head machine screws. Cast boxes shall not be drilled.
- C. On steel structures, exposed boxes shall be supported to the steel member by drilling and tapping the member and fastening the boxes by means of round head machine screws.
- D. Boxes may be supported on steel members by APPROVED beam clamps if conduit is supported by beam clamps.
- E. Boxes shall be fastened to wood structures by means of a minimum of two (2) wood screws adequately large and long to properly support. (Quantity depends on size of box.)
- F. Wood, plastic, or fiber plugs shall not be used for fastenings.
- G. Explosive devices shall not be used unless specifically allowed.

END OF SECTION 26 05 33

SECTION 26 05 42 - EQUIPMENT WIRING SYSTEMS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Electrical connections to equipment specified under other Sections or furnished by the Owner.

1.2 REFERENCES

- A. NEMA WD 1 - General Purpose Wiring Devices
- B. NEMA WD 6 - Wiring Device Configurations
- C. NFPA 70 - National Electrical Code (NEC)

PART 2 - PRODUCTS

2.1 CORDS AND CAPS

- A. Straight-blade Attachment Plug: NEMA WD 1.
- B. Locking-blade Attachment Plug: NEMA WD 5.
- C. Attachment Plug Configuration: Match receptacle configuration at outlet provided for equipment.
- D. Cord Construction: Oil-resistant thermoset insulated Type SO multi-conductor flexible cord with identified equipment grounding conductor, suitable for hard usage in damp locations.
- E. Cord Size: Suitable for connected load of equipment and rating of branch circuit over-current protection.

PART 3 - EXECUTION

3.1 INSPECTION

- A. Verify that equipment is ready for electrical connection, wiring, and energization.

3.2 PREPARATION

- A. Review equipment submittals prior to installation and electrical rough-in. Verify location, size, and type of connections. Coordinate details of equipment connections with supplier and installer.

3.3 INSTALLATION

- A. Use wire and cable with insulation suitable for temperatures encountered in heat-producing equipment.
- B. Make cord connections to equipment using flexible conduit. Use liquidtight flexible conduit in damp or wet locations.
- C. Install pre-finished cord set where connection with attachment plug is indicated or specified, or use attachment plug with suitable strain-relief clamps.
- D. Provide suitable strain-relief clamps for cord connections to outlet boxes and equipment connection boxes.
- E. Make wiring connections in control panel or in wiring compartment of pre-wired equipment in accordance with manufacturer's instructions. Provide interconnecting wiring where indicated.
- F. Install disconnect switches, controllers, control stations, and control devices such as limit switches and temperature switches as indicated. Connect with conduit and wiring as indicated.
- G. Coolers and Freezers: Cut and seal conduit openings in freezer and cooler walls, floor, and ceilings.

END OF SECTION 26 05 42

SECTION 26 05 53 - ELECTRICAL IDENTIFICATION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Adhesive Markings and Field Labels
- B. Nameplates and Signs
- C. Product Colors

1.2 REFERENCES

- A. NFPA 70E - National Electrical Safety Code
- B. NFPA 70 - National Electrical Code (NEC)
- C. ANSI A13.1 - Standard for Pipe Identification
- D. ANSI Z535.4 - Standard for Product Safety Signs and Labels

1.3 SUBMITTALS

- A. General: Submit the following in accordance with Division 1 Specification Sections and under provisions of Section 26 05 00.
 - 1. Product Data for each type of product specified.
 - 2. Schedule of nomenclature to be used for identification signs and labels for each piece of equipment including, but not limited to, the following equipment types as specified in Division 26.
 - 3. Samples of each color, lettering style and other graphic representation required for identification materials including samples of labels and signs.
 - 4. Identification required in this section shall apply to equipment furnished in Division 26 and any other applicable Divisions including Division 21/22/23.

PART 2 - PRODUCTS

2.1 ADHESIVE MARKINGS AND FIELD LABELS

- A. Adhesive Marking Labels for Raceway: Pre-printed, flexible, self-adhesive vinyl labels with legend indicating voltage and service (Emergency, Lighting, Power, HVAC, Communications, Control, Fire).
 - 1. Label Size as follows:
 - a. Raceways: Kroy or Brother labels 1-inch high by 12-inches long (minimum).
 - 2. Color: As specified for various systems.

- B. Colored Adhesive Marking Tape for banding Raceways, Wires, and Cables: Self-adhesive vinyl tape not less than 3 mils thick by 1 inch to 2 inches in width.
- C. Pretensioned Flexible Wraparound Colored Plastic Sleeves for Cable Identification: flexible acrylic bands sized to suit the cable diameter and arranged to stay in place by pre-tensioned gripping action when coiled around the cable.
- D. Wire/Cable Designation Tape Markers: Vinyl or vinyl-cloth, self-adhesive, wraparound, cable/conductor markers with preprinted numbers and letter.
- E. Cable Ties: Fungus-inert, self-extinguishing, one-piece, self-locking nylon cable ties, 0.18-inch minimum width, 50-lb minimum tensile strength, and suitable for a temperature range from -40°F to 185°F (-40°C to 85°C), type 2/2S or type 21/21S based on application. Provide ties in specified colors when used for color coding. Cable ties shall be listed and identified for the application, securement, and support.
- F. Underground Plastic Markers: Bright colored continuously printed plastic ribbon tape of not less than 6 inches wide by 4 mil thick, printed legend indicating type of underground line, manufactured for direct burial service. Tape shall contain a continuous metallic wire to allow location with a metal detector.
- G. Aluminum, Wraparound Marker Bands: 1-inch width, 0.014 (5mm) inch thick aluminum bands with stamped or embossed legend, and fitted with slots or ears for permanently securing around wire or cable jacket or around groups of conductors.
- H. Brass or Aluminum Tags: 2" (50mm) by 2" (50mm) by .05-inch metal tags with stamped legend, punched for fastener.
- I. Indoor/Outdoor Number and Letters: Outdoor grade vinyl label with acrylic adhesive designed for permanent application in severe indoor and outdoor environments.
- J. Text Sizes:
 - 1. The following information shall be used for text heights, fonts, and size, unless otherwise noted.
 - a. Font: Normal 721 Swiss Bold
 - b. Adhesive Labels: 3/16 inch minimum text height
 - c. Vinyl / Plastic Laminate Labels: 3/4" inch minimum text height

2.2 NAMEPLATES AND SIGNS

- A. Engraved, Plastic-Laminated Labels, Signs and Instruction Plates: Engraving stock melamine plastic laminate, 1/16-inch minimum thick for signs up to 20 square inches, or 8 inches in length; 1/8 inch thick for larger sizes. Labels shall be punched for mechanical fasteners.

B. Text Sizes:

1. The following information shall be used for text heights, fonts, and size, unless otherwise noted.

a. Text Height: 3/8 inch minimum

C. Baked-Enamel Signs for interior Use: Preprinted aluminum signs, punched, or drilled for fasteners, with colors, legend, and size required for application. Mounting 1/4" grommets in corners.

D. Exterior, Metal-Backed, Butyrate Signs: Weather-resistant, nonfading, preprinted, cellulose-acetate butyrate signs with 0.0396 inch galvanized-steel backing: and with colors, legend, and size required for application. Mounting 1/4" grommets in corners.

E. Safety Signs: Comply with 29 CFR, Chapter XVII, Part 1910.145.

F. Fasteners for Plastic-Laminated Signs; Self-tapping stainless steel screws or number 10/32 stainless steel machine screws with nuts and flat and lock washers.

2.3 PRODUCT COLORS

A. Adhesive Markings and Field Labels:

1. All Labels: Black letters on white face
2. Normal Power and General Labels: Black letters on white face or black letters on clear face
3. Control Labels: Black letters on white face or black letters on clear face
4. Medium Voltage (greater than 1,000 volts): Black letters on white face or black letters on clear face
5. Fire Alarm: Red letters on white face or red letters on clear face
6. Emergency: Red letters on white face or red letters on clear face

B. Nameplates and Signs:

1. NORMAL POWER: Black letters on white face
2. Control Labels: Black letters on white face
3. EMERGENCY: White letters on red face
4. GROUNDING: White letters on green face.
5. CAUTION or UPS: Black letters on yellow face

C. Raceways and Conduit:

1. Provide color coded conduit as indicated below. Conduit shall be colored by the manufacturer:
 - a. Normal Power and General Distribution: Silver
 - b. Emergency Power Distribution System:
 - 1) All Emergency: Orange
 - 2) Legally Required Standby: Yellow

- 3) Optional Standby: Orange
- 4) Life Safety and Critical Branch: Yellow
- 5) Equipment Branch: Orange

- c. Fire Alarm System: Red
- d. Temperature Controls: Refer to mechanical cover sheet for color
- e. Ground: Green
- f. Low Voltage and Telephone: Purple
- g. Clock, Sound, Security System, and Intercom: Black
- h. Nurse Call: White

D. Box Covers:

- 1. Box covers shall be painted to correspond with system type as follows:

- a. Normal Power and General: Silver
- b. Emergency Power and Distribution:
 - 1) All Emergency: Orange
 - 2) Legally Required Standby: Yellow
 - 3) Optional Standby: Orange
 - 4) Life Safety and Critical Branch: Yellow
 - 5) Equipment Branch: Orange
- c. Fire Alarm System: Red
- d. Temperature Controls: Refer to mechanical cover sheet for color
- e. Ground: Green
- f. Low Voltage and Telephone: Purple
- g. Clock, Sound, Security System, and Intercom: Black
- h. Nurse Call: White

- 2. Box cover colors shall match conduit colors listed above.

E. Conductor Color Identification: Refer to Part 3 for additional information.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Lettering and Graphics: Coordinate names, abbreviations, colors, and other designations used in electrical identification work with corresponding designations specified or indicated. Install numbers, lettering, and colors as approved in submittals and as required by code.
- B. Exposed Ceilings and Finished Spaces: The project includes exposed ceilings in finished spaces. The installation of colored raceways and labeling may not be aesthetically desirable in finished spaces. The contractor shall coordinate identification requirements in exposed ceilings of finished spaces with the A/E prior to installation and ordering of materials.

- C. Electrical System Color Chart: This Contractor shall furnish and install framed 8" x 12" charts of the color-coded identification scheme used for the electrical system in all electrical rooms and next to the main fire alarm panel.
- D. Install identification devices in accordance with manufacturer's written instruction and requirements of Electrical Code.
- E. Sequence of Work: Where identification is to be applied to surfaces that require finish, install identification after completion of finish work. All mounting surfaces shall be cleaned and degreased prior to identification installation.
- F. Circuit Identification: Tag or label conductors as follows:
 - 1. Multiple Power or Lighting Circuits in Same Enclosure: Where multiple branch circuits are terminated or spliced in a box or enclosure, label each conductor with source and circuit number.
 - 2. Multiple Control Wiring and Communication/Signal Circuits in Same Enclosure: For control and communications/signal wiring, use wire/cable marking tape at terminations in wiring boxes, troughs, and control cabinets. Use consistent letter/number conductor designations throughout on wire/cable marking tape.
 - 3. Match identification markings with designations used in panelboards shop drawings, Contract Documents, and similar previously established identification schemes for the facility's electrical installations.
- G. Apply warning, caution and instruction signs as follows:
 - 1. Install warning, caution or instruction signs where required by Electrical Code, where indicated, or where reasonably required to assure safe operation and maintenance of electrical systems and of the items to which they connect. Install engraved plastic-laminated instruction signs with approved legend where instructions or explanations are needed for system or equipment operation. Install metal-backed butyrate signs for outdoor items.
 - 2. Emergency Operating Signs: Install, where required by Electrical Code, where indicated, or where reasonably required to assure safe operation and maintenance of electrical systems and of the items to which they connect, engraved laminate signs with white legend on red background with minimum 3/8-inch high lettering for emergency instructions on power transfer, load shedding, or other emergency operations.
- H. Apply circuit/control/item designation labels of engraved plastic laminate for pushbuttons, pilot lights, alarm/signal components, and similar items, except where labeling is specified elsewhere.
- I. Install labels parallel to equipment lines at locations as required and at locations for best convenience of viewing without interference with operation and maintenance of equipment.
- J. Install ARC FLASH WARNING signs on all power distribution equipment per Section 26 05 73.
- K. Install ARC FLASH WARNING signs on all switchboards, panelboards, industrial control panels, and motor control centers.

1. Sample Label:

! WARNING
ARC FLASH AND SHOCK HAZARD
APPROPRIATE PPE REQUIRED
FAILURE TO COMPLY CAN RESULT IN DEATH OR INJURY
REFER TO NFPA 70E

L. Circuits with more than 600V: Identify raceway and cable with "DANGER-HIGH VOLTAGE" in black letters 2 (50mm) inches high on orange background at 10'-0 foot intervals.

1. Entire floor area directly above conduits running beneath and within 12 inches of a basement or ground floor that is in contact with earth or is framed above unexcavated space.
2. Wall surfaces directly external to conduits concealed within wall.
3. All accessible surfaces of concrete envelope around conduits in vertical shafts, exposed in building, or concealed above suspended ceilings.

M. Selective Coordination Label: Install caution signs on all switchboards, distribution panels, panelboards, disconnects, and other equipment with selectively coordinated overcurrent protection devices. Sign at a minimum shall contain:

1. **CAUTION: OVERCURRENT DEVICES IN THIS ENCLOSURE ARE SELECTIVELY COORDINATED. EQUIVALENT REPLACEMENTS AND TRIP SETTINGS ARE REQUIRED.**

N. Underground Electrical Lines: For exterior underground power, control, signal, and communication lines, install continuous underground plastic line marker located directly above line at 6 (150mm) to 8 (205mm) inches below grade. A single plastic line marker is permitted when the width of the common trench does not exceed 16 inches; provide a second plastic line marker to mark each edge of the trench when 16 inches of width is exceeded. Limit line markers to direct-buried cables.

3.2 LIGHTING CONTROL AND RECEPTACLE COVER PLATES

A. Product:

1. Adhesive labels and field markings
2. Nameplates and signs

B. Identification material to be a clear, 3/8-inch Kroy tape or Brother self-laminating vinyl label with black letters. Embossed Dymo-Tape labels are not acceptable. Permanently affix identification label to cover plates, centered above the receptacle openings.

C. Identification material to be engraved plastic-laminated labels, 1/16-inch minimum thickness with white letters on a red face. Letter and number size to 1/8-inch high.

D. Identification to be engraved directly on the stainless steel coverplates. Letter and number size to 1/8-inch high.

- E. Provide identification on all switch and receptacle cover plates. Identification shall indicate source and circuit number serving the device (e.g. "C1A #24"). Identification for switch cover plates shall be installed on the inside cover.

3.3 CONDUIT AND EXPOSED CABLE LABELING

- A. Product:
 - 1. Adhesive labels and field markings
- B. Conduit Identification: Pre-printed, flexible, self-adhesive vinyl labels with legend at 10 foot (3 meter) intervals to identify all conduits run exposed or located above accessible ceilings. Conduits located above non-accessible ceiling or in floors and walls shall be labeled within 3 feet of becoming accessible, or separated by enclosures, walls, partitions, ceilings, and floors. Labels for multiple conduits shall be aligned. Refer to color requirements in Part 2 when applicable in addition to the following:
 - 1. Medium Voltage (greater than 1,000 volt): Indicate feeder identification and voltage.
 - 2. 1000 Volt or less Normal/Emergency Power: Indicate feeder identification and voltage.
 - 3. Essential Electrical System EES: When applicable the label shall include "Essential Electrical System EES". Maximum interval between label intervals shall be 25 feet or as required by code.
 - 4. Fire Alarm: Indicate "FIRE ALARM".
 - 5. Grounding: Indicate "GROUND" and equipment and designation.
 - 6. Security System: Indicate "Security".
 - 7. Telephone System: Indicate "Telephone".
- C. Blank conduit ends or outlet boxes for future extension of system shall have permanent identification marker indicating purpose of conduit or box and where the raceway originated.

3.4 CONDUIT AND RACEWAY COLOR BANDING FOR EXISTING CONDITIONS AND REMODELING

- A. Existing Conduit and Raceways: Identify existing conduits and raceways within the limits of the project boundary with color banding.
 - 1. Existing conduit and raceways to be color banded: 3/4 inch and larger.
 - 2. The Contractor shall perform a review of the existing conduit, raceway, and system type prior to submitting a bid. The Contractor's review shall include a review of areas with non-finished ceilings and areas with accessible finished ceilings.
- B. New Conduit and Raceways: Identify new conduits and raceways with color banding. The following products and materials shall be identified with color banding when required by Part 1 of this specification.
 - 1. Rigid metallic conduit and fittings (RMC)
 - 2. Intermediate metallic conduit and fittings (IMC)
 - 3. Reinforced thermosetting resin conduit (RTRC)
 - 4. Phenolic reinforced thermosetting resin conduit (phenolic RTRC conduit) Example: Fire-rated cable and assemblies

5. Wire and cable installed with or without raceways:
 - a. Fire-rated cable and assemblies (including but not limited to MI, fire-rated MC)
 - b. Healthcare facilities cable (HFC)
 - c. Armored cable (AC)
 - d. Metal-clad cable (MC)
 - e. Low voltage cabling

C. Instructions:

1. Band exposed or accessible raceways, cables, and bare conductors of the. Bands shall be pretensioned, snap-around colored plastic sleeves, colored adhesive marking tape, or a combination of the two. Make each color band 2 inches wide, completely encircling conduit, and place adjacent bands of two-color markings in contact, side by side. Refer to Part 1 of this specification for specific systems and colors requiring banding.
2. Install bands at changes within 36 inches of direction changes, all wall/floor penetrations, at each junction box, and at 10-foot maximum intervals in straight runs.

3.5 BOX LABELING

A. Products:

1. Adhesive labels and field markings

B. Identify Junction, Pull and Connection Boxes: Labeling shall be 3/8-inch Kroy tape, letters/numbers color coded same as conduits. In rooms that are painted out, provide labeling on inside of cover.

C. All junction, pull, and connection boxes shall be identified as follows:

1. For power and lighting circuits, indicate system voltage and identity of contained circuits ("120V, 1LA1-3,5,7").
2. Essential Electrical System EES: When applicable the label shall include "Essential Electrical System EES". Maximum interval between label intervals shall be 25 feet or as required by code.
3. For other wiring, indicate system type and description of wiring ("FIRE ALARM NAC #1").

3.6 CONDUCTOR COLOR CODING

A. Products:

1. All wire and cables shall be color coded by the manufacturer.
2. All wires and cables, 6 AWG or larger, used in motor circuits, main feeders, sub-main feeders, and branch circuits shall be coded by the application of plastic tape. The tape shall be 3-M, Plymouth or Permacel in colors specified below. The tape shall be applied at each conductor termination with two 1-inch tape bands at 6-inch centers. Contractor option to use colored cabling in lieu of the tape at each end for conductor 6 AWG to 500 KCM.

- B. Color coding shall be applied at all panels, switches, junction boxes, pull boxes, vaults, manholes etc., where the wires and cables are visible and terminations are made. The same color coding shall be used throughout the entire electrical system, therefore maintaining proper phasing throughout the entire project.
- C. Colored cable ties shall be applied in groups of three ties of specified color to each conductor at each terminal or splice point starting 3 inches from the termination and spaced at 3- inches centers. Tighten to a snug fit, and cut off excess length.
- D. Where more than one nominal voltage system exists in a building or facility, each ungrounded conductor of a multi-wire branch circuit, where accessible, shall be identified by phase and system.
- E. Conductors shall be color coded as follows:
 - 1. 120/240 Volt, 3-Wire:
 - a. A-Phase - Black
 - b. B-Phase - Red
 - c. Neutral - White
 - d. Ground Bond - Green
 - 2. 208Y/120 Volt, 4-Wire:
 - a. A-Phase - Black
 - b. B-Phase - Red
 - c. C-Phase - Blue
 - d. Neutral - White
 - e. Ground Bond - Green
 - 3. 480Y/277 Volt, 4-Wire:
 - a. A-Phase - Brown
 - b. B-Phase - Orange
 - c. C-Phase - Yellow
 - d. Neutral - Gray
 - e. Ground Bond - Green
 - 4. 120 Volt, 2-Wire Isolated (Ungrounded) Power System:
 - a. A-Phase - Orange with distinctive colored stripe other than white, green or gray along the entire length of the conductor
 - b. B-Phase - Brown with distinctive colored stripe other than white, green or gray along the entire length of the conductor
 - c. Ground Reference - Green
 - 5. 120/208 Volt, 3-Wire, Isolated (Ungrounded) Power System:
 - a. A-Phase - Orange with distinctive colored stripe other than white, green or gray along the entire length of the conductor

- b. B-Phase - Brown with distinctive colored stripe other than white, green or gray along the entire length of the conductor
 - c. C-Phase - Yellow with distinctive colored stripe other than white, green or gray along the entire length of the conductor
 - d. Ground Reference - Green
6. 0 to 1500 Volt, Direct Current DC Power System:
- a. Ungrounded Positive Polarity: Red or black with permanent red stripe marked along the entire length. Provide shrink wrap sleeves at terminations indication (POS, POSITIVE, or POS (+)).
 - b. Ungrounded Negative Polarity: Black. Provide shrink wrap sleeves at terminations indication (NEG, NEGATIVE, or NEG (-)).
 - c. Grounded Conductor in Grounded DC systems (refer to paragraphs a and b above for marking of ungrounded conductors):
 - 1) When Positive Polarity is Grounded: White along entire length. Provide shrink wrap sleeves at terminations indication (POS. POSITIVE, or POS (+)).
 - 2) When Negative Polarity is Grounded: White along entire length. Provide shrink wrap sleeves at termination indication (NEG, NEGATIVE, or NEG (-)).
7. Grounding Conductors:
- a. Equipment grounding conductors, main/system/supply-side bonding jumpers: Green.
 - b. Isolated Equipment Ground Conductors: Green with colored distinctive yellow stripe along the entire length of the conductor. Isolated ground for feeders, use colored tape with alternating bands of green and yellow to provide a minimum of three bands of green and two bands of yellow.
8. Cabling for Remote Control, Signal, and Power Limited Circuits:
- a. Fire Alarm: Refer to Fire Alarm and Automatic Detection Section 28 31 00 for cable color requirements.
 - b. Low Voltage Switching: Per manufacturer recommendations and code requirements.
 - c. Building Automation Systems and Control: Refer to the Temperature Control Contactor notes located on the mechanical cover sheet.
 - d. Nurse Call: Refer to Division 27.
 - e. Electronic Control: Per manufacturer recommendations and code requirements.
 - f. Audio/Visual Systems: Refer to Division 27.
 - g. Structured Cabling: Refer to Division 27.

3.7 CONTROL EQUIPMENT IDENTIFICATION

A. Products:

- 1. Nameplates and signs

- B. Provide identification on the front of all control equipment such as combination starters, starters, VFDs, contactors, motor control centers, etc.
- C. Identification shall be provided for all connections to equipment furnished by this Contractor, other contractors, or the Owner.
- D. Labeling shall include:
 - 1. Equipment type and contract documents designation of equipment being served.
 - 2. Location of equipment being served if it is not located within sight.
 - 3. Voltage and phase of circuit(s).
 - 4. Panel and circuit number(s) serving the equipment.
 - 5. Method of automatic control, if included ("AUTO CONTROL BY FMCS").
 - 6. Available fault current; refer to one-line diagram or panel schedule of panel serving equipment.
 - 7. Date of fault current study, refer to one-line diagram
 - 8. Sample Label:

EXHAUST FAN EF-1 ("LOCATED ON ROOF")
480V, 3-PHASE
FED FROM "1HA1-1"
AUTO CONTROL BY FMCS
22,000 AMPS AVAILABLE FAULT CURRENT
DATE OF STUDY: 1 JAN 2017

3.8 EQUIPMENT CONNECTION IDENTIFICATION

- A. Products:
 - 1. Nameplates and signs
- B. Provide identification for hard wired electrical connections to equipment such as disconnects switches, starters, etc. Plug and cord type connections do not require this specific label.
- C. Identification shall be provided for all connections to equipment furnished by this Contractor, other contractors, or the Owner. The following list of equipment is specifically being listed to receive an equipment connection label; this list does not limit the equipment that shall receive a label:
 - 1. Mechanical heating, ventilation, and air conditioning equipment; chillers, boilers, pumps, air handling ventilation units, condensing units, unit heaters, and similar equipment
 - 2. Plumbing equipment
- D. Labeling shall include:
 - 1. Equipment type and contract documents designation of equipment being served
 - 2. Location of equipment being served if it is not located within sight.
 - 3. Voltage and rating of the equipment.
 - 4. Panel and circuit numbers(s) serving the equipment
 - 5. Available fault current; refer to one-line diagram or panel schedule of panel serving equipment.

6. Date of fault current study; refer to one-line diagram
7. Sample Label:

UNIT HEATER UH-1 ("LOCATED IN STORAGE ROOM 200")
480V: 3-PHASE
FED FROM "1HA1-1"
22,000 AMPS AVAILABLE FAULT CURRENT
DATE OF STUDY: 1 JAN 2017

3.9 POWER DISTRIBUTION EQUIPMENT IDENTIFICATION

A. Products:

1. Nameplates and signs

B. Provide identification on the front of all power distribution equipment such as panelboards, switchboards, switchgear, motor control centers, generators, UPS, storage battery disconnects, transfer switches, etc. Labels shall be visible on the exterior of the gear, correspond to the one-line diagram nomenclature, and identify each cubicle of multi-section gear.

1. Interior Equipment: The identification material shall be engraved plastic-laminated labels.
2. Exterior Equipment: The identification material shall be engraved vinyl labels.
3. Labeling shall include:
 - a. Essential Electrical System EES: When applicable the label shall include "Essential Electrical System EES". Applicable equipment includes components of the life safety and critical branch for healthcare facilities (generators, transfer switches, switchboards, distribution panels, panelboards, etc.).
 - b. Equipment type and contract documents designation of equipment.
 - c. Voltage of the equipment.
 - d. Name of the upstream equipment and location of the upstream equipment if it is not located within sight.
 - e. Rating and type of the overcurrent protection device serving the equipment if it is not located within sight ("FED BY 400A/3P BREAKER").
 - f. Sample Label:

DISTRIBUTION PANEL DP-H1
480Y/277V
FED FROM SWITCHBOARD "SB-1" (LOCATED IN MAIN ELEC ROOM)

4. Provide the following on a separate label, installed below the label above:

- a. Available fault current; refer to one-line diagram or panel schedules
- b. Date of fault current study; refer to one-line diagram
- c. Sample Label:

22,000 AMPS AVAILABLE FAULT CURRENT
DATE OF STUDY: 1 JAN 2017

C. Service Equipment Label: A separate nameplate for the service entrance equipment and include:

1. Nominal system voltage, service wire size, quantity, material, distance
2. Maximum available fault current; refer to one-line diagram for values
3. Clearing time of overcurrent protection devices based on available fault current. Refer to calculations and report from Section 26 05 73 for value.
4. Date of fault current study; refer to one-line diagram
5. Date of label
6. Sample Label:

480Y/277V, 6 SETS 4#750KCM CU, 75FT
39,800 AMPS AVAILABLE FAULT CURRENT
0.07 SECOND CLEARING TIME
DATE OF STUDY: 1 JAN 2017
DATE OF LABEL: 4 JUL 2017

D. Arc Energy Reduction Label:

1. Provide a separate engraved plastic laminate label centered at the top of each vertical section of the electrical gear indicating the following when applicable.
 - a. Label: "This equipment is designed with a [system listed below]".
 - b. Applicable Systems:
 - 1) Zone-selective interlocking system for selective coordination and arc energy reduction
 - 2) Differential relaying system for selective coordination and arc energy reduction
 - 3) Arc energy reducing maintenance switch
 - 4) Energy reducing active arc flash mitigation system

E. Adjustable-Trip Over Current Protection Label:

1. Provide a separate engraved plastic laminate label adjacent to each overcurrent projection device with adjustable trip settings. Provide label separate from load identification label.
 - a. Label:
 - 1) Long-time delay:
 - 2) Long-time pickup:
 - 3) Short-time delay:
 - 4) Short-time pickup:
 - 5) Instantaneous:
 - 6) Ground fault delay:
 - 7) Ground fault:

b. Sample Label:

Long-time delay:	10.0
Long-time pickup:	1.0
Short-time delay:	0.15
Short-time pickup:	5.0
Instantaneous:	2.0
Ground fault delay:	0.25
Ground fault:	50.0

F. Nominal System Voltage Label:

1. Where more than one nominal voltage system exists in a building or facility, the identification of color coding used in the panelboard or equipment shall be permanently posted on the interior of the door or cover.

G. Distribution panelboards and switchboards shall have each overcurrent protection device identified with name and location of the load being served ("AHU-1 LOCATED IN PENTHOUSE 1"). Provide a separate engraved plastic laminate label adjacent to each overcurrent projection device with feeder wire size, feeder wire quantity, conductor material and distance in feet. Provide label separate from load identification label and adjustable trip settings label.

1. Sample Labels for Feeders:

4#3/0 CU & 1#6 CU GND, 125FT
4#250KCM AL & 1#6 GND CU, 125FT
2 SETS 4#400KCM CU & 1#1 GND CU, 125FT

H. Branch panelboards shall be provided with typed panel schedules upon completion of the project. Existing panelboards shall have their existing panel schedules typed, with all circuit changes, additions or deletions also typed on the panel schedules. A copy of all panel schedules for the project shall be turned over as part of the O&M Manuals. Refer to Section 26 05 00 for other requirements.

3.10 INDUSTRIAL CONTROL PANEL IDENTIFICATION

A. Products:

1. Nameplates and signs

B. Provide identification on the front of all industrial control panels and similar equipment. Labels shall be visible on the exterior of the gear and correspond to the one-line and/or schematic diagram nomenclature.

1. Interior equipment: The identification material shall be engraved plastic-laminated labels.
2. Labeling shall include:
 - a. Equipment type and contract documents designation of equipment.
 - b. Manufacturer / Assembler of industrial control panel
 - c. Voltage, phase, frequency, full load current of each supply circuit

- d. Name of the upstream equipment and location of the upstream equipment if it is not located within sight.
- e. Rating and type of the overcurrent protection device serving the equipment if it is not located within sight ("FED BY 400A/3P BREAKER").
- f. Sample Label:

INDUSTRIAL CONTROL PANEL ICP-1
ABC COMPANY
480V, 3PHASE, 60HZ, 60A (PANEL E1-1 LOCATED IN ELEC 123)
120V, 1PHASE, 60HZ, 20A (PANEL E2-1 LOCATED IN ELEC 123)
22,000 SHORT CIRCUIT RATING

C. Nominal System Voltage Label:

- 1. Where more than one nominal voltage system exists in a building or facility, the identification of color coding used shall be permanently posted on the interior of the door or cover of the industrial control panel.

D. Schematic Diagram: Provide a laminated copy of the industrial control panel schematic wiring diagram. Post the diagram on the inside cover of the control panel.

3.11 TRANSFORMER EQUIPMENT IDENTIFICATION

A. Products:

- 1. Nameplates and signs

B. Provide identification on the front of all transformers. The identification nameplate shall be an engraved plastic-laminated label.

C. Labeling shall include:

- 1. Equipment type and contract documents designation of equipment
- 2. Name of the upstream equipment.
- 3. Voltage and rating of the equipment.
- 4. Location of the upstream equipment if it is not located within sight.
- 5. Sample Label:

TRANSFORMER TR-15
480V: 208Y/120V 15KVA
FED FROM SWITCHBOARD "SB-1" (LOCATED IN ELEC 123)

3.12 DC VOLTAGE EQUIPMENT IDENTIFICATION

A. Products:

- 1. Names and signs

B. Provide identification on the front of all DC voltage equipment, storage batteries, disconnects. The identification nameplate shall be engraved plastic-laminate label.

C. Label shall include:

1. Equipment type and contract documents designation of equipment.
2. Name of upstream equipment and location of the upstream equipment if it is not located within sight.
3. Nominal equipment voltage and rating.
4. Available fault current (from batteries if applicable).
5. Date of fault current study; refer to one-line diagram.
6. Sample Label:

STORAGE BATTERY SB-1
600 VOLT DC, 50 KVA
39,800 AMPS AVAILABLE FAULT CURRENT
DATE OF STUDY: 1 JAN 2017

3.13 ELECTRICAL WORKING CLEARANCE IDENTIFICATION

A. Products:

1. Safety Yellow paint and custom stencils

B. Provide custom identification of electrical equipment working clearances in mechanical, electrical, storage, janitorial, and similar non-public areas.

END OF SECTION 26 05 53

SECTION 26 22 00 - DRY TYPE TRANSFORMERS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Dry type two winding transformers (TR-#)

1.2 REFERENCES

- A. NEMA - ST 1 - Specialty Transformers
- B. NEMA ST 20 - Dry Type Transformers for General Applications
- C. ANSI/IEEE C57.12.01 - General Requirements for Dry Type Distribution and Power Transformers
- D. ANSI/IEEE C57.12.91 - Test Code for Dry Type Distribution and Power Transformers
- E. Department of Energy 10 CFR Part 431 - Energy Conservation Program for Commercial Equipment: Distribution Transformers Energy Conservation Standards; Final Rule.
- F. NEMA TP 2 - Standard Test Method for Measuring the Energy Consumption of Distribution Transformers
- G. NEMA TP 3 - Standard for the Labeling of Distribution Transformer Efficiency

1.3 SUBMITTALS

- A. Submit product data under provisions of Section 26 05 00.
- B. Include outline and support point dimensions of enclosures and accessories, unit weight, voltage, KVA, and impedance ratings and characteristics, loss data, efficiency at 35, 50, 75 and 100 percent rated load, sound level, tap configurations, insulation system type, and rated temperature rise.

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Store and protect products under provisions of Section 26 05 00.
- B. Store in a warm, dry location with uniform temperature. Cover ventilating openings to keep out dust.
- C. Handle transformers using only lifting eyes and brackets provided for that purpose. Protect units against entrance of rain, sleet, or snow if handled in inclement weather.

PART 2 - PRODUCTS

2.1 DRY TYPE TWO WINDING TRANSFORMERS

A. Acceptable Manufacturers:

1. Square D 7400 EX##T / SK300##KB Series
2. Eaton V48M / H48M / B48M Series
3. ABB 9T Series
4. Hammond SG / SMK Series
5. Siemens 3F3 Series

B. Dry Type Transformers: NEMA ST 20, factory-assembled, air-cooled dry type transformers; ratings as shown on the drawings. Transformers supplied under this project shall meet the US Department of Energy (DOE) 2016 Efficiency requirements or the most current DOE CFR in effect.

C. Insulation system and average winding temperature rise for rated KVA as follows:

Ratings	Class	Rise (degree C)
Less than 15	185	As shown on the drawings
or higher	220	As shown on the drawings

D. Case temperature shall not exceed 40°C rise above ambient at its warmest point.

E. Winding Taps, Transformers Less than 15 KVA: Two 5 percent below rated voltage, full capacity taps on primary winding.

F. Winding Taps, Transformers 15 KVA and Larger: Two (2) 2-1/2% below and two (2) 2-1/2% above rated voltage, full capacity taps on primary winding.

G. Sound Levels: Average audible sound level shall not exceed the values given below when tested to NEMA ST 20 standards:

	Average Sound Level, Decibels			
	Self-Cooled Ventilated			Self-Cooled Sealed
Equivalent Winding kVA Range	K-Factor = 1 K-Factor = 4 K-Factor = 9	K-Factor = 13 K-Factor = 20	Forced Air w/ Fans Running	
0-9	40	40	67	45
9.01-30.00	45	45	67	50
30.01-50.00	45	48	67	50
50.01-150.00	50	53	67	55
150.01-300.00	55	58	67	57
300.01-500.00	60	63	67	59
500.01-700.00	62	65	67	61

	Average Sound Level, Decibels			
	Self-Cooled Ventilated			Self-Cooled Sealed
Equivalent Winding kVA Range	K-Factor = 1 K-Factor = 4 K-Factor = 9	K-Factor = 13 K-Factor = 20	Forced Air w/ Fans Running	
700.00-1000.00	64	67	67	63

- H. Ground core and coil assembly to enclosure by means of a visible flexible copper grounding strap.
- I. Mounting: Transformers 75 KVA and less shall be suitable for wall, floor, or trapeze mounting; transformers larger than 75 KVA shall be suitable for floor or trapeze mounting.
- J. Coil Conductors: Continuous windings with terminations brazed or welded.
- K. Enclosure: NEMA ST 20; Type 1. Provide lifting eyes or brackets.
- L. Isolate core and coil from enclosure using vibration-absorbing mounts.
- M. Nameplate: NEMA TP 3; Include transformer connection data and overload capacity based on rated allowable temperature rise.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Set transformer plumb and level.
- B. Use flexible conduit, 2 feet minimum length, for connections to transformer case. Make conduit connections to side panel of enclosure.
- C. Mount transformers on four 3"x3"x1/2" thick, 50 durometer rubber vibration isolating pads suitable for isolating the transformer noise from the building structure.
- D. Ventilated transformers: Provide factory label on horizontal surface to prohibit storage on top, front, or adjacent to transformer.

3.2 FIELD QUALITY CONTROL

- A. Check for damage and tight connections prior to energizing transformer.
- B. Measure primary and secondary voltages and make appropriate tap adjustments. Adjustments shall be made at completion of project and at approximately 6 months following project acceptance when requested by the Owner.

END OF SECTION 26 22 00

SECTION 26 24 16 - PANELBOARDS

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Lighting and appliance branch circuit panelboards: Panel '###'

1.2 RELATED SECTIONS AND WORK

- A. Refer to the Electrical Distribution Diagram and Electrical Schedules for size, rating, and configuration.

1.3 REFERENCES

- A. NEMA AB 1 - Molded Case Circuit Breakers
- B. NEMA FU 1 - Low voltage cartridge fuses
- C. NEMA KS 1 - Enclosed Switches
- D. NEMA PB 1 - Panelboards
- E. NEMA PB 1.1 - Instructions for Safe Installation, Operation and Maintenance of Panelboards Rated 600 Volts or Less
- F. NEMA PB 1.2 - Application Guide for Ground-fault Protective Devices for Equipment
- G. UL 248 - Low-Voltage Fuses
- H. UL 67 - Panelboards

1.4 SUBMITTALS

- A. Submit shop drawings for equipment and component devices under provisions of Section 26 05 00.
- B. Include outline and support point dimensions, voltage, main bus ampacity, integrated short circuit ampere rating, circuit breaker and fusible switch arrangement and sizes.
- C. Selective Coordination Study: Submit study to prove that all essential electrical systems, emergency systems and legally required standby system panelboards are selectively coordinated with all supply side overcurrent protective devices.
- D. Arc Energy Reduction Documentation: Submit documentation to demonstrate the arc energy reduction system is set to operate at a value below the available arcing current.
- E. Submit manufacturer's instructions under provisions of Section 26 05 00.

1.5 SPARE PARTS

- A. Keys: Furnish four (4) each to the Owner.
- B. Fuses: Furnish 10% or a minimum of three (3) spare fuses of each type and rating installed to the Owner.
- C. Fuse Pullers: Furnish one (1) fuse puller to the Owner.

PART 2 - PRODUCTS

2.1 RATINGS

- A. Definitions:
 - 1. Fully rated equipment shall be defined as equipment where all devices in that equipment shall carry a minimum of the AIC rating that is specified.
- B. The panelboards for this project shall be fully rated unless otherwise specifically noted in the Drawings or Specifications.

2.2 BRANCH CIRCUIT PANELBOARDS

- A. General
 - 1. Manufacturers:
 - a. Square D NQ, NF
 - b. Siemens P1
 - c. Eaton PRL1, PRL2
- B. Lighting and Appliance Branch Circuit Panelboards: NEMA PB 1; circuit breaker type.
- C. Enclosure: NEMA PB 1; Type 1.
- D. Provide cabinet front with door-in-door construction, concealed hinge, and flush lock all keyed alike. Door hardware shall provide swing clear operation (180-degree swing). Finish in manufacturer's standard gray enamel.
- E. Provide panelboards with copper bus, ratings as scheduled on the drawings. Provide copper ground bus in all panelboards.
- F. All unlabeled circuits shown on the panelboard schedule shall be fully prepared spaces for future breakers.
- G. All multiple-section panelboards shall have the same dimensional back box and cabinet front size.
- H. Minimum Integrated Short Circuit Rating: As shown on the drawings.

- I. Provide handle lock-on devices for all breakers serving exit sign and lighting circuits with emergency battery units. Provide handle lock-on devices and red handles for breakers serving fire alarm panels.
- J. Molded Case Circuit Breakers: Bolt-on type thermal magnetic trip circuit breakers, with common trip handle for all poles. Provide circuit breakers UL listed as Type SWD for lighting circuits. Provide UL Class A ground fault interrupter circuit breakers where scheduled on the drawings. Do not use tandem circuit breakers.
- K. Current Limiting Molded Case Circuit Breakers: Provide circuit breakers with integral thermal and instantaneous magnetic trip in each pole, coordinated with automatically resetting current limiting elements in each pole. Interrupting rating 100,000 symmetrical amperes, let-through current and energy level less than permitted for same size Class RK-5 fuse.
- L. Suitable for use as service entrance equipment. Provide line side (service style) barriers.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install panelboards plumb as indicated on the drawings in conformance with NEMA PB 1.1.
- B. Height: 6 feet to handle of highest device.
- C. Provide filler plates for unused spaces in panelboards.
- D. Provide custom typed circuit directory for each branch circuit panelboard. Provide updated custom typed circuit directory for each existing branch circuit panelboard with new or revised circuits per the scope of work. Label shall include equipment name or final approved room name, room number, and load type for each circuit (examples: SUMP SP-1 or ROOM 101 RECEIPT). Revise directory to reflect circuit changes required to balance phase loads. Printed copies of the bid document panel schedules are not acceptable as circuit directories.
- E. Stub five (5) empty one-inch conduits to accessible location above ceiling out of each recessed panelboard.

3.2 FIELD QUALITY CONTROL

- A. Measure steady state load currents at each panelboard feeder. Should the difference at any panelboard between phases exceed 20 percent, rearrange circuits in the panelboard to balance the phase loads within 20 percent. Take care to maintain proper phasing for multi-wire branch circuits.
- B. Visual and Mechanical Inspection: Inspect for physical damage, proper alignment, anchorage, and grounding. Check proper installation and tightness of connections for circuit breakers, fusible switches, and fuses.

END OF SECTION 26 24 16

SECTION 26 27 16 - CABINETS AND ENCLOSURES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Hinged cover enclosures
- B. Cabinets
- C. Terminal blocks and accessories

1.2 REFERENCES

- A. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum)
- B. ANSI/NEMA ICS 1 - Industrial Control and Systems
- C. ANSI/NEMA ICS 4 - Terminal Blocks for Industrial Control Equipment and Systems
- D. ANSI/NEMA ICS 6 - Enclosures for Industrial Control Equipment and Systems

1.3 SUBMITTALS

- A. Submit product data under provisions of Section 26 05 00.
- B. Shop Drawings for Equipment Panels: Include wiring schematic diagram, wiring diagram, outline drawing and construction diagram as described in ANSI/NEMA ICS 1.
- C. Include cabinets and enclosures in composite electronic coordination files. Refer to Section 26 05 00 for coordination drawing requirements.

PART 2 - PRODUCTS

2.1 HINGED COVER ENCLOSURES

- A. Construction: NEMA 250; Type 1 14 gauge steel. Provide stainless steel construction for operating rooms, invasive procedure rooms, and medical scanning rooms.
- B. Finish: Manufacturer's standard polyester powder paint finish.
- C. Covers: Continuous hinge with stainless steel hinge pin. Covers longer than 24 inches shall have 3-point latching.
- D. Locks: Flush 1/4 turn cylinder key latch.
- E. Provide interior white painted metal panel for mounting terminal blocks and electrical components.

2.2 CABINETS

- A. Cabinet Boxes: Galvanized steel with removable endwalls, Insert inches wide, Insert inches high, Insert inches deep.
- B. Cabinet Fronts: Steel, flush type with concealed trim clamps, concealed hinge and flush lock keyed to match branch circuit panelboard; finish in gray baked enamel.

2.3 TERMINAL BLOCKS AND ACCESSORIES

- A. Terminal Blocks: ANSI/NEMA ICS 4; UL listed.
- B. Power Terminals: Unit construction type, closed-back type, with tubular pressure screw connectors, rated 600 volts.
- C. Signal and Control Terminals: Modular construction type, channel mounted; tubular pressure screw connectors, rated 300 volts.

2.4 FABRICATION

- A. Shop assemble enclosures and cabinets housing terminal blocks or electrical components in accordance with ANSI/NEMA ICS 6.
- B. Provide conduit hubs on enclosures.
- C. Provide protective pocket inside front cover with schematic diagram, connection diagram, and layout drawing of control wiring and components within enclosure.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install cabinets and enclosures plumb; anchor securely to wall and structural supports at each corner, minimum.
- B. Provide accessory feet for free-standing equipment enclosures.
- C. Install trim plumb.

END OF SECTION 26 27 16

SECTION 26 27 26 - WIRING DEVICES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Device plates and box covers
- B. Receptacles (REC-#)
- C. Cord and plug sets

1.2 QUALITY ASSURANCE

- A. Provide similar devices from a single manufacturer.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in the Electrical Code, by a testing agency to Authorities Having Jurisdiction and marked for intended use.
- C. Comply with the Electrical Code.

1.3 REFERENCES

- A. DSCC W-C-896F - General Specification for Electrical Power Connector
- B. FS W-C-596 - Electrical Power Connector, Plug, Receptacle, and Cable Outlet
- C. NEMA WD 1 - General Color Requirements for Wiring Devices
- D. NEMA WD 6 - Wiring Devices - Dimensional Requirements
- E. NFPA 70 - National Electrical Code (NEC)
- F. CEC California Electrical Code
- G. UL 498 - Standard for Attachment Plugs and Receptacles
- H. UL 943 - Standard for Ground Fault Circuit Interrupters

1.4 SUBMITTALS

- A. Submit product data under provisions of Section 26 05 00.
- B. Provide product data showing configurations, finishes, dimensions, and manufacturer's instructions.
- C. Provide a non-returnable sample of each countertop and furniture-mounted receptacle assembly as part of the submittal process.

1.5 COORDINATION

- A. Receptacles for Owner Furnished Equipment: Match plug configurations.
- B. Cord and Plug Sets: Match equipment requirements.

PART 2 - PRODUCTS

2.1 DEVICE COLOR

- A. All switch, receptacle, and outlet colors shall be ivory, unless indicated otherwise.

2.2 COVERPLATES

- A. All switches, receptacles, and outlets shall be complete with the following:
 - 1. #302 stainless steel coverplates in finished spaces where walls are finished.
 - 2. #302 stainless steel coverplates in unfinished spaces for flush boxes.
 - 3. Galvanized steel coverplates in unfinished spaces for surface mounted boxes.
- B. Where several devices are ganged together, the coverplate shall be of the ganged style for the number of devices used.
- C. Install nameplate identification as indicated in Section 26 05 53.
- D. Plate securing screws shall be metal with head color matching the wall plate finish.

2.3 RECEPTACLES

- A. Refer to Electrical Symbols List for device type.
- B. Devices that are shaded on the drawings shall be red.
- C. Devices that are shaded on the drawings shall be red and shall have an illuminated face or indicator light to indicate that there is power to the device.
- D. REC-DUP: NEMA 5-20R Duplex Receptacle:
 - 1. Spec Grade: 125-volt, 20 amp, 3-wire grounding type with impact resistant thermoplastic face and brass back strap.
 - a. Manufacturers:
 - 1) Hubbell 5352
 - 2) Leviton 5362-S
 - 3) Pass & Seymour 5362
 - 4) Cooper 5362

2. Heavy Duty: 125-volt, 20 amp, 3-wire grounding type heavy duty industrial grade with impact resistant thermoplastic face and one-piece brass back strap with integral ground contacts.
 - a. Manufacturers:
 - 1) Hubbell 5362
 - 2) Leviton 5362
 - 3) Pass & Seymour 5362A
 - 4) Cooper AH5362

- E. REC-DUP-GFI: NEMA 5-20R Ground Fault Duplex Receptacle:
 1. Standard Grade: 125-volt, 20 amp, 3-wire grounding type with test and reset buttons in impact resistant thermoplastic face.
 - a. Device shall perform self-test of GFCI circuitry in accordance with UL 943.
 - b. Manufacturers:
 - 1) Hubbell GF20L
 - 2) Leviton GFNT2
 - 3) Pass & Seymour 2097
 - 4) Cooper SGF20

- F. REC-DUP-GFI-R: Remote Ground Fault Device:
 1. Ground fault device for remote downstream receptacles. 125-volt, 20 amp. Test and reset buttons in impact resistance thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell GFBF20
 - 2) Leviton 6895
 - 3) Pass & Seymour 2085
 - 4) Cooper VGFD20

- G. REC-DUP-WP: NEMA 5-20R Weatherproof Ground Fault Duplex Receptacle:
 1. 125-volt, 20 amp, 3-wire grounding type with test and reset buttons in impact resistant thermoplastic face, weather resistant WR listed. Provide extra-duty NEMA 3R rated while-in-use clear cover.
 2. Device shall perform self-test of GFCI circuitry in accordance with UL 943.
 - a. Manufacturers:
 - 1) Hubbell GFTWRST20 with clear housing RW57300
 - 2) Leviton GFWT2 with clear housing 5977-CL
 - 3) Pass & Seymour 2097TRWR with clear housing WIUC10-C
 - 4) Cooper WRS GF20 with clear housing WIU-1

H. REC-SIM-520R: NEMA 5-20R Simplex Receptacle:

1. 125-volt, 20 amp, 3-wire grounding type with impact resistant thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell HBL5361
 - 2) Leviton 5361
 - 3) Pass & Seymour 5361
 - 4) Cooper 5361

I. REC-SIM-620R: NEMA 6-20R Simplex Receptacle:

1. 250-volt, 20 amp, 2-pole, 3-wire grounding type with thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell HBL5461
 - 2) Leviton 5461
 - 3) Pass & Seymour 5871
 - 4) Cooper 5461

J. REC-SIM-750R: NEMA 7-50R Simplex Receptacle:

1. 277-volt, 50 amp, 2-pole, 3-wire grounding type with thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell HBL9365
 - 2) Leviton 9750-A
 - 3) Pass & Seymour
 - 4) Cooper

K. REC-SIM-L530R: NEMA L5-30R Simplex Receptacle Locking Type:

1. 125-volt, 30 amp, 2-pole, 3-wire grounding type with impact resistant thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell
 - 2) Leviton
 - 3) Pass & Seymour L530
 - 4) Cooper CWL530R

L. REC-SIM-L1630R: NEMA L16-30R Locking Type Simplex Receptacle:

1. 480-volt, 30 amp, 3-pole, 4-wire grounding type with thermoplastic face.
 - a. Manufacturers:
 - 1) Hubbell HBL2730

- 2) Leviton 2730
- 3) Pass & Seymour L1630R
- 4) Cooper CWL1630R

- M. REC-QUAD: NEMA 5-20R Double Duplex Receptacle:
1. Consists of two duplex receptacles, double gang box, plaster ring and faceplate.
 - a. Manufacturers:
 - 1) Refer to Duplex Receptacle above.
- N. REC-QUAD-GFI: NEMA 5-20R Double Duplex GFI Receptacle:
1. Consists of two duplex GFI receptacles, double gang box, plaster ring and faceplate.
 - a. Manufacturers:
 - 1) Refer to Duplex GFI Receptacle above.
- O. Back wired devices shall be complete with eight holes that are screw activated with metal clamps for connection to #12 or #10 copper conductors.
- P. Side wired devices shall have four binding screws that are undercut for positive wire retention.
- Q. Ground fault circuit interrupter (GFCI) receptacles shall comply with UL 943 requiring increased surge immunity, improved corrosion resistance, improved resistance to false tripping and diagnostic indication for miswiring if the line and load conductors are reversed during installation.
- R. Isolated ground receptacles shall have the equipment ground contacts connected only to the green grounding screw terminal of the device with inherent electrical isolation from the mounting strap.
- S. Integral surge suppression receptacles with integral surge suppression shall comply with the following:
1. Category A3 listed.
 2. Line to ground, line to neutral, and neutral to ground modes.
 3. Metal-oxide varistors with a nominal clamp level rating of 500 volts and minimum single transient pulse energy dissipation of 210 joules per mode.
 4. Status indication: Light visible in the face of the device and audible alarm to indicate device is no longer active or in service.
 5. Distinctive symbol on device face to denote SPD-type device.
 6. Device shall be blue with blue coverplate.
 7. NEMA 5-20R duplex receptacle, 125-volt, 20 amp, 3-wire grounding type heavy duty industrial grade with impact resistant thermoplastic face and one-piece brass back strap.
 - a. Manufacturers:
 - 1) Hubbell HBL5362SA

- 2) Leviton
- 3) Pass & Seymour
- 4) Cooper

T. Hazardous (Classified) location receptacles shall comply with NEMA FB 11.

2.4 CORD AND PLUG SETS

- A. Description: Match voltage and current ratings and number of conductors to requirements of equipment being connected.
1. Cord: Rubber-insulated, stranded copper conductors, with Type SOW-A jacket; with green insulated grounding conductor and equipment rating ampacity plus a minimum of 30 percent.
 2. Plug: Nylon body and integral cable-clamping jaws. Match cord and receptacle type for connection, FS/UL listed.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install convenience receptacles at elevations indicated in the General Installation Notes on the contract drawings.
- B. Install specific-use receptacles at heights shown on the contract drawings. Install devices level, plumb, and square with building lines. Coordinate installation of adjacent devices of separate systems with common mounting heights, including lighting, power, systems, technology, and temperature control device rough-ins.
- C. Ground Fault Protection: Provide ground fault protection for all branch circuit breakers serving 120/208 receptacle outlets rated 21 - 50 amps single phase and 21-100 amps three phase in the following locations, as shown on drawings, or required by adopted code:
1. Bathrooms, locker rooms, shower rooms
 2. Kitchens
 3. Rooftops
 4. Interior/Exterior locations subject to damp/wet conditions
 5. When located within 6 feet of sinks, bathtubs, and shower stalls
 6. Garages, accessory buildings, service bays
- D. Drill opening for poke-through fitting installation in accordance with manufacturer's instructions. This Contractor is responsible for taking any measures required to ensure no conduits or other services are damaged. This may include X-ray or similar non-destructive means.
- E. Install receptacles vertically with ground slot up or where indicated on the drawings, horizontally with ground slot to the left.
- F. Install decorative plates on switch, receptacle, and blank outlets in finished areas, using jumbo size plates for outlets installed in masonry walls.

- G. Install galvanized steel plates on outlet boxes and junction boxes in unfinished areas, above accessible ceilings, and on surface-mounted outlets.
- H. Install devices and wall plates flush and level.
- I. Install nameplate identification to receptacle cover plates indicated. Identification shall identify panel name and circuit number. Refer to Specification Section 26 05 53 - Electrical Identification.
- J. Test receptacles and modular wiring connectors for proper polarity, ground continuity and compliance with requirements.

END OF SECTION 26 27 26

SECTION 26 28 13 - FUSES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Fuses

1.2 REFERENCES

- A. UL 198C - High-Interrupting Capacity Fuses; Current Limiting Types
- B. UL 198E - Class R Fuses
- C. FS W-F-870 - Fuseholders (For Plug and Enclosed Cartridge Fuses)
- D. NEMA FU 1 - Low Voltage Cartridge Fuses
- E. NFPA 70 - National Electrical Code (NEC)

1.3 SUBMITTALS

- A. Submit product data under provisions of Section 26 05 00.

1.4 EXTRA MATERIALS

- A. Provide two fuse pullers.
- B. Provide three of each size and type of fuse installed.

1.5 PROJECT CONDITIONS

- A. Where ambient temperature to which fuses are directly exposed is less than 40°F or more than 100°F, apply manufacturer's ambient temperature adjustment factors to fuse ratings.

PART 2 - PRODUCTS

2.1 MANUFACTURERS - FUSES

- A. Bussman, Division of Eaton
- B. Edison Fuse, Division of Cooper Industries
- C. Mersen
- D. Littelfuse Inc

2.2 FUSES

- A. Dimensions and Performance: NEMA FU 1, Class as specified or indicated.
- B. Voltage: Provide fuses with voltage rating suitable for circuit phase-to-phase voltage.
- C. Fuses with ratings larger than 600 amperes: Class L (time delay), unless otherwise noted on the drawings.
- D. Fuses with ratings larger than 200 amperes but equal to or less than 600 amperes: Class RK-1 (time delay), unless otherwise noted on the drawings.
- E. Fuses with ratings less than or equal to 200 amperes (not including control transformer fuses): Class RK-5, unless otherwise noted on the drawings.
- F. Control transformer fuses: Class CC (time delay).
- G. Fuses for packaged equipment: Size and type as recommended by equipment manufacturer.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install fuses where indicated on the drawings and specifications.
- B. Install fuses in accordance with manufacturer's instruction.
- C. Install fuses in packaged equipment as required by equipment manufacturer.
- D. Install fuse with label oriented such that manufacturer, type, and size are easily read.

END OF SECTION 26 28 13

SECTION 26 28 16 - DISCONNECT SWITCHES

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Fusible switches
- B. Non-fusible switches
- C. Molded case circuit switches
- D. Molded case switches
- E. Motor disconnect switch
- F. Mechanically interlocked disconnect
- G. Elevator Service Disconnect Switch
- H. Mobile Diagnostics Service Disconnect
- I. Enclosures

1.2 RELATED SECTIONS AND WORK

- A. Refer to the Disconnect and Starter Schedule for rating and configuration.

1.3 REFERENCES

- A. NEMA KS 1 - Enclosed Switches

1.4 SUBMITTALS

- A. Submit product data under provisions of Section 26 05 00.
- B. Product Data: For each type of enclosed switch, circuit breakers, accessory and component indicated, include dimensions, weights, and manufacturer's technical data on features, performance, and ratings.
- C. Electrical Characteristics: For each type of enclosed switch, enclosure types, current and voltage ratings, short-circuit current ratings, UL listing for series rating of installed devices, features, characteristics, ratings, and factory settings of individual overcurrent protective devices and auxiliary components.

1.5 COORDINATION

- A. Coordinate layout and installation of switches, circuit breakers, and components with other construction, including conduit, piping, equipment, and adjacent surfaces. Maintain required workspace clearances and required clearances for equipment access doors and panels.

PART 2 - PRODUCTS

2.1 FUSIBLE AND NON-FUSIBLE SWITCHES

- A. Acceptable Manufacturers:
 - 1. Square D 3110 Series
 - 2. Eaton DH Series
 - 3. ABB TH Series
 - 4. Siemens HNF / HF Series
- B. FDS-; Fusible Switch Assemblies: NEMA KS 1; Type heavy duty, quick-make, quick-break, load interrupter enclosed knife switch with externally operable handle interlocked to prevent opening front cover with switch in ON position. Handle lockable in OFF position. Fuse Clips: Class 'R' fuse clips only, unless indicated otherwise on the drawings.
- C. DS-; Non-fusible Switch Assemblies: NEMA KS 1; Type heavy duty, quick-make, quick-break, load interrupter enclosed knife switch with externally operable handle interlocked to prevent opening front cover with switch in ON position. Handle lockable in OFF position.
- D. Enclosures: Type as indicated on the disconnect schedule.
- E. Accessories: As indicated on the disconnect schedule.

2.2 MOLDED CASE CIRCUIT BREAKERS AND SWITCHES

- A. Acceptable Manufacturers:
 - 1. Square D
 - 2. Eaton
 - 3. ABB
 - 4. Siemens
- B. CB-; Molded Case Circuit Breaker: NEMA AB 1, with interrupting capacity to meet available fault currents.
 - 1. Thermal Magnetic Circuit Breakers: Inverse time-current element for low-level overloads and instantaneous magnetic trip element for short circuits. Adjustable magnetic trip setting for circuit-breaker frame sizes 250 A and larger.
 - 2. Adjustable Instantaneous Trip Circuit Breakers: Magnetic trip element with front-mounted, field-adjustable trip settings.
 - 3. Electronic Trip Unit Circuit Breakers: RMS sensing; field-replaceable rating plug; with the following field-adjustable settings:
 - a. Instantaneous trip.
 - b. Long- and short-time pickup levels.
 - c. Long- and short-time adjustments.
 - d. Ground-fault pickup level, time delay, and I²t responses.
 - 4. Current Limiting Circuit Breakers: Frame sizes 400 A and smaller and let-through ratings less than NEMA FU 1, RK-5.

- C. CB-; Molded Case Switches: Molded case circuit breaker with fixed, high-set instantaneous trip only, and short-circuit withstand rating equal to equivalent breaker frame size interrupting rating.
- D. Accessories: As indicated on the disconnect schedule.

2.3 MOTOR DISCONNECT SWITCH

- A. Acceptable Manufacturers:
 - 1. Square D 3110 Series
 - 2. Eaton r5 Series
 - 3. ABB ML Series
 - 4. Siemens LBR Series
- B. MD-; Rotary Switch Assemblies: Rated for making and breaking loads, rotary type enclosed switch with externally operable handle interlocked to prevent opening front cover with switch in ON position. Handle lockable in OFF position.
- C. Enclosures: Type as indicated on the Disconnect Schedule.
- D. Ground lug connection provided in enclosure.
- E. Accessories: As indicated on the Disconnect Schedule.
- F. Listed UL 508 suitable for motor control.

2.4 MECHANICALLY INTERLOCKED DISCONNECT

- A. Acceptable Manufacturers:
 - 1. Disconnect
 - a. Square D 3110 Series
 - b. Eaton DH Series
 - c. ABB TH Series
 - d. Siemens HF Series
 - 2. Receptacle
 - a. Crouse-Hinds Arktite
 - b. Appleton Powertite
- B. DSS-; Switch and Plug Assemblies: Rated for making and breaking loads, enclosed switch with externally operable interlock to prevent disconnecting receptacle with switch in ON position or inserting receptacle in ON position. Padlock lockable provision to meet OSHA lockout/tagout regulations.
- C. Enclosures: Type as indicated on the Disconnect Schedule.
- D. Ground lug connection provided in enclosure.

- E. Accessories: Matching male pin and sleeve plug, two auxiliary/pilot contacts. As indicated on the Disconnect Schedule.
- F. Listed UL 2682 suitable for motor disconnect.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Install disconnect switches where indicated on the drawings.
- B. Install fuses in fusible disconnect switches.
- C. Provide adhesive label on inside door of each switch indicating UL fuse class and size for replacement.

3.2 ADJUSTING

- A. Set field-adjustable circuit breaker trip ranges.

END OF SECTION 26 28 16