

## Questions & Answers - 1

**Project** 22-727-001 - Bus Fueling Station Design and Install  
**Buying Organization** Poudre School District

| No | Question/Answer  | Question Date |
|----|--|---------------|
| Q1 | <p><b>Question: Setbacks for ASTs</b></p> <p>According to the Colorado Department of Labor and Employment - Division of Oil and Public Safety Storage Tank Regulations (7 C.C.R. 1101-14), the minimum setback for the 10,000-gallon protected AST (UL 2085), that is being delivered for this project, is 25 feet from a property line that can be built upon. As shown on the provided to-scale drawing, the distance between the property fence and the edge of asphalt is around 20 feet. As such, the western side of the new AST will need to be placed on the edge or near the edge of existing asphalt with the full tank and bollards encroaching approximately 16 feet into the asphalt. There is no need for a retaining wall. As such can we exclude pricing for this from our bid response?</p> <p><b>Answer:</b> The District has received conflicting guidance on the setback and would like bidders to provide both plan options. The District will seek clarification on the setback.</p> | 04/11/2022    |
| Q2 | <p><b>Question: Tank Gauge Monitoring</b></p> <p>At the time of the site visit, the District stated that they did not need the tank gauge monitoring system to be located in an office (a waterproof cabinet near the tank location would be fine). Please confirm that the District has not changed their mind on this. If they have, an additional 2 or 3 conduits will need to be placed when the District runs the new power service to the tank site.</p> <p><b>Answer:</b> The District has not changed this thinking.</p>   | 04/11/2022    |