

## Questions & Answers - 1

**Project** 23-178-001 - Solar Shade Structure Design and Installation  
**Buying Organization** Poudre School District

No	Question/Answer	Question Date
Q1	<p><b>Question: Minor Amendment</b></p> <p>We're assuming that there will not be a minor amendment process with this project since this will be permitted through the state but would like a confirmation.</p> <p><b>Answer:</b> The District is a state property so does not go through local jurisdiction except for Fire Department. The District will pay for permit fees with the State and Poudre Fire Authority if needed. The Contractor is required to file for permits. There would not be a minor amendment process with the City of Fort Collins.</p>	09/23/2022
Q2	<p><b>Question: Structure Setbacks</b></p> <p>Is there a certain distance you folks would like the structure to be placed away from the school building so that kids do not climb either structure.</p> <p><b>Answer:</b> A minimum of 8-10 ft.</p>	09/23/2022
Q3	<p><b>Question: Electrical Tie-in</b></p> <p>Would you folks like us to submit a separate line item for what it would cost for Sandbox to conduct the electrical tie-in or should we assume that you folks are going to be taking care of this portion of the project?</p> <p><b>Answer:</b> The bid should include all electrical from the solar shade structure to the electrical room. Once the power reaches the electrical room, the District will provide the manpower and materials from the inverter to the main electrical panel. The District may install an isolated disconnect between the main electrical service and the inverter but will provide manpower and materials for this isolated disconnect.</p>	09/23/2022