

Questions & Answers - 1

Solicitation 21-700-001 - Fire Alarm Replacement Projects
Buying Organization Poudre School District

No	Question/Answer	Question Date
Q1	<p>Question: Fire Alarm Replacements</p> <p>1) are additional speakers required beyond what is shown on the drawings for alternate 2 upgrade to voice evacuations? 2) is there a requirement for 10% of spare devices for stock?</p> <p>Answer: There are no drawings for alternate 2. The alternate to voice evacuation, at this time, is design build.</p> <p>10% added spare devices are not required for stock. 10% added devices are required for installed notification appliances.</p>	10/28/2020
Q2	<p>Question: Fire Alarm Inspection</p> <p>We are reviewing the documents for the Fire Alarm Replacement Project as posted on BidNet, and are aware of the walkthrough on 10/30.</p> <p>Do you anticipate releasing a bid for the inspection and monitoring services on the Fire Alarm Systems at Poudre School District as well?</p> <p>Answer: No, ITM is in house by Poudre School District. Monitoring and existing monitoring by Safe Systems of the schools will not change. Bosch programming in Alternate 3 will be by PSD.</p>	10/30/2020
Q3	<p>Question: Data Cabling Needs</p> <p>21-700-001 - Fire Alarm Replacement Projects</p> <p>We are currently under contract pulling Data Cables in all 55 District Buildings over the next year. Is there any desire to add the Fire Alarm Category Data Cabling Needs to our scope while we are in each building?</p> <p>Answer: Required data cable in Alternate 3 shall be installed at the Bosch communicator.</p>	11/02/2020